

PLATINUM ENERGY SERVICES ULC
SUITE 400, 333 - 11 AVENUE S.W. CALGARY, ALBERTA T2R 1L9

Date Printed: 2/12/2016

VESSEL DESCRIPTION

TWO (2) 8'-0" OD x 30'-0" LONG TREATERS

Vessel designed with DesignCalcs, Version: 2016.1
Vessel is ASME Code Stamped

Wind Analysis performed in accordance with ASCE 7-10
Seismic Analysis performed in accordance with ASCE 7-10

Job No: 30137 & 30138

Vessel Number: 01

NAMEPLATE INFORMATION

Vessel MAWP: 75.00 PSI at 350 °F

MDMT: -20 °F at 75.00 PSI

Serial Number(s): 30137 & 30138

National Board Number(s): _____

Canadian Registration Number(s): TBA

Year Built: 2016

Radiography: RT 2

Postweld Heat Treated: NONE

Construction Type: W

Notes

BUILT IN ACCORDANCE WITH ASME SECTION VIII, DIV 1, 2015 EDITION

UG-22 LOADINGS HAVE BEEN CONSIDERED

CALCULATION NO: 30137/8-VES-01 REV 0

Signatures

BOB DAVIES: _____



Date: 16 / 02 / 12

Table of Contents

8'-0" OD x 30'-0" LONG SHELL	1
96" OD FLANGED & DISHED HEAD C/W 1.5" SF (RIGHT SIDE)	2
8'-0" OD FLANGED & DISHED HEAD C/W 1.5" SF (LEFT SIDE)	3
4" 150# RFSO (N1)	4
3" 150# RFSO (N2)	7
3" 150# RFSO (N3)	9
3" 150# RFWN (N4)	11
8" 150# RFSO (N5)	13
3" 150# RFWN (N6A)	16
3" 150# RFWN (N6B)	18
3" 150# RFWN (N6C)	20
3" 150# RFWN (N6D)	22
4" 150# RFSO (N7A)	24
4" 150# RFSO (N7B)	27
4" 150# RFSO (N7C)	30
1" 150# RFSO (N8)	33
1" 150# RFSO (N9)	35
2" 150# RFSO (N10A)	37
2" 150# RFSO (N10B)	39
1" 150# RFSO (N11A)	41
1" 150# RFSO (N11B)	43
1" 150# RFSO (N11C)	45
1" 150# RFSO (N11D)	47
1" 150# RFSO (N12)	49
1" 150# RFSO (N13)	51
1" 150# RFSO (N14)	53
1" 150# RFSO (N15A)	55
1" 150# RFSO (N15B)	57
1" 150# RFSO (N15C)	59
1" 150# RFSO (N15D)	61
1" 150# RFSO (N15E)	63
3" 150# RFSO (N16)	65
3" 150# RFSO (N17)	67
3" 150# RFSO (N18)	69
3" 150# RFSO (N19)	71
18" 150# RFSO (M1)	73
18" 150# RFSO (M2)	76
2" 6000# CPLG (C1)	79
Saddle Information	81
ASME Flanges	82
Attachment/Loading Information	83
Zick Information - Saddle: TWO (2) SUPPORT SADDLES	84

Table of Contents

MDMT Summary	111
MAWP Summary	112
Summary Information	114
Hydrostatic Test Information Par. UG-99(b)	115

PLATINUM ENERGY SERVICES ULC
SUITE 400, 333 - 11 AVENUE S.W. CALGARY, ALBERTA T2R 1L9

Date Printed: 2/12/2016

Project Description

TWO (2) VESSELS

DRAWING NO'S:

30137-VES-01 REV 0

30138-VES-01 REV 0

CALCULATION NO'S:

30137-VES-01 REV 0




30138-VES-01 REV 0

CRN DRAWING NO:

96OD-360-75-TR-1FT REV A

PLATINUM ENERGY SERVICES ULC
SUITE 400, 333 - 11 AVENUE S.W. CALGARY, ALBERTA T2R 1L9

Date Printed: 2/12/2016



PLATINUM ENERGY SERVICES ULC

8'-0" OD x 30'-0" LONG SHELL

Job No: 30137 & 30138
Number: 1Vessel Number: 01
Mark Number: S1

Date Printed: 2/12/2016

Cylindrical Shell Design Information

Design Pressure:	75.00 PSI	Design Temperature:	350 °F
Static Head:	3.50 PSI	Long. Joint Efficiency:	100 %
Shell Material:	SA-516 Gr. 70	Factor B Chart:	CS-2
Material Condition:	Normalized	Material Stress (hot):	20000 PSI
Shell Length:	360.0000 in.	Material Stress (cold):	20000 PSI
		Compressive Stress:	10942 PSI
Corrosion Allowance:	0.0625 in.	Actual Circumferential Stress:	12026 PSI
External Corrosion Allowance:	0.0000 in.	Actual Longitudinal Stress:	5974 PSI
Outside Diameter (new):	96.0000 in.	Extreme Fiber Elongation:	0.39 %
Outside Diameter (corroded):	96.0000 in.	Specific Gravity:	1.00
Shell Surface Area:	753.98 Sq. Ft.	Weight of Fluid:	92780.70 lb.
Shell Estimated Volume:	11106.06 Gal.	Total Flooded Shell Weight:	104136.38 lb.
Circ. Joint Efficiency:	100 %	Shell Weight:	11355.68 lb.

Minimum Design Metal Temperature Data

Min. Temperature Curve:	D	Pressure at MDMT:	75.00 PSI
UCS-66(b) reduction:	No	Minimum Design Metal Temperature:	-20 °F
UCS-68(c) reduction:	No	Computed Minimum Temperature:	-55 °F

Design Thickness Calculations**Longitudinal Stress Calculations per Paragraph UG-27(c)(2)**

$$t = \frac{PR}{2SE + 0.4P} = \frac{78.50 * 47.6875}{2 * 20000 * 1.00 + 0.4 * 78.50} = 0.0935 + 0.0625_{\text{(corrosion)}} + 0.0000_{\text{(ext. corrosion)}} = \text{minimum of } \mathbf{0.1560 \text{ in.}}$$

Circumferential Stress Calculations per Appendix 1-1

$$t = \frac{PR_o}{SE + 0.4P} = \frac{78.50 * 48.0000}{20000 * 1.00 + 0.4 * 78.50} = 0.1881 + 0.0625_{\text{(corrosion)}} + 0.0000_{\text{(ext. corrosion)}} = \text{minimum of } \mathbf{0.2506 \text{ in.}}$$

External loads do not control design.

Nominal Shell Thickness Selected = 0.3750 in.

PLATINUM ENERGY SERVICES ULC

96" OD FLANGED & DISHED HEAD C/W 1.5" SF (RIGHT SIDE)

Job No: 30137 & 30138
Number: 1Vessel Number: 01
Mark Number: H1

Date Printed: 2/12/2016

ASME F&D Head Design Information

Design Pressure:	75.00 PSI	Design Temperature:	350 °F
Static Head:	3.50 PSI	Joint Efficiency:	100 %
Head Material:	SA-516 Gr. 70	Factor B Chart:	CS-2
Material Condition:	Normalized	Material Stress (hot):	20000 PSI
Corrosion Allowance:	0.0625 in.	Material Stress (cold):	20000 PSI
External Corrosion Allowance:	0.0000 in.	Actual Head Stress:	17654 PSI
Head Location:	Right	Straight Flange :	1.5000 in.
Outside Diameter :	96.0000 in.	Knuckle (r) :	5.7600 in.
Thin Out :	0.0000 in.		
Crown Radius (Lo) :	96.0000 in.	$M = \frac{1}{4}[3 + \sqrt{L/r}]$:	1.7631
Extreme Fiber Elongation:	5.49 %	Specific Gravity:	1.00
Head Surface Area:	61.34 Sq. Ft.	Weight of Fluid:	3136.30 lb.
Head Estimated Volume:	376.06 Gal.	Total Flooded Head Weight:	4218.43 lb.
Head Weight:	1082.13 lb.		

Minimum Design Metal Temperature Data

Min. Temperature Curve:	D	Pressure at MDMT:	75.00 PSI
UCS-66(b) reduction:	No	Minimum Design Metal Temperature:	-20 °F
UCS-68(c) reduction:	No	Computed Minimum Temperature:	-55 °F

Design Thickness Calculations**Design Thickness Calculations per Appendix 1-4(d)**

$$t = \frac{P L_o M}{2SE + P(M - 0.2)} = \frac{78.50 * 96.0000 * 1.7631}{2 * 20000 * 1.00 + 78.50 (1.7631 - 0.2)}$$

$$= 0.3312 + 0.0625 \text{ (corrosion)} + 0.0000 \text{ (ext. corrosion)} + 0.0000 \text{ (thin out)} = \text{minimum of } \mathbf{0.3937} \text{ in.}$$

Minimum Head Thickness Selected = 0.4375 in.

PLATINUM ENERGY SERVICES ULC

8'-0" OD FLANGED & DISHED HEAD C/W 1.5" SF (LEFT SIDE)

Job No: 30137 & 30138
Number: 2Vessel Number: 01
Mark Number: H2

Date Printed: 2/12/2016

ASME F&D Head Design Information

Design Pressure:	75.00 PSI	Design Temperature:	350 °F
Static Head:	3.50 PSI	Joint Efficiency:	100 %
Head Material:	SA-516 Gr. 70	Factor B Chart:	CS-2
Material Condition:	Normalized	Material Stress (hot):	20000 PSI
Corrosion Allowance:	0.0625 in.	Material Stress (cold):	20000 PSI
External Corrosion Allowance:	0.0000 in.	Actual Head Stress:	15121 PSI
Head Location:	Left	Straight Flange :	1.5000 in.
Outside Diameter :	96.0000 in.	Knuckle (r) :	5.7600 in.
Thin Out :	0.0000 in.		
Crown Radius (Lo) :	96.0000 in.	$M = \frac{1}{4}[3 + \sqrt{L/r}]$:	1.7628
Extreme Fiber Elongation:	6.24 %	Specific Gravity:	1.00
Head Surface Area:	61.27 Sq. Ft.	Weight of Fluid:	3123.84 lb.
Head Estimated Volume:	374.56 Gal.	Total Flooded Head Weight:	4358.98 lb.
Head Weight:	1235.14 lb.		

Minimum Design Metal Temperature Data

Min. Temperature Curve:	D	Pressure at MDMT:	75.00 PSI
UCS-66(b) reduction:	No	Minimum Design Metal Temperature:	-20 °F
UCS-68(c) reduction:	No	Computed Minimum Temperature:	-55 °F

Design Thickness Calculations**Design Thickness Calculations per Appendix 1-4(d)**

$$t = \frac{P L_o M}{2SE + P(M - 0.2)} = \frac{78.50 * 96.0000 * 1.7628}{2 * 20000 * 1.00 + 78.50 (1.7628 - 0.2)}$$

$$= 0.3311 + 0.0625 \text{ (corrosion)} + 0.0000 \text{ (ext. corrosion)} + 0.0000 \text{ (thin out)} = \text{minimum of } \mathbf{0.3936 \text{ in.}}$$

Minimum Head Thickness Selected = **0.5000 in.**

PLATINUM ENERGY SERVICES ULC

4" 150# RFSO (N1)

Job No: 30137 & 30138
 Number: 1
 ID Number: 1

Vessel Number: 01
 Mark Number: N1

Date Printed: 2/12/2016

Nozzle Design Information

Design Pressure:	75.00 PSI	Design Temperature:	350 °F
Static Head:	3.50 PSI	Nozzle Efficiency (E):	100 %
Nozzle Material:	SA-106 Gr. B	Joint Efficiency (E ₁):	1.00
		Factor B Chart:	CS-2
External Projection:	6.0000 in.	Allowable Stress at Design Temperature (S _d):	17100 PSI
Internal Projection:	0.5000 in.	Allowable Stress at Ambient Temperature:	17100 PSI
Inside Corrosion Allowance:	0.0625 in.	Correction Factor (F):	1.00
External Corrosion Allowance:	0.0000 in.	Nozzle Path:	None
Nozzle Pipe Size:	4	Nozzle Pipe Schedule:	80
Nozzle ID (new):	3.8260 in.	Nozzle Wall Thickness(new):	0.3370 in.
Nozzle ID (corroded):	3.9510 in.	Nozzle Wall Thickness(corroded):	0.2745 in.
External Limit of Reinforcement:	0.6863 in.	Upper Weld Leg Size(Weld 41):	0.3750 in.
Internal Limit of Reinforcement:	0.5300 in.	Internal Weld Leg Size(Weld 43):	0.3750 in.
Parallel Limit of Reinf (2Lpar):	7.9020 in.	Outside Groove Weld Depth:	0.3750 in.

Minimum Design Metal Temperature

Min. Temp. Curve:	B	Pressure at MDMT:	75.00 PSI
UCS-66(b) reduction:	Yes	Minimum Design Metal Temperature:	-20 °F
UCS-68(c) reduction:	No	Computed Minimum Temperature:	-155 °F

Host Component: Shell 1 - 8'-0" OD x 30'-0" LONG SHELL

Material:	SA-516 Gr. 70	Shell wall thickness(new):	0.3750 in.
Material Stress(S _y):	20000 PSI	Shell wall thickness(corroded):	0.3125 in.


Nozzle Detail Information

Fig. UW-16.1 (c)

Upper Weld Leg Size(Weld 41): 0.3750 in.

Internal Weld Leg Size(Weld 43): 0.3750 in.

Nozzle Wall Thickness(t_n): 0.3370 in.

Outside Groove Weld Depth: 0.3750 in.

Nozzle passes through the vessel, attached by a groove weld.

Pipe Size: 4 Schedule: 80

Nozzle is adequate for UG-45 requirements.

Opening is adequately reinforced for Internal Pressure.

Weld Strength Paths are adequate.

PLATINUM ENERGY SERVICES ULC

4" 150# RFSO (N1)

Job No: 30137 & 30138
 Number: 1
 ID Number: 1

Vessel Number: 01
 Mark Number: N1

Date Printed: 2/12/2016

Required Shell Thickness per Paragraph UG-37(a)

$$t_r = \frac{P R_o}{S E + 0.4 P} = \frac{78.50 * 48.0000}{20000 * 1 + 0.4 * 78.50} = \mathbf{0.1881 \text{ in.}}$$

Nozzle Required Thickness Calculations**Required Nozzle Thickness for Internal Pressure per Paragraph UG-37(a)**

$$t_{rn} = \frac{P R_n}{S E - 0.6 P} = \frac{78.50 * 1.9755}{17100 * 1 - 0.6 * 78.50} = \mathbf{0.0091 \text{ in.}}$$

Strength Reduction Factors

$$f_{r1} = \min \left[\frac{S_n}{S_v}, 1.0000 \right] = \min \left[\frac{17100}{20000}, 1.0000 \right] = 0.8550 \quad f_{r2} = \min \left[\frac{S_n}{S_v}, 1.0000 \right] = \min \left[\frac{17100}{20000}, 1.0000 \right] = 0.8550$$

UG-45 Thickness Calculations**Nozzle Thickness for Pressure Loading (plus corrosion)**

$$t_a = \frac{P R_n}{S E - 0.6 P} + C_a + \text{ext. Ca} = \frac{78.50 * 1.9755}{17100 * 1.00 - 0.6 * 78.50} + 0.0625 + 0.0000 = \mathbf{0.0716 \text{ in.}}$$

Nozzle Thickness for Internal Pressure (plus corrosion) Based on Host

$$t_{b1} = \frac{P R_o}{S E + 0.4 P} + C_a + \text{ext. Ca} = \frac{78.50 * 48.0000}{20000 * 1 + 0.4 * 78.50} + 0.0625 + 0.0000 = \mathbf{0.2506 \text{ in.}}$$

Minimum Thickness (plus corrosion) per Table UG-45

$$t_{b3} = \text{minimum thickness (Table UG-45) + } C_a + \text{ext. Ca} = \mathbf{0.2695 \text{ in.}}$$

Nozzle Minimum Thickness Based on Host and Table UG-45

$$t_b = \min[t_{b3}, \max(t_{b1}, t_{b2})] = \mathbf{0.2506 \text{ in.}}$$

$$t_{UG-45} = \max(t_a, t_b) = \mathbf{0.2506 \text{ in.}}$$

Wall thickness = $t_n * 0.875(\text{pipe}) = \mathbf{0.2950}$ is greater than or equal to UG-45 value of **0.2506**

PLATINUM ENERGY SERVICES ULC

4" 150# RFSO (N1)

Job No: 30137 & 30138
 Number: 1
 ID Number: 1

Vessel Number: 01
 Mark Number: N1

Date Printed: 2/12/2016

Limits of Reinforcement (UG-40)

$$\begin{aligned}
 L_{par} &= \max(d, R_n + t + t_h) = \max(3.9510, 1.9755 + 0.3125 + 0.2745) &= \mathbf{3.9510 \text{ in.}} \\
 L_{noro} &= \min(2.5 t, 2.5 t_h + t_e) = \min(2.5 * 0.3125, 2.5 * 0.2745 + 0.0000) &= \mathbf{0.6863 \text{ in.}} \\
 L_{nori} &= \min(2.5 t, 2.5 t_i) = \min(2.5 * 0.3125, 2.5 * 0.2120) &= \mathbf{0.5300 \text{ in.}}
 \end{aligned}$$

Nozzle Reinforcement Calculations (Internal Pressure)

$$\begin{aligned}
 A &= \max\{C [d t_r F + 2 t_n t_r F (1 - f_{r1})], 0\} = \max\{1.0000 * [3.9510 * 0.1881 * 1.00 + 2 * 0.2745 * 0.1881 * 1.00 * (1 - 0.8550)], 0\} \\
 &= \mathbf{0.7582 \text{ sq. in.}}
 \end{aligned}$$

$$\begin{aligned}
 A1 &= \max\{2 L_{par} - d (E_1 t - F t_r) - 2 t_n (E_1 t - F t_r) (1 - f_{r1}), 0\} = \\
 &\max\{2 * 3.9510 - 3.9510 * (1.0000 * 0.3125 - 1.00 * 0.1881) - 2 * 0.2745 * (1.0000 * 0.3125 - 1.00 * 0.1881) * (1 - 0.8550), 0\} \\
 &= \mathbf{0.4816 \text{ sq. in.}}
 \end{aligned}$$

$$\begin{aligned}
 A2 &= \max\{2 \min(h_o, L_{noro}) [\min(t_h, L_{par} - 0.5 d) - t_{rn}] f_{r2}, 0\} = \\
 &\max\{2 * \min(6.0000, 0.6863) * [\min(0.2745, 3.9510 - 0.5 * 3.9510) - 0.0091] * 0.8550, 0\} \\
 &= \mathbf{0.3114 \text{ sq. in.}}
 \end{aligned}$$

$$\begin{aligned}
 A3 &= \max\{2 \min(h, L_{nori}) \min(t_i, L_{par} - 0.5 d) f_{r2}, 0\} = \\
 &\max\{2 * \min(0.4375, 0.5300) * \min(0.2120, 3.9510 - 0.5 * 3.9510) * 0.8550, 0\} \\
 &= \mathbf{0.1586 \text{ sq. in.}}
 \end{aligned}$$

$$\begin{aligned}
 A41 &= f_{r2} [L_{41}^2 - (L_{41} - L_{41pareff})^2 - (L_{41} - L_{41noreff})^2] = \\
 &0.8550 * [0.3750^2 - (0.3750 - 0.3750)^2 - (0.3750 - 0.3750)^2] \\
 &= \mathbf{0.1202 \text{ sq. in.}}
 \end{aligned}$$

$$\begin{aligned}
 A42 &= f_{r4} L_{42pareff} L_{42noreff} = \\
 &0.0000 * 0.0000 * 0.0000 \\
 &= \mathbf{0.0000 \text{ sq. in.}}
 \end{aligned}$$

$$\begin{aligned}
 A43 &= f_{r2} [L_{43}^2 - (L_{43} - L_{43pareff})^2 - (L_{43} - L_{43noreff})^2] = \\
 &0.8550 * [0.2857^2 - (0.2857 - 0.2857)^2 - (0.2857 - 0.2857)^2] \\
 &= \mathbf{0.0698 \text{ sq. in.}}
 \end{aligned}$$

$$\begin{aligned}
 A5 &= \\
 &= \mathbf{0.0000 \text{ sq. in.}}
 \end{aligned}$$

$$\text{Area Available (Internal Pressure)} = A1 + A2 + A3 + A41 + A42 + A43 + A5 = 1.1417 \text{ sq. in., which is } \geq A (0.7582)$$

PLATINUM ENERGY SERVICES ULC

3" 150# RFSO (N2)

Job No: 30137 & 30138
 Number: 2
 ID Number: 2

Vessel Number: 01
 Mark Number: N2

Date Printed: 2/12/2016

Nozzle Design Information

Design Pressure:	75.00 PSI	Design Temperature:	350 °F
Static Head:	3.50 PSI	Nozzle Efficiency (E):	100 %
Nozzle Material:	SA-106 Gr. B	Joint Efficiency (E ₁):	1.00
		Factor B Chart:	CS-2
External Projection:	6.0000 in.	Allowable Stress at Design Temperature (S):	17100 PSI
Internal Projection:	0.0000 in.	Allowable Stress at Ambient Temperature:	17100 PSI
Inside Corrosion Allowance:	0.0625 in.	Correction Factor (F):	1.00
External Corrosion Allowance:	0.0000 in.	Nozzle Path:	None
Nozzle Pipe Size:	3	Nozzle Pipe Schedule:	80
Nozzle ID (new):	2.9000 in.	Nozzle Wall Thickness(new):	0.3000 in.
Nozzle ID (corroded):	3.0250 in.	Nozzle Wall Thickness(corroded):	0.2375 in.
Developed Opening:	3.1760 in.	Tangential Dimension L:	39.0000 in.
External Limit of Reinforcement:	0.5938 in.	Upper Weld Leg Size(Weld 41):	0.3750 in.
Internal Limit of Reinforcement:	0.4375 in.	Internal Weld Leg Size(Weld 43):	0.0000 in.
Parallel Limit of Reinf (2Lpar):	6.6020 in.	Outside Groove Weld Depth:	0.4375 in.

Minimum Design Metal Temperature

Min. Temp. Curve: B	Pressure at MDMT:	75.00 PSI
UCS-66(b) reduction: Yes	Minimum Design Metal Temperature:	-20 °F
UCS-68(c) reduction: No	Computed Minimum Temperature:	-155 °F

Host Component: Head 1 - 96" OD FLANGED & DISHED HEAD C/W 1.5" SF (RIGHT SIDE)

Material: SA-516 Gr. 70	Head wall thickness(new):	0.4375 in.
Material Stress(S _y): 20000 PSI	Head wall thickness - thin out (corroded):	0.3750 in.


Nozzle Detail Information

Fig. UW-16.1 (c)

Upper Weld Leg Size(Weld 41): 0.3750 in.

Nozzle Wall Thickness(t_n): 0.3000 in.

Outside Groove Weld Depth: 0.4375 in.

tangential to the vessel wall, attached by a groove weld.

Pipe Size: 3 Schedule: 80

Nozzle is adequate for UG-45 requirements.

Opening is adequately reinforced for Internal Pressure.

Reinforcement calculations are not required per UG-36(c)(3)(a) See Uw-14 for exceptions.

Weld Strength Paths are adequate.

PLATINUM ENERGY SERVICES ULC

3" 150# RFSO (N2)

Job No: 30137 & 30138
 Number: 2
 ID Number: 2

Vessel Number: 01
 Mark Number: N2

Date Printed: 2/12/2016

Required Head Thickness per Paragraph UG-37(a)

$$t_r = \frac{P L o M}{(2 S E + P * (M - 0.2))} = \frac{78.50 * 96.0000 * 1.0000}{(2 * 20000 * 1 + 78.50 * (1.0000 - 0.2))} = \mathbf{0.1881 \text{ in.}}$$

Nozzle Required Thickness Calculations**Required Nozzle Thickness for Internal Pressure per Paragraph UG-37(a)**

$$t_{rn} = \frac{P R n}{S E - 0.6 P} = \frac{78.50 * 1.5125}{17100 * 1 - 0.6 * 78.50} = \mathbf{0.0070 \text{ in.}}$$

Strength Reduction Factors

$$f r 1 = \min \left\{ \frac{S_n}{S_v}, 1.0000 \right\} = \min \left\{ \frac{17100}{20000}, 1.0000 \right\} = 0.8550 \quad f r 2 = \min \left\{ \frac{S_n}{S_v}, 1.0000 \right\} = \min \left\{ \frac{17100}{20000}, 1.0000 \right\} = 0.8550$$

UG-45 Thickness Calculations**Nozzle Thickness for Pressure Loading (plus corrosion)**

$$t_a = \frac{P R n}{S E - 0.6 P} + C a + \text{ext. } C a = \frac{78.50 * 1.5125}{17100 * 1.00 - 0.6 * 78.50} + 0.0625 + 0.0000 = \mathbf{0.0695 \text{ in.}}$$

Nozzle Thickness for Internal Pressure (plus corrosion) Based on Host

$$t_{b1} = \frac{P L o M}{(2 S E + P * (M - 0.2))} + C a + \text{ext. } C a = \frac{78.50 * 96.0000 * 1.7631}{(2 * 20000 * 1 + 78.50 * (1.7631 - 0.2))} + 0.0625 + 0.0000 = \mathbf{0.3937 \text{ in.}}$$

Minimum Thickness (plus corrosion) per Table UG-45

$$t_{b3} = \text{minimum thickness (Table UG-45) + } C a + \text{ext. } C a = \mathbf{0.2515 \text{ in.}}$$

Nozzle Minimum Thickness Based on Host and Table UG-45

$$t_b = \min[t_{b3}, \max(t_{b1}, t_{b2})] = \mathbf{0.2515 \text{ in.}}$$

$$t_{UG-45} = \max(t_a, t_b) = \mathbf{0.2515 \text{ in.}}$$

Wall thickness = $t_n * 0.875(\text{pipe}) = \mathbf{0.2620}$ is greater than or equal to UG-45 value of **0.2515**

PLATINUM ENERGY SERVICES ULC

3" 150# RFSO (N3)

Job No: 30137 & 30138
 Number: 3
 ID Number: 3

Vessel Number: 01
 Mark Number: N3

Date Printed: 2/12/2016

Nozzle Design Information

Design Pressure:	75.00 PSI	Design Temperature:	350 °F
Static Head:	3.50 PSI	Nozzle Efficiency (E):	100 %
Nozzle Material:	SA-106 Gr. B	Joint Efficiency (E ₁):	1.00
		Factor B Chart:	CS-2
External Projection:	6.0000 in.	Allowable Stress at Design Temperature (S):	17100 PSI
Internal Projection:	0.0000 in.	Allowable Stress at Ambient Temperature:	17100 PSI
Inside Corrosion Allowance:	0.0625 in.	Correction Factor (F):	1.00
External Corrosion Allowance:	0.0000 in.	Nozzle Path:	None
Nozzle Pipe Size:	3	Nozzle Pipe Schedule:	80
Nozzle ID (new):	2.9000 in.	Nozzle Wall Thickness(new):	0.3000 in.
Nozzle ID (corroded):	3.0250 in.	Nozzle Wall Thickness(corroded):	0.2375 in.
Developed Opening:	2.9004 in.	Tangential Dimension L:	1.6694 in.
External Limit of Reinforcement:	0.5938 in.	Upper Weld Leg Size(Weld 41):	0.3750 in.
Internal Limit of Reinforcement:	0.4375 in.	Internal Weld Leg Size(Weld 43):	0.0000 in.
Parallel Limit of Reinf (2Lpar):	6.0510 in.	Outside Groove Weld Depth:	0.4375 in.

Minimum Design Metal Temperature

Min. Temp. Curve: B	Pressure at MDMT:	75.00 PSI
UCS-66(b) reduction: Yes	Minimum Design Metal Temperature:	-20 °F
UCS-68(c) reduction: No	Computed Minimum Temperature:	-155 °F

Host Component: Head 1 - 96" OD FLANGED & DISHED HEAD C/W 1.5" SF (RIGHT SIDE)

Material: SA-516 Gr. 70	Head wall thickness(new):	0.4375 in.
Material Stress(S _y): 20000 PSI	Head wall thickness - thin out (corroded):	0.3750 in.


Nozzle Detail Information

Fig. UW-16.1 (c)

Upper Weld Leg Size(Weld 41): 0.3750 in.

Nozzle Wall Thickness(t_n): 0.3000 in.

Outside Groove Weld Depth: 0.4375 in.

tangential to the vessel wall, attached by a groove weld.

Pipe Size: 3 Schedule: 80

Nozzle is adequate for UG-45 requirements.

Opening is adequately reinforced for Internal Pressure.

Reinforcement calculations are not required per UG-36(c)(3)(a) See Uw-14 for exceptions.

Weld Strength Paths are adequate.

PLATINUM ENERGY SERVICES ULC

3" 150# RFSO (N3)

Job No: 30137 & 30138
 Number: 3
 ID Number: 3

Vessel Number: 01
 Mark Number: N3

Date Printed: 2/12/2016

Required Head Thickness per Paragraph UG-37(a)

$$t_r = \frac{P L o M}{(2 S E + P * (M - 0.2))} = \frac{78.50 * 96.0000 * 1.0000}{(2 * 20000 * 1 + 78.50 * (1.0000 - 0.2))} = \mathbf{0.1881 \text{ in.}}$$

Nozzle Required Thickness Calculations**Required Nozzle Thickness for Internal Pressure per Paragraph UG-37(a)**

$$t_{rn} = \frac{P R n}{S E - 0.6 P} = \frac{78.50 * 1.5125}{17100 * 1 - 0.6 * 78.50} = \mathbf{0.0070 \text{ in.}}$$

Strength Reduction Factors

$$f r 1 = \min \left\{ \frac{S_n}{S_v}, 1.0000 \right\} = \min \left\{ \frac{17100}{20000}, 1.0000 \right\} = 0.8550 \quad f r 2 = \min \left\{ \frac{S_n}{S_v}, 1.0000 \right\} = \min \left\{ \frac{17100}{20000}, 1.0000 \right\} = 0.8550$$

UG-45 Thickness Calculations**Nozzle Thickness for Pressure Loading (plus corrosion)**

$$t_a = \frac{P R n}{S E - 0.6 P} + C a + \text{ext. } C a = \frac{78.50 * 1.5125}{17100 * 1.00 - 0.6 * 78.50} + 0.0625 + 0.0000 = \mathbf{0.0695 \text{ in.}}$$

Nozzle Thickness for Internal Pressure (plus corrosion) Based on Host

$$t_{b1} = \frac{P L o M}{(2 S E + P * (M - 0.2))} + C a + \text{ext. } C a = \frac{78.50 * 96.0000 * 1.7631}{(2 * 20000 * 1 + 78.50 * (1.7631 - 0.2))} + 0.0625 + 0.0000 = \mathbf{0.3937 \text{ in.}}$$

Minimum Thickness (plus corrosion) per Table UG-45

$$t_{b3} = \text{minimum thickness (Table UG-45) + } C a + \text{ext. } C a = \mathbf{0.2515 \text{ in.}}$$

Nozzle Minimum Thickness Based on Host and Table UG-45

$$t_b = \min[t_{b3}, \max(t_{b1}, t_{b2})] = \mathbf{0.2515 \text{ in.}}$$

$$t_{UG-45} = \max(t_a, t_b) = \mathbf{0.2515 \text{ in.}}$$

Wall thickness = $t_n * 0.875(\text{pipe}) = \mathbf{0.2620}$ is greater than or equal to UG-45 value of **0.2515**

PLATINUM ENERGY SERVICES ULC

3" 150# RFWN (N4)

Job No: 30137 & 30138
 Number: 4
 ID Number: 4

Vessel Number: 01
 Mark Number: N4

Date Printed: 2/12/2016

Nozzle Design Information

Design Pressure:	75.00 PSI	Design Temperature:	350 °F
Static Head:	3.50 PSI	Nozzle Efficiency (E):	100 %
Nozzle Material:	SA-106 Gr. B	Joint Efficiency (E ₁):	1.00
		Factor B Chart:	CS-2
External Projection:	6.0000 in.	Allowable Stress at Design Temperature (S):	17100 PSI
Internal Projection:	0.0000 in.	Allowable Stress at Ambient Temperature:	17100 PSI
Inside Corrosion Allowance:	0.0625 in.	Correction Factor (F):	1.00
External Corrosion Allowance:	0.0000 in.	Nozzle Path:	None
Nozzle Pipe Size:	3	Nozzle Pipe Schedule:	80
Nozzle ID (new):	2.9000 in.	Nozzle Wall Thickness(new):	0.3000 in.
Nozzle ID (corroded):	3.0250 in.	Nozzle Wall Thickness(corroded):	0.2375 in.
External Limit of Reinforcement:	0.5938 in.	Upper Weld Leg Size(Weld 41):	0.3750 in.
Internal Limit of Reinforcement:	0.4375 in.	Internal Weld Leg Size(Weld 43):	0.0000 in.
Parallel Limit of Reinf (2Lpar):	6.0500 in.	Outside Groove Weld Depth:	0.3750 in.

Minimum Design Metal Temperature

Min. Temp. Curve:	B	Pressure at MDMT:	75.00 PSI
UCS-66(b) reduction:	Yes	Minimum Design Metal Temperature:	-20 °F
UCS-68(c) reduction:	No	Computed Minimum Temperature:	-155 °F

Host Component: Shell 1 - 8'-0" OD x 30'-0" LONG SHELL

Material:	SA-516 Gr. 70	Shell wall thickness(new):	0.3750 in.
Material Stress(S _y):	20000 PSI	Shell wall thickness(corroded):	0.3125 in.

Nozzle Detail Information

Backing strip if used may
 be removed after welding




Fig. UW-16.1 (c)

Upper Weld Leg Size(Weld 41): 0.3750 in.

Nozzle Wall Thickness(t_n): 0.3000 in.

Outside Groove Weld Depth: 0.3750 in.

Nozzle passes through the vessel, attached by a groove weld.

Pipe Size: 3 Schedule: 80

Nozzle is adequate for UG-45 requirements.

Opening is adequately reinforced for Internal Pressure.

Reinforcement calculations are not required per UG-36(c)(3)(a) See Uw-14 for exceptions.

Weld Strength Paths are adequate.

PLATINUM ENERGY SERVICES ULC

3" 150# RFWN (N4)

Job No: 30137 & 30138
 Number: 4
 ID Number: 4

Vessel Number: 01
 Mark Number: N4

Date Printed: 2/12/2016

Required Shell Thickness per Paragraph UG-37(a)

$$t_r = \frac{P R_o}{S E + 0.4 P} = \frac{78.50 * 48.0000}{20000 * 1 + 0.4 * 78.50} = \mathbf{0.1881 \text{ in.}}$$

Nozzle Required Thickness Calculations**Required Nozzle Thickness for Internal Pressure per Paragraph UG-37(a)**

$$t_{rn} = \frac{P R_n}{S E - 0.6 P} = \frac{78.50 * 1.5125}{17100 * 1 - 0.6 * 78.50} = \mathbf{0.0070 \text{ in.}}$$

Strength Reduction Factors

$$f_{r1} = \min \left\{ \frac{S_n}{S_v}, 1.0000 \right\} = \min \left\{ \frac{17100}{20000}, 1.0000 \right\} = 0.8550 \quad f_{r2} = \min \left\{ \frac{S_n}{S_v}, 1.0000 \right\} = \min \left\{ \frac{17100}{20000}, 1.0000 \right\} = 0.8550$$

UG-45 Thickness Calculations**Nozzle Thickness for Pressure Loading (plus corrosion)**

$$t_a = \frac{P R_n}{S E - 0.6 P} + C_a + \text{ext. Ca} = \frac{78.50 * 1.5125}{17100 * 1.00 - 0.6 * 78.50} + 0.0625 + 0.0000 = \mathbf{0.0695 \text{ in.}}$$

Nozzle Thickness for Internal Pressure (plus corrosion) Based on Host

$$t_{b1} = \frac{P R_o}{S E + 0.4 P} + C_a + \text{ext. Ca} = \frac{78.50 * 48.0000}{20000 * 1 + 0.4 * 78.50} + 0.0625 + 0.0000 = \mathbf{0.2506 \text{ in.}}$$

Minimum Thickness (plus corrosion) per Table UG-45

$$t_{b3} = \text{minimum thickness (Table UG-45) + } C_a + \text{ext. Ca} = \mathbf{0.2515 \text{ in.}}$$

Nozzle Minimum Thickness Based on Host and Table UG-45

$$t_b = \min[t_{b3}, \max(t_{b1}, t_{b2})] = \mathbf{0.2506 \text{ in.}}$$

$$t_{UG-45} = \max(t_a, t_b) = \mathbf{0.2506 \text{ in.}}$$

Wall thickness = $t_n * 0.875(\text{pipe}) = \mathbf{0.2620}$ is greater than or equal to UG-45 value of **0.2506**

PLATINUM ENERGY SERVICES ULC

8" 150# RFSO (N5)

Job No: 30137 & 30138
 Number: 5
 ID Number: 5

Vessel Number: 01
 Mark Number: N5

Date Printed: 2/12/2016

Nozzle Design Information

Design Pressure:	75.00 PSI	Design Temperature:	350 °F
Static Head:	3.50 PSI	Nozzle Efficiency (E):	100 %
Nozzle Material:	SA-106 Gr. B	Joint Efficiency (E ₁):	1.00
		Factor B Chart:	CS-2
External Projection:	6.0000 in.	Allowable Stress at Design Temperature (S):	17100 PSI
Internal Projection:	0.0000 in.	Allowable Stress at Ambient Temperature:	17100 PSI
Inside Corrosion Allowance:	0.0625 in.	Correction Factor (F):	1.00
External Corrosion Allowance:	0.0000 in.	Nozzle Path:	None
Nozzle Pipe Size:	8	Nozzle Pipe Schedule:	80
Nozzle ID (new):	7.6250 in.	Nozzle Wall Thickness(new):	0.5000 in.
Nozzle ID (corroded):	7.7500 in.	Nozzle Wall Thickness(corroded):	0.4375 in.
Developed Opening:	7.6858 in.	Tangential Dimension L:	12.0000 in.
External Limit of Reinforcement:	0.9375 in.	Upper Weld Leg Size(Weld 41):	0.3750 in.
Internal Limit of Reinforcement:	0.9375 in.	Internal Weld Leg Size(Weld 43):	0.0000 in.
Parallel Limit of Reinf (2Lpar):	15.6234 in.	Outside Groove Weld Depth:	0.4375 in.

Minimum Design Metal Temperature

Min. Temp. Curve: B	Pressure at MDMT:	75.00 PSI
UCS-66(b) reduction: Yes	Minimum Design Metal Temperature:	-20 °F
UCS-68(c) reduction: No	Computed Minimum Temperature:	-153 °F

Host Component: Head 1 - 96" OD FLANGED & DISHED HEAD C/W 1.5" SF (RIGHT SIDE)

Material: SA-516 Gr. 70	Head wall thickness(new):	0.4375 in.
Material Stress(S _y): 20000 PSI	Head wall thickness - thin out (corroded):	0.3750 in.


Nozzle Detail Information

Fig. UW-16.1 (c)

Upper Weld Leg Size(Weld 41): 0.3750 in.

Nozzle Wall Thickness(t_n): 0.5000 in.

Outside Groove Weld Depth: 0.4375 in.

tangential to the vessel wall, attached by a groove weld.

Pipe Size: 8 Schedule: 80

Nozzle is adequate for UG-45 requirements.

Opening is adequately reinforced for Internal Pressure.

Weld Strength Paths are adequate.

PLATINUM ENERGY SERVICES ULC

8" 150# RFSO (N5)

Job No: 30137 & 30138
 Number: 5
 ID Number: 5

Vessel Number: 01
 Mark Number: N5

Date Printed: 2/12/2016

Required Head Thickness per Paragraph UG-37(a)

$$t_r = \frac{P L o M}{(2 S E + P * (M - 0.2))} = \frac{78.50 * 96.0000 * 1.0000}{(2 * 20000 * 1 + 78.50 * (1.0000 - 0.2))} = \mathbf{0.1881 \text{ in.}}$$

Nozzle Required Thickness Calculations**Required Nozzle Thickness for Internal Pressure per Paragraph UG-37(a)**

$$t_{rn} = \frac{P R n}{S E - 0.6 P} = \frac{78.50 * 3.8750}{17100 * 1 - 0.6 * 78.50} = \mathbf{0.0178 \text{ in.}}$$

Strength Reduction Factors

$$f r 1 = \min \left\{ \frac{S_n}{S_v}, 1.0000 \right\} = \min \left\{ \frac{17100}{20000}, 1.0000 \right\} = 0.8550 \quad f r 2 = \min \left\{ \frac{S_n}{S_v}, 1.0000 \right\} = \min \left\{ \frac{17100}{20000}, 1.0000 \right\} = 0.8550$$

UG-45 Thickness Calculations**Nozzle Thickness for Pressure Loading (plus corrosion)**

$$t_a = \frac{P R n}{S E - 0.6 P} + C a + \text{ext. Ca} = \frac{78.50 * 3.8750}{17100 * 1.00 - 0.6 * 78.50} + 0.0625 + 0.0000 = \mathbf{0.0803 \text{ in.}}$$

Nozzle Thickness for Internal Pressure (plus corrosion) Based on Host

$$t_{b1} = \frac{P L o M}{(2 S E + P * (M - 0.2))} + C a + \text{ext. Ca} = \frac{78.50 * 96.0000 * 1.7631}{(2 * 20000 * 1 + 78.50 * (1.7631 - 0.2))} + 0.0625 + 0.0000 = \mathbf{0.3937 \text{ in.}}$$

Minimum Thickness (plus corrosion) per Table UG-45

$$t_{b3} = \text{minimum thickness (Table UG-45) + Ca + ext. Ca} = \mathbf{0.3445 \text{ in.}}$$

Nozzle Minimum Thickness Based on Host and Table UG-45

$$t_b = \min[t_{b3}, \max(t_{b1}, t_{b2})] = \mathbf{0.3445 \text{ in.}}$$

$$t_{UG-45} = \max(t_a, t_b) = \mathbf{0.3445 \text{ in.}}$$

Wall thickness = $t_n * 0.875(\text{pipe}) = \mathbf{0.4370}$ is greater than or equal to UG-45 value of **0.3445**

PLATINUM ENERGY SERVICES ULC

8" 150# RFSO (N5)

Job No: 30137 & 30138
 Number: 5
 ID Number: 5

Vessel Number: 01
 Mark Number: N5

Date Printed: 2/12/2016

Limits of Reinforcement (UG-40)

$$\begin{aligned}
 L_{par} &= \max(d, R_n + t + t_h) = \max(7.8117, 3.8750 + 0.3750 + 0.4375) &= 7.8117 \text{ in.} \\
 L_{noro} &= \min(2.5 t, 2.5 t_h + t_e) = \min(2.5 * 0.3750, 2.5 * 0.4375 + 0.0000) &= 0.9375 \text{ in.} \\
 L_{nori} &= \min(2.5 t, 2.5 t_i) = \min(2.5 * 0.3750, 2.5 * 0.3750) &= 0.9375 \text{ in.}
 \end{aligned}$$

Nozzle Reinforcement Calculations (Internal Pressure)

$$A = \max\{C [d t_r F + 2 t_n t_r F (1 - f_{r1})], 0\} = \max\{1.0000 * [7.8117 * 0.1881 * 1.00 + 2 * 0.4375 * 0.1881 * 1.00 * (1 - 0.8550)], 0\} = 1.4932 \text{ sq. in.}$$

$$\begin{aligned}
 A1 &= \max\{2 L_{par} - d\} (E_1 t - F t_r) - 2 t_n (E_1 t - F t_r) (1 - f_{r1}), 0\} = \\
 &\max\{2 * 7.8117 - 7.8117\} * (1.0000 * 0.3750 - 1.00 * 0.1881) - 2 * 0.4375 * (1.0000 * 0.3750 - 1.00 * 0.1881) * (1 - 0.8550), 0\} \\
 &= 1.4363 \text{ sq. in.}
 \end{aligned}$$

$$\begin{aligned}
 A2 &= \max\{2 \min(h_o, L_{noro}) [\min(t_h, L_{par} - 0.5 d) - t_{rn}] f_{r2}, 0\} = \\
 &\max\{2 * \min(6.0000, 0.9375) * [\min(0.4375, 7.8117 - 0.5 * 7.8117) - 0.0178] * 0.8550, 0\} \\
 &= 0.6728 \text{ sq. in.}
 \end{aligned}$$

$$\begin{aligned}
 A3 &= \max\{2 \min(h, L_{nori}) \min(t_i, L_{par} - 0.5 d) f_{r2}, 0\} = \\
 &\max\{2 * \min(0.0000, 0.9375) * \min(0.3750, 7.8117 - 0.5 * 7.8117) * 0.8550, 0\} \\
 &= 0.0000 \text{ sq. in.}
 \end{aligned}$$

$$\begin{aligned}
 A41 &= f_{r2} [L_{41}^2 - (L_{41} - L_{41pareff})^2 - (L_{41} - L_{41noreff})^2] = \\
 &0.8550 * [0.3750^2 - (0.3750 - 0.3750)^2 - (0.3750 - 0.3750)^2] \\
 &= 0.1202 \text{ sq. in.}
 \end{aligned}$$

$$\begin{aligned}
 A42 &= f_{r4} L_{42pareff} L_{42noreff} = \\
 &0.0000 * 0.0000 * 0.0000 \\
 &= 0.0000 \text{ sq. in.}
 \end{aligned}$$

$$\begin{aligned}
 A43 &= f_{r2} L_{43pareff} L_{43noreff} = \\
 &0.8550 * 0.0000 * 0.0000 \\
 &= 0.0000 \text{ sq. in.}
 \end{aligned}$$

$$\begin{aligned}
 A5 &= \\
 &= 0.0000 \text{ sq. in.}
 \end{aligned}$$

$$\text{Area Available (Internal Pressure)} = A1 + A2 + A3 + A41 + A42 + A43 + A5 = 2.2294 \text{ sq. in., which is } \geq A (1.4932)$$

PLATINUM ENERGY SERVICES ULC

3" 150# RFWN (N6A)

Job No: 30137 & 30138
 Number: 6
 ID Number: 6

Vessel Number: 01
 Mark Number: N6A

Date Printed: 2/12/2016

Nozzle Design Information

Design Pressure:	75.00 PSI	Design Temperature:	350 °F
Static Head:	3.50 PSI	Nozzle Efficiency (E):	100 %
Nozzle Material:	SA-106 Gr. B	Joint Efficiency (E ₁):	1.00
		Factor B Chart:	CS-2
External Projection:	6.0000 in.	Allowable Stress at Design Temperature (S _d):	17100 PSI
Internal Projection:	0.0000 in.	Allowable Stress at Ambient Temperature:	17100 PSI
Inside Corrosion Allowance:	0.0625 in.	Correction Factor (F):	1.00
External Corrosion Allowance:	0.0000 in.	Nozzle Path:	None
Nozzle Pipe Size:	3	Nozzle Pipe Schedule:	80
Nozzle ID (new):	2.9000 in.	Nozzle Wall Thickness(new):	0.3000 in.
Nozzle ID (corroded):	3.0250 in.	Nozzle Wall Thickness(corroded):	0.2375 in.
External Limit of Reinforcement:	0.5938 in.	Upper Weld Leg Size(Weld 41):	0.3750 in.
Internal Limit of Reinforcement:	0.4375 in.	Internal Weld Leg Size(Weld 43):	0.0000 in.
Parallel Limit of Reinf (2Lpar):	6.0500 in.	Outside Groove Weld Depth:	0.3750 in.

Minimum Design Metal Temperature

Min. Temp. Curve:	B	Pressure at MDMT:	75.00 PSI
UCS-66(b) reduction:	Yes	Minimum Design Metal Temperature:	-20 °F
UCS-68(c) reduction:	No	Computed Minimum Temperature:	-155 °F

Host Component: Shell 1 - 8'-0" OD x 30'-0" LONG SHELL

Material:	SA-516 Gr. 70	Shell wall thickness(new):	0.3750 in.
Material Stress(S _y):	20000 PSI	Shell wall thickness(corroded):	0.3125 in.

Nozzle Detail Information

Backing strip if used may
 be removed after welding




Fig. UW-16.1 (c)

Upper Weld Leg Size(Weld 41): 0.3750 in.

Nozzle Wall Thickness(t_n): 0.3000 in.

Outside Groove Weld Depth: 0.3750 in.

Nozzle passes through the vessel, attached by a groove weld.

Pipe Size: 3 Schedule: 80

Nozzle is adequate for UG-45 requirements.

Opening is adequately reinforced for Internal Pressure.

Reinforcement calculations are not required per UG-36(c)(3)(a) See Uw-14 for exceptions.

Weld Strength Paths are adequate.

PLATINUM ENERGY SERVICES ULC

3" 150# RFWN (N6A)

Job No: 30137 & 30138
 Number: 6
 ID Number: 6

Vessel Number: 01
 Mark Number: N6A

Date Printed: 2/12/2016

Required Shell Thickness per Paragraph UG-37(a)

$$t_r = \frac{P R_o}{S E + 0.4 P} = \frac{78.50 * 48.0000}{20000 * 1 + 0.4 * 78.50} = \mathbf{0.1881 \text{ in.}}$$

Nozzle Required Thickness Calculations**Required Nozzle Thickness for Internal Pressure per Paragraph UG-37(a)**

$$t_{rn} = \frac{P R_n}{S E - 0.6 P} = \frac{78.50 * 1.5125}{17100 * 1 - 0.6 * 78.50} = \mathbf{0.0070 \text{ in.}}$$

Strength Reduction Factors

$$f_{r1} = \min \left[\frac{S_n}{S_v}, 1.0000 \right] = \min \left[\frac{17100}{20000}, 1.0000 \right] = 0.8550 \quad f_{r2} = \min \left[\frac{S_n}{S_v}, 1.0000 \right] = \min \left[\frac{17100}{20000}, 1.0000 \right] = 0.8550$$

UG-45 Thickness Calculations**Nozzle Thickness for Pressure Loading (plus corrosion)**

$$t_a = \frac{P R_n}{S E - 0.6 P} + C_a + \text{ext. Ca} = \frac{78.50 * 1.5125}{17100 * 1.00 - 0.6 * 78.50} + 0.0625 + 0.0000 = \mathbf{0.0695 \text{ in.}}$$

Nozzle Thickness for Internal Pressure (plus corrosion) Based on Host

$$t_{b1} = \frac{P R_o}{S E + 0.4 P} + C_a + \text{ext. Ca} = \frac{78.50 * 48.0000}{20000 * 1 + 0.4 * 78.50} + 0.0625 + 0.0000 = \mathbf{0.2506 \text{ in.}}$$

Minimum Thickness (plus corrosion) per Table UG-45

$$t_{b3} = \text{minimum thickness (Table UG-45)} + C_a + \text{ext. Ca} = \mathbf{0.2515 \text{ in.}}$$

Nozzle Minimum Thickness Based on Host and Table UG-45

$$t_b = \min[t_{b3}, \max(t_{b1}, t_{b2})] = \mathbf{0.2506 \text{ in.}}$$

$$t_{UG-45} = \max(t_a, t_b) = \mathbf{0.2506 \text{ in.}}$$

Wall thickness = $t_n * 0.875(\text{pipe}) = \mathbf{0.2620}$ is greater than or equal to UG-45 value of **0.2506**

PLATINUM ENERGY SERVICES ULC

3" 150# RFWN (N6B)

Job No: 30137 & 30138
 Number: 7
 ID Number: 7

Vessel Number: 01
 Mark Number: N6B

Date Printed: 2/12/2016

Nozzle Design Information

Design Pressure:	75.00 PSI	Design Temperature:	350 °F
Static Head:	3.50 PSI	Nozzle Efficiency (E):	100 %
Nozzle Material:	SA-106 Gr. B	Joint Efficiency (E ₁):	1.00
		Factor B Chart:	CS-2
External Projection:	6.0000 in.	Allowable Stress at Design Temperature (S _d):	17100 PSI
Internal Projection:	0.0000 in.	Allowable Stress at Ambient Temperature:	17100 PSI
Inside Corrosion Allowance:	0.0625 in.	Correction Factor (F):	1.00
External Corrosion Allowance:	0.0000 in.	Nozzle Path:	None
Nozzle Pipe Size:	3	Nozzle Pipe Schedule:	80
Nozzle ID (new):	2.9000 in.	Nozzle Wall Thickness(new):	0.3000 in.
Nozzle ID (corroded):	3.0250 in.	Nozzle Wall Thickness(corroded):	0.2375 in.
External Limit of Reinforcement:	0.5938 in.	Upper Weld Leg Size(Weld 41):	0.3750 in.
Internal Limit of Reinforcement:	0.4375 in.	Internal Weld Leg Size(Weld 43):	0.0000 in.
Parallel Limit of Reinf (2Lpar):	6.0500 in.	Outside Groove Weld Depth:	0.3750 in.

Minimum Design Metal Temperature

Min. Temp. Curve:	B	Pressure at MDMT:	75.00 PSI
UCS-66(b) reduction:	Yes	Minimum Design Metal Temperature:	-20 °F
UCS-68(c) reduction:	No	Computed Minimum Temperature:	-155 °F

Host Component: Shell 1 - 8'-0" OD x 30'-0" LONG SHELL

Material:	SA-516 Gr. 70	Shell wall thickness(new):	0.3750 in.
Material Stress(S _y):	20000 PSI	Shell wall thickness(corroded):	0.3125 in.

Nozzle Detail Information

Backing strip if used may
 be removed after welding




Fig. UW-16.1 (c)

Upper Weld Leg Size(Weld 41): 0.3750 in.

Nozzle Wall Thickness(t_n): 0.3000 in.

Outside Groove Weld Depth: 0.3750 in.

Nozzle passes through the vessel, attached by a groove weld.

Pipe Size: 3 Schedule: 80

Nozzle is adequate for UG-45 requirements.

Opening is adequately reinforced for Internal Pressure.

Reinforcement calculations are not required per UG-36(c)(3)(a) See Uw-14 for exceptions.

Weld Strength Paths are adequate.

PLATINUM ENERGY SERVICES ULC

3" 150# RFWN (N6B)

Job No: 30137 & 30138
 Number: 7
 ID Number: 7

Vessel Number: 01
 Mark Number: N6B

Date Printed: 2/12/2016

Required Shell Thickness per Paragraph UG-37(a)

$$t_r = \frac{P R_o}{S E + 0.4 P} = \frac{78.50 * 48.0000}{20000 * 1 + 0.4 * 78.50} = \mathbf{0.1881 \text{ in.}}$$

Nozzle Required Thickness Calculations**Required Nozzle Thickness for Internal Pressure per Paragraph UG-37(a)**

$$t_{rn} = \frac{P R_n}{S E - 0.6 P} = \frac{78.50 * 1.5125}{17100 * 1 - 0.6 * 78.50} = \mathbf{0.0070 \text{ in.}}$$

Strength Reduction Factors

$$f_{r1} = \min \left\{ \frac{S_n}{S_v}, 1.0000 \right\} = \min \left\{ \frac{17100}{20000}, 1.0000 \right\} = 0.8550 \quad f_{r2} = \min \left\{ \frac{S_n}{S_v}, 1.0000 \right\} = \min \left\{ \frac{17100}{20000}, 1.0000 \right\} = 0.8550$$

UG-45 Thickness Calculations**Nozzle Thickness for Pressure Loading (plus corrosion)**

$$t_a = \frac{P R_n}{S E - 0.6 P} + C_a + \text{ext. Ca} = \frac{78.50 * 1.5125}{17100 * 1.00 - 0.6 * 78.50} + 0.0625 + 0.0000 = \mathbf{0.0695 \text{ in.}}$$

Nozzle Thickness for Internal Pressure (plus corrosion) Based on Host

$$t_{b1} = \frac{P R_o}{S E + 0.4 P} + C_a + \text{ext. Ca} = \frac{78.50 * 48.0000}{20000 * 1 + 0.4 * 78.50} + 0.0625 + 0.0000 = \mathbf{0.2506 \text{ in.}}$$

Minimum Thickness (plus corrosion) per Table UG-45

$$t_{b3} = \text{minimum thickness (Table UG-45) + } C_a + \text{ext. Ca} = \mathbf{0.2515 \text{ in.}}$$

Nozzle Minimum Thickness Based on Host and Table UG-45

$$t_b = \min[t_{b3}, \max(t_{b1}, t_{b2})] = \mathbf{0.2506 \text{ in.}}$$

$$t_{UG-45} = \max(t_a, t_b) = \mathbf{0.2506 \text{ in.}}$$

Wall thickness = $t_n * 0.875(\text{pipe}) = \mathbf{0.2620}$ is greater than or equal to UG-45 value of **0.2506**

PLATINUM ENERGY SERVICES ULC

3" 150# RFWN (N6C)

Job No: 30137 & 30138
 Number: 8
 ID Number: 8

Vessel Number: 01
 Mark Number: N6C

Date Printed: 2/12/2016

Nozzle Design Information

Design Pressure:	75.00 PSI	Design Temperature:	350 °F
Static Head:	3.50 PSI	Nozzle Efficiency (E):	100 %
Nozzle Material:	SA-106 Gr. B	Joint Efficiency (E ₁):	1.00
		Factor B Chart:	CS-2
External Projection:	6.0000 in.	Allowable Stress at Design Temperature (S _d):	17100 PSI
Internal Projection:	0.0000 in.	Allowable Stress at Ambient Temperature:	17100 PSI
Inside Corrosion Allowance:	0.0625 in.	Correction Factor (F):	1.00
External Corrosion Allowance:	0.0000 in.	Nozzle Path:	None
Nozzle Pipe Size:	3	Nozzle Pipe Schedule:	80
Nozzle ID (new):	2.9000 in.	Nozzle Wall Thickness(new):	0.3000 in.
Nozzle ID (corroded):	3.0250 in.	Nozzle Wall Thickness(corroded):	0.2375 in.
External Limit of Reinforcement:	0.5938 in.	Upper Weld Leg Size(Weld 41):	0.3750 in.
Internal Limit of Reinforcement:	0.4375 in.	Internal Weld Leg Size(Weld 43):	0.0000 in.
Parallel Limit of Reinf (2Lpar):	6.0500 in.	Outside Groove Weld Depth:	0.3750 in.

Minimum Design Metal Temperature

Min. Temp. Curve:	B	Pressure at MDMT:	75.00 PSI
UCS-66(b) reduction:	Yes	Minimum Design Metal Temperature:	-20 °F
UCS-68(c) reduction:	No	Computed Minimum Temperature:	-155 °F

Host Component: Shell 1 - 8'-0" OD x 30'-0" LONG SHELL

Material:	SA-516 Gr. 70	Shell wall thickness(new):	0.3750 in.
Material Stress(S _y):	20000 PSI	Shell wall thickness(corroded):	0.3125 in.

Nozzle Detail Information

Backing strip if used may
 be removed after welding




Fig. UW-16.1 (c)

Upper Weld Leg Size(Weld 41): 0.3750 in.

Nozzle Wall Thickness(t_n): 0.3000 in.

Outside Groove Weld Depth: 0.3750 in.

Nozzle passes through the vessel, attached by a groove weld.

Pipe Size: 3 Schedule: 80

Nozzle is adequate for UG-45 requirements.

Opening is adequately reinforced for Internal Pressure.

Reinforcement calculations are not required per UG-36(c)(3)(a) See Uw-14 for exceptions.

Weld Strength Paths are adequate.

PLATINUM ENERGY SERVICES ULC

3" 150# RFWN (N6C)

Job No: 30137 & 30138
 Number: 8
 ID Number: 8

Vessel Number: 01
 Mark Number: N6C

Date Printed: 2/12/2016

Required Shell Thickness per Paragraph UG-37(a)

$$t_r = \frac{P R_o}{S E + 0.4 P} = \frac{78.50 * 48.0000}{20000 * 1 + 0.4 * 78.50} = \mathbf{0.1881 \text{ in.}}$$

Nozzle Required Thickness Calculations**Required Nozzle Thickness for Internal Pressure per Paragraph UG-37(a)**

$$t_{rn} = \frac{P R_n}{S E - 0.6 P} = \frac{78.50 * 1.5125}{17100 * 1 - 0.6 * 78.50} = \mathbf{0.0070 \text{ in.}}$$

Strength Reduction Factors

$$f_{r1} = \min \left\{ \frac{S_n}{S_v}, 1.0000 \right\} = \min \left\{ \frac{17100}{20000}, 1.0000 \right\} = 0.8550 \quad f_{r2} = \min \left\{ \frac{S_n}{S_v}, 1.0000 \right\} = \min \left\{ \frac{17100}{20000}, 1.0000 \right\} = 0.8550$$

UG-45 Thickness Calculations**Nozzle Thickness for Pressure Loading (plus corrosion)**

$$t_a = \frac{P R_n}{S E - 0.6 P} + C_a + \text{ext. Ca} = \frac{78.50 * 1.5125}{17100 * 1.00 - 0.6 * 78.50} + 0.0625 + 0.0000 = \mathbf{0.0695 \text{ in.}}$$

Nozzle Thickness for Internal Pressure (plus corrosion) Based on Host

$$t_{b1} = \frac{P R_o}{S E + 0.4 P} + C_a + \text{ext. Ca} = \frac{78.50 * 48.0000}{20000 * 1 + 0.4 * 78.50} + 0.0625 + 0.0000 = \mathbf{0.2506 \text{ in.}}$$

Minimum Thickness (plus corrosion) per Table UG-45

$$t_{b3} = \text{minimum thickness (Table UG-45)} + C_a + \text{ext. Ca} = \mathbf{0.2515 \text{ in.}}$$

Nozzle Minimum Thickness Based on Host and Table UG-45

$$t_b = \min[t_{b3}, \max(t_{b1}, t_{b2})] = \mathbf{0.2506 \text{ in.}}$$

$$t_{UG-45} = \max(t_a, t_b) = \mathbf{0.2506 \text{ in.}}$$

Wall thickness = $t_n * 0.875(\text{pipe}) = \mathbf{0.2620}$ is greater than or equal to UG-45 value of **0.2506**

PLATINUM ENERGY SERVICES ULC

3" 150# RFWN (N6D)

Job No: 30137 & 30138
 Number: 9
 ID Number: 9

Vessel Number: 01
 Mark Number: N6D

Date Printed: 2/12/2016

Nozzle Design Information

Design Pressure:	75.00 PSI	Design Temperature:	350 °F
Static Head:	3.50 PSI	Nozzle Efficiency (E):	100 %
Nozzle Material:	SA-106 Gr. B	Joint Efficiency (E ₁):	1.00
		Factor B Chart:	CS-2
External Projection:	6.0000 in.	Allowable Stress at Design Temperature (S):	17100 PSI
Internal Projection:	0.0000 in.	Allowable Stress at Ambient Temperature:	17100 PSI
Inside Corrosion Allowance:	0.0625 in.	Correction Factor (F):	1.00
External Corrosion Allowance:	0.0000 in.	Nozzle Path:	None
Nozzle Pipe Size:	3	Nozzle Pipe Schedule:	80
Nozzle ID (new):	2.9000 in.	Nozzle Wall Thickness(new):	0.3000 in.
Nozzle ID (corroded):	3.0250 in.	Nozzle Wall Thickness(corroded):	0.2375 in.
External Limit of Reinforcement:	0.5938 in.	Upper Weld Leg Size(Weld 41):	0.3750 in.
Internal Limit of Reinforcement:	0.4375 in.	Internal Weld Leg Size(Weld 43):	0.0000 in.
Parallel Limit of Reinf (2Lpar):	6.0500 in.	Outside Groove Weld Depth:	0.3750 in.

Minimum Design Metal Temperature

Min. Temp. Curve:	B	Pressure at MDMT:	75.00 PSI
UCS-66(b) reduction:	Yes	Minimum Design Metal Temperature:	-20 °F
UCS-68(c) reduction:	No	Computed Minimum Temperature:	-155 °F

Host Component: Shell 1 - 8'-0" OD x 30'-0" LONG SHELL

Material:	SA-516 Gr. 70	Shell wall thickness(new):	0.3750 in.
Material Stress(S _y):	20000 PSI	Shell wall thickness(corroded):	0.3125 in.

Nozzle Detail Information

Backing strip if used may
 be removed after welding




Fig. UW-16.1 (c)

Upper Weld Leg Size(Weld 41): 0.3750 in.

Nozzle Wall Thickness(t_n): 0.3000 in.

Outside Groove Weld Depth: 0.3750 in.

Nozzle passes through the vessel, attached by a groove weld.

Pipe Size: 3 Schedule: 80

Nozzle is adequate for UG-45 requirements.

Opening is adequately reinforced for Internal Pressure.

Reinforcement calculations are not required per UG-36(c)(3)(a) See Uw-14 for exceptions.

Weld Strength Paths are adequate.

PLATINUM ENERGY SERVICES ULC

3" 150# RFWN (N6D)

Job No: 30137 & 30138
 Number: 9
 ID Number: 9

Vessel Number: 01
 Mark Number: N6D

Date Printed: 2/12/2016

Required Shell Thickness per Paragraph UG-37(a)

$$t_r = \frac{P R_o}{S E + 0.4 P} = \frac{78.50 * 48.0000}{20000 * 1 + 0.4 * 78.50} = \mathbf{0.1881 \text{ in.}}$$

Nozzle Required Thickness Calculations**Required Nozzle Thickness for Internal Pressure per Paragraph UG-37(a)**

$$t_{rn} = \frac{P R_n}{S E - 0.6 P} = \frac{78.50 * 1.5125}{17100 * 1 - 0.6 * 78.50} = \mathbf{0.0070 \text{ in.}}$$

Strength Reduction Factors

$$f_{r1} = \min \left\{ \frac{S_n}{S_v}, 1.0000 \right\} = \min \left\{ \frac{17100}{20000}, 1.0000 \right\} = 0.8550 \quad f_{r2} = \min \left\{ \frac{S_n}{S_v}, 1.0000 \right\} = \min \left\{ \frac{17100}{20000}, 1.0000 \right\} = 0.8550$$

UG-45 Thickness Calculations**Nozzle Thickness for Pressure Loading (plus corrosion)**

$$t_a = \frac{P R_n}{S E - 0.6 P} + C_a + \text{ext. Ca} = \frac{78.50 * 1.5125}{17100 * 1.00 - 0.6 * 78.50} + 0.0625 + 0.0000 = \mathbf{0.0695 \text{ in.}}$$

Nozzle Thickness for Internal Pressure (plus corrosion) Based on Host

$$t_{b1} = \frac{P R_o}{S E + 0.4 P} + C_a + \text{ext. Ca} = \frac{78.50 * 48.0000}{20000 * 1 + 0.4 * 78.50} + 0.0625 + 0.0000 = \mathbf{0.2506 \text{ in.}}$$

Minimum Thickness (plus corrosion) per Table UG-45

$$t_{b3} = \text{minimum thickness (Table UG-45) + } C_a + \text{ext. Ca} = \mathbf{0.2515 \text{ in.}}$$

Nozzle Minimum Thickness Based on Host and Table UG-45

$$t_b = \min[t_{b3}, \max(t_{b1}, t_{b2})] = \mathbf{0.2506 \text{ in.}}$$

$$t_{UG-45} = \max(t_a, t_b) = \mathbf{0.2506 \text{ in.}}$$

Wall thickness = $t_n * 0.875(\text{pipe}) = \mathbf{0.2620}$ is greater than or equal to UG-45 value of **0.2506**

PLATINUM ENERGY SERVICES ULC

4" 150# RFSO (N7A)

Job No: 30137 & 30138
 Number: 10
 ID Number: 10

Vessel Number: 01
 Mark Number: N7A

Date Printed: 2/12/2016

Nozzle Design Information

Design Pressure:	75.00 PSI	Design Temperature:	350 °F
Static Head:	3.50 PSI	Nozzle Efficiency (E):	100 %
Nozzle Material:	SA-106 Gr. B	Joint Efficiency (E ₁):	1.00
		Factor B Chart:	CS-2
External Projection:	6.0000 in.	Allowable Stress at Design Temperature (S):	17100 PSI
Internal Projection:	0.5000 in.	Allowable Stress at Ambient Temperature:	17100 PSI
Inside Corrosion Allowance:	0.0625 in.	Correction Factor (F):	1.00
External Corrosion Allowance:	0.0000 in.	Nozzle Path:	None
Nozzle Pipe Size:	4	Nozzle Pipe Schedule:	80
Nozzle ID (new):	3.8260 in.	Nozzle Wall Thickness(new):	0.3370 in.
Nozzle ID (corroded):	3.9510 in.	Nozzle Wall Thickness(corroded):	0.2745 in.
Developed Opening:	4.4282 in.	Tangential Dimension L:	24.0000 in.
External Limit of Reinforcement:	0.6863 in.	Upper Weld Leg Size(Weld 41):	0.3750 in.
Internal Limit of Reinforcement:	0.5300 in.	Internal Weld Leg Size(Weld 43):	0.3750 in.
Parallel Limit of Reinf (2Lpar):	9.1420 in.	Outside Groove Weld Depth:	0.3750 in.

Minimum Design Metal Temperature

Min. Temp. Curve: B	Pressure at MDMT:	75.00 PSI
UCS-66(b) reduction: Yes	Minimum Design Metal Temperature:	-20 °F
UCS-68(c) reduction: No	Computed Minimum Temperature:	-155 °F

Host Component: Shell 1 - 8'-0" OD x 30'-0" LONG SHELL

Material: SA-516 Gr. 70	Shell wall thickness(new):	0.3750 in.
Material Stress(S _y): 20000 PSI	Shell wall thickness(corroded):	0.3125 in.


Nozzle Detail Information

Fig. UW-16.1 (c)

Upper Weld Leg Size(Weld 41): 0.3750 in.

Internal Weld Leg Size(Weld 43): 0.3750 in.

Nozzle Wall Thickness(t_n): 0.3370 in.

Outside Groove Weld Depth: 0.3750 in.

tangential to the vessel wall, attached by a groove weld.

Pipe Size: 4 Schedule: 80

Nozzle is adequate for UG-45 requirements.

Opening is adequately reinforced for Internal Pressure.

Weld Strength Paths are adequate.

PLATINUM ENERGY SERVICES ULC

4" 150# RFSO (N7A)

Job No: 30137 & 30138
 Number: 10
 ID Number: 10

Vessel Number: 01
 Mark Number: N7A

Date Printed: 2/12/2016

Required Shell Thickness per Paragraph UG-37(a)

$$t_r = \frac{P R_o}{S E + 0.4 P} = \frac{78.50 * 48.0000}{20000 * 1 + 0.4 * 78.50} = \mathbf{0.1881 \text{ in.}}$$

Nozzle Required Thickness Calculations**Required Nozzle Thickness for Internal Pressure per Paragraph UG-37(a)**

$$t_{rn} = \frac{P R_n}{S E - 0.6 P} = \frac{78.50 * 1.9755}{17100 * 1 - 0.6 * 78.50} = \mathbf{0.0091 \text{ in.}}$$

Strength Reduction Factors

$$f_{r1} = \min \left\{ \frac{S_n}{S_v}, 1.0000 \right\} = \min \left\{ \frac{17100}{20000}, 1.0000 \right\} = 0.8550 \quad f_{r2} = \min \left\{ \frac{S_n}{S_v}, 1.0000 \right\} = \min \left\{ \frac{17100}{20000}, 1.0000 \right\} = 0.8550$$

UG-45 Thickness Calculations**Nozzle Thickness for Pressure Loading (plus corrosion)**

$$t_a = \frac{P R_n}{S E - 0.6 P} + C_a + \text{ext. Ca} = \frac{78.50 * 1.9755}{17100 * 1.00 - 0.6 * 78.50} + 0.0625 + 0.0000 = \mathbf{0.0716 \text{ in.}}$$

Nozzle Thickness for Internal Pressure (plus corrosion) Based on Host

$$t_{b1} = \frac{P R_o}{S E + 0.4 P} + C_a + \text{ext. Ca} = \frac{78.50 * 48.0000}{20000 * 1 + 0.4 * 78.50} + 0.0625 + 0.0000 = \mathbf{0.2506 \text{ in.}}$$

Minimum Thickness (plus corrosion) per Table UG-45

$$t_{b3} = \text{minimum thickness (Table UG-45) + } C_a + \text{ext. Ca} = \mathbf{0.2695 \text{ in.}}$$

Nozzle Minimum Thickness Based on Host and Table UG-45

$$t_b = \min[t_{b3}, \max(t_{b1}, t_{b2})] = \mathbf{0.2506 \text{ in.}}$$

$$t_{UG-45} = \max(t_a, t_b) = \mathbf{0.2506 \text{ in.}}$$

Wall thickness = $t_n * 0.875(\text{pipe}) = \mathbf{0.2950}$ is greater than or equal to UG-45 value of **0.2506**

PLATINUM ENERGY SERVICES ULC

4" 150# RFSO (N7A)

Job No: 30137 & 30138
 Number: 10
 ID Number: 10

Vessel Number: 01
 Mark Number: N7A

Date Printed: 2/12/2016

Limits of Reinforcement (UG-40)

$$\begin{aligned}
 L_{par} &= \max(d, R_n + t + t_h) = \max(4.5710, 1.9755 + 0.3125 + 0.2745) &= \mathbf{4.5710 \text{ in.}} \\
 L_{noro} &= \min(2.5 t, 2.5 t_h + t_e) = \min(2.5 * 0.3125, 2.5 * 0.2745 + 0.0000) &= \mathbf{0.6863 \text{ in.}} \\
 L_{nori} &= \min(2.5 t, 2.5 t_i) = \min(2.5 * 0.3125, 2.5 * 0.2120) &= \mathbf{0.5300 \text{ in.}}
 \end{aligned}$$

Nozzle Reinforcement Calculations (Internal Pressure)

$$\mathbf{A} = \max\{C [d t_r F + 2 t_n t_r F (1 - f_{r1})], 0\} = \max\{1.0000 * [4.5710 * 0.1881 * 1.00 + 2 * 0.2745 * 0.1881 * 1.00 * (1 - 0.8550)], 0\} \\
 = \mathbf{0.8748 \text{ sq. in.}}$$

$$\begin{aligned}
 \mathbf{A1} &= \max\{2 L_{par} - d (E_1 t - F t_r) - 2 t_n (E_1 t - F t_r) (1 - f_{r1}), 0\} = \\
 &\max\{(2 * 4.5710 - 4.5710) * (1.0000 * 0.3125 - 1.00 * 0.1881) - 2 * 0.2745 * (1.0000 * 0.3125 - 1.00 * 0.1881) * (1 - 0.8550), 0\} \\
 &= \mathbf{0.5587 \text{ sq. in.}}
 \end{aligned}$$

$$\begin{aligned}
 \mathbf{A2} &= \max\{2 \min(h_o, L_{noro}) [\min(t_h, L_{par} - 0.5 d) - t_{rn}] f_{r2}, 0\} = \\
 &\max\{2 * \min(6.0000, 0.6863) * [\min(0.2745, 4.5710 - 0.5 * 4.5710) - 0.0091] * 0.8550, 0\} \\
 &= \mathbf{0.3114 \text{ sq. in.}}
 \end{aligned}$$

$$\begin{aligned}
 \mathbf{A3} &= \max\{2 \min(h, L_{nori}) \min(t_i, L_{par} - 0.5 d) f_{r2}, 0\} = \\
 &\max\{2 * \min(0.4375, 0.5300) * \min(0.2120, 4.5710 - 0.5 * 4.5710) * 0.8550, 0\} \\
 &= \mathbf{0.1586 \text{ sq. in.}}
 \end{aligned}$$

$$\begin{aligned}
 \mathbf{A41} &= f_{r2} [L_{41}^2 - (L_{41} - L_{41pareff})^2 - (L_{41} - L_{41noreff})^2] = \\
 &0.8550 * [0.3750^2 - (0.3750 - 0.3750)^2 - (0.3750 - 0.3750)^2] \\
 &= \mathbf{0.1202 \text{ sq. in.}}
 \end{aligned}$$

$$\begin{aligned}
 \mathbf{A42} &= f_{r4} L_{42pareff} L_{42noreff} = \\
 &0.0000 * 0.0000 * 0.0000 \\
 &= \mathbf{0.0000 \text{ sq. in.}}
 \end{aligned}$$

$$\begin{aligned}
 \mathbf{A43} &= f_{r2} [L_{43}^2 - (L_{43} - L_{43pareff})^2 - (L_{43} - L_{43noreff})^2] = \\
 &0.8550 * [0.2857^2 - (0.2857 - 0.2857)^2 - (0.2857 - 0.2857)^2] \\
 &= \mathbf{0.0698 \text{ sq. in.}}
 \end{aligned}$$

$$\begin{aligned}
 \mathbf{A5} &= \\
 &= \mathbf{0.0000 \text{ sq. in.}}
 \end{aligned}$$

$$\mathbf{Area Available (Internal Pressure)} = A1 + A2 + A3 + A41 + A42 + A43 + A5 = 1.2188 \text{ sq. in., which is } \geq A (0.8748)$$

4" 150# RFSO (N7B)

Job No: 30137 & 30138
Number: 11
ID Number: 11

Vessel Number:01
Mark Number: N7B

Date Printed: 2/12/2016

Nozzle Design Information

Design Pressure:	75.00	PSI	Design Temperature:	350	°F
Static Head:	3.50	PSI	Nozzle Efficiency (E):	100	%
Nozzle Material:	SA-106 Gr. B		Joint Efficiency (E ₁):	1.00	
			Factor B Chart:	CS-2	
External Projection:	6.0000	in.	Allowable Stress at Design Temperature (S):	17100	PSI
Internal Projection:	0.5000	in.	Allowable Stress at Ambient Temperature:	17100	PSI
Inside Corrosion Allowance:	0.0625	in.	Correction Factor (F):	1.00	
External Corrosion Allowance:	0.0000	in.	Nozzle Path:	None	
Nozzle Pipe Size:	4		Nozzle Pipe Schedule:	80	
Nozzle ID (new):	3.8260	in.	Nozzle Wall Thickness(new):	0.3370	in.
Nozzle ID (corroded):	3.9510	in.	Nozzle Wall Thickness(corroded):	0.2745	in.
Developed Opening:	4.4282	in.	Tangential Dimension L:	24.0000	in.
External Limit of Reinforcement:	0.6863	in.	Upper Weld Leg Size(Weld 41):	0.3750	in.
Internal Limit of Reinforcement:	0.5300	in.	Internal Weld Leg Size(Weld 43):	0.3750	in.
Parallel Limit of Reinf (2Lpar):	9.1420	in.	Outside Groove Weld Depth:	0.3750	in.

Minimum Design Metal Temperature

Min. Temp. Curve: B	Pressure at MDMT: 75.00 PSI
UCS-66(b) reduction: Yes	Minimum Design Metal Temperature: -20 °F
UCS-68(c) reduction: No	Computed Minimum Temperature: -155 °F

Host Component: Shell 1 - 8'-0" OD x 30'-0" LONG SHELL

Material:	SA-516 Gr. 70	Shell wall thickness(new):	0.3750 in.
Material Stress(S_v):	20000 PSI	Shell wall thickness(corroded):	0.3125 in.

Nozzle Detail Information




Fig. UV-16.1 (c)

Upper Weld Leg Size(Weld 41): 0.3750 in.

Internal Weld Leg Size(Weld 43): 0.3750 in.

Nozzle Wall Thickness(t_n): 0.3370 in.

Outside Groove Weld Depth: 0.3750 in.

tangential to the vessel wall, attached by a groove weld.

Pipe Size: 4 Schedule: 80

Nozzle is adequate for UG-45 requirements.

Opening is adequately reinforced for Internal Pressure.

Weld Strength Paths are adequate.

PLATINUM ENERGY SERVICES ULC

4" 150# RFSO (N7B)

Job No: 30137 & 30138
 Number: 11
 ID Number: 11

Vessel Number: 01
 Mark Number: N7B

Date Printed: 2/12/2016

Required Shell Thickness per Paragraph UG-37(a)

$$t_r = \frac{P R_o}{S E + 0.4 P} = \frac{78.50 * 48.0000}{20000 * 1 + 0.4 * 78.50} = \mathbf{0.1881 \text{ in.}}$$

Nozzle Required Thickness Calculations**Required Nozzle Thickness for Internal Pressure per Paragraph UG-37(a)**

$$t_{rn} = \frac{P R_n}{S E - 0.6 P} = \frac{78.50 * 1.9755}{17100 * 1 - 0.6 * 78.50} = \mathbf{0.0091 \text{ in.}}$$

Strength Reduction Factors

$$f_{r1} = \min \left\{ \frac{S_n}{S_v}, 1.0000 \right\} = \min \left\{ \frac{17100}{20000}, 1.0000 \right\} = 0.8550 \quad f_{r2} = \min \left\{ \frac{S_n}{S_v}, 1.0000 \right\} = \min \left\{ \frac{17100}{20000}, 1.0000 \right\} = 0.8550$$

UG-45 Thickness Calculations**Nozzle Thickness for Pressure Loading (plus corrosion)**

$$t_a = \frac{P R_n}{S E - 0.6 P} + C_a + \text{ext. } C_a = \frac{78.50 * 1.9755}{17100 * 1.00 - 0.6 * 78.50} + 0.0625 + 0.0000 = \mathbf{0.0716 \text{ in.}}$$

Nozzle Thickness for Internal Pressure (plus corrosion) Based on Host

$$t_{b1} = \frac{P R_o}{S E + 0.4 P} + C_a + \text{ext. } C_a = \frac{78.50 * 48.0000}{20000 * 1 + 0.4 * 78.50} + 0.0625 + 0.0000 = \mathbf{0.2506 \text{ in.}}$$

Minimum Thickness (plus corrosion) per Table UG-45

$$t_{b3} = \text{minimum thickness (Table UG-45) + } C_a + \text{ext. } C_a = \mathbf{0.2695 \text{ in.}}$$

Nozzle Minimum Thickness Based on Host and Table UG-45

$$t_b = \min[t_{b3}, \max(t_{b1}, t_{b2})] = \mathbf{0.2506 \text{ in.}}$$

$$t_{UG-45} = \max(t_a, t_b) = \mathbf{0.2506 \text{ in.}}$$

Wall thickness = $t_n * 0.875(\text{pipe}) = \mathbf{0.2950}$ is greater than or equal to UG-45 value of **0.2506**

PLATINUM ENERGY SERVICES ULC

4" 150# RFSO (N7B)

Job No: 30137 & 30138
 Number: 11
 ID Number: 11

Vessel Number: 01
 Mark Number: N7B

Date Printed: 2/12/2016

Limits of Reinforcement (UG-40)

$$\begin{aligned}
 L_{par} &= \max(d, R_n + t + t_h) = \max(4.5710, 1.9755 + 0.3125 + 0.2745) &= \mathbf{4.5710 \text{ in.}} \\
 L_{noro} &= \min(2.5 t, 2.5 t_h + t_e) = \min(2.5 * 0.3125, 2.5 * 0.2745 + 0.0000) &= \mathbf{0.6863 \text{ in.}} \\
 L_{nori} &= \min(2.5 t, 2.5 t_i) = \min(2.5 * 0.3125, 2.5 * 0.2120) &= \mathbf{0.5300 \text{ in.}}
 \end{aligned}$$

Nozzle Reinforcement Calculations (Internal Pressure)

$$\mathbf{A} = \max\{C [d t_r F + 2 t_n t_r F (1 - f_{r1})], 0\} = \max\{1.0000 * [4.5710 * 0.1881 * 1.00 + 2 * 0.2745 * 0.1881 * 1.00 * (1 - 0.8550)], 0\} \\
 = \mathbf{0.8748 \text{ sq. in.}}$$

$$\begin{aligned}
 \mathbf{A1} &= \max\{2 L_{par} - d (E_1 t - F t_r) - 2 t_n (E_1 t - F t_r) (1 - f_{r1}), 0\} = \\
 &\max\{2 * 4.5710 - 4.5710 * (1.0000 * 0.3125 - 1.00 * 0.1881) - 2 * 0.2745 * (1.0000 * 0.3125 - 1.00 * 0.1881) * (1 - 0.8550), 0\} \\
 &= \mathbf{0.5587 \text{ sq. in.}}
 \end{aligned}$$

$$\begin{aligned}
 \mathbf{A2} &= \max\{2 \min(h_o, L_{noro}) [\min(t_h, L_{par} - 0.5 d) - t_{rn}] f_{r2}, 0\} = \\
 &\max\{2 * \min(6.0000, 0.6863) * [\min(0.2745, 4.5710 - 0.5 * 4.5710) - 0.0091] * 0.8550, 0\} \\
 &= \mathbf{0.3114 \text{ sq. in.}}
 \end{aligned}$$

$$\begin{aligned}
 \mathbf{A3} &= \max\{2 \min(h, L_{nori}) \min(t_i, L_{par} - 0.5 d) f_{r2}, 0\} = \\
 &\max\{2 * \min(0.4375, 0.5300) * \min(0.2120, 4.5710 - 0.5 * 4.5710) * 0.8550, 0\} \\
 &= \mathbf{0.1586 \text{ sq. in.}}
 \end{aligned}$$

$$\begin{aligned}
 \mathbf{A41} &= f_{r2} [L_{41}^2 - (L_{41} - L_{41pareff})^2 - (L_{41} - L_{41noreff})^2] = \\
 &0.8550 * [0.3750^2 - (0.3750 - 0.3750)^2 - (0.3750 - 0.3750)^2] \\
 &= \mathbf{0.1202 \text{ sq. in.}}
 \end{aligned}$$

$$\begin{aligned}
 \mathbf{A42} &= f_{r4} L_{42pareff} L_{42noreff} = \\
 &0.0000 * 0.0000 * 0.0000 \\
 &= \mathbf{0.0000 \text{ sq. in.}}
 \end{aligned}$$

$$\begin{aligned}
 \mathbf{A43} &= f_{r2} [L_{43}^2 - (L_{43} - L_{43pareff})^2 - (L_{43} - L_{43noreff})^2] = \\
 &0.8550 * [0.2857^2 - (0.2857 - 0.2857)^2 - (0.2857 - 0.2857)^2] \\
 &= \mathbf{0.0698 \text{ sq. in.}}
 \end{aligned}$$

$$\begin{aligned}
 \mathbf{A5} &= \\
 &= \mathbf{0.0000 \text{ sq. in.}}
 \end{aligned}$$

$$\mathbf{Area Available (Internal Pressure)} = A1 + A2 + A3 + A41 + A42 + A43 + A5 = 1.2188 \text{ sq. in., which is } \geq A (0.8748)$$

4" 150# RFSO (N7C)

Job No: 30137 & 30138
Number: 12
ID Number: 12

Vessel Number:01
Mark Number: N7C

Date Printed: 2/12/2016

Nozzle Design Information

Design Pressure:	75.00	PSI	Design Temperature:	350	°F
Static Head:	3.50	PSI	Nozzle Efficiency (E):	100	%
Nozzle Material:	SA-106 Gr. B		Joint Efficiency (E ₁):	1.00	
			Factor B Chart:	CS-2	
External Projection:	6.0000	in.	Allowable Stress at Design Temperature (S):	17100	PSI
Internal Projection:	0.5000	in.	Allowable Stress at Ambient Temperature:	17100	PSI
Inside Corrosion Allowance:	0.0625	in.	Correction Factor (F):	1.00	
External Corrosion Allowance:	0.0000	in.	Nozzle Path:	None	
Nozzle Pipe Size:	4		Nozzle Pipe Schedule:	80	
Nozzle ID (new):	3.8260	in.	Nozzle Wall Thickness(new):	0.3370	in.
Nozzle ID (corroded):	3.9510	in.	Nozzle Wall Thickness(corroded):	0.2745	in.
Developed Opening:	4.4282	in.	Tangential Dimension L:	24.0000	in.
External Limit of Reinforcement:	0.6863	in.	Upper Weld Leg Size(Weld 41):	0.3750	in.
Internal Limit of Reinforcement:	0.5300	in.	Internal Weld Leg Size(Weld 43):	0.3750	in.
Parallel Limit of Reinf (2Lpar):	9.1420	in.	Outside Groove Weld Depth:	0.3750	in.

Minimum Design Metal Temperature

Min. Temp. Curve: B	Pressure at MDMT: 75.00 PSI
UCS-66(b) reduction: Yes	Minimum Design Metal Temperature: -20 °F
UCS-68(c) reduction: No	Computed Minimum Temperature: -155 °F

Host Component: Shell 1 - 8'-0" OD x 30'-0" LONG SHELL

Material:	SA-516 Gr. 70	Shell wall thickness(new):	0.3750 in.
Material Stress(S_v):	20000 PSI	Shell wall thickness(corroded):	0.3125 in.

Nozzle Detail Information




Fig. UV-16.1 (c)

Upper Weld Leg Size(Weld 41): 0.3750 in.

Internal Weld Leg Size(Weld 43): 0.3750 in.

Nozzle Wall Thickness(t_n): 0.3370 in.

Outside Groove Weld Depth: 0.3750 in.

tangential to the vessel wall, attached by a groove weld.

Pipe Size: 4 Schedule: 80

Nozzle is adequate for UG-45 requirements.

Opening is adequately reinforced for Internal Pressure.

Weld Strength Paths are adequate.

PLATINUM ENERGY SERVICES ULC

4" 150# RFSO (N7C)

Job No: 30137 & 30138
 Number: 12
 ID Number: 12

Vessel Number: 01
 Mark Number: N7C

Date Printed: 2/12/2016

Required Shell Thickness per Paragraph UG-37(a)

$$t_r = \frac{P R_o}{S E + 0.4 P} = \frac{78.50 * 48.0000}{20000 * 1 + 0.4 * 78.50} = \mathbf{0.1881 \text{ in.}}$$

Nozzle Required Thickness Calculations**Required Nozzle Thickness for Internal Pressure per Paragraph UG-37(a)**

$$t_{rn} = \frac{P R_n}{S E - 0.6 P} = \frac{78.50 * 1.9755}{17100 * 1 - 0.6 * 78.50} = \mathbf{0.0091 \text{ in.}}$$

Strength Reduction Factors

$$f_{r1} = \min \left\{ \frac{S_n}{S_v}, 1.0000 \right\} = \min \left\{ \frac{17100}{20000}, 1.0000 \right\} = 0.8550 \quad f_{r2} = \min \left\{ \frac{S_n}{S_v}, 1.0000 \right\} = \min \left\{ \frac{17100}{20000}, 1.0000 \right\} = 0.8550$$

UG-45 Thickness Calculations**Nozzle Thickness for Pressure Loading (plus corrosion)**

$$t_a = \frac{P R_n}{S E - 0.6 P} + C_a + \text{ext. Ca} = \frac{78.50 * 1.9755}{17100 * 1.00 - 0.6 * 78.50} + 0.0625 + 0.0000 = \mathbf{0.0716 \text{ in.}}$$

Nozzle Thickness for Internal Pressure (plus corrosion) Based on Host

$$t_{b1} = \frac{P R_o}{S E + 0.4 P} + C_a + \text{ext. Ca} = \frac{78.50 * 48.0000}{20000 * 1 + 0.4 * 78.50} + 0.0625 + 0.0000 = \mathbf{0.2506 \text{ in.}}$$

Minimum Thickness (plus corrosion) per Table UG-45

$$t_{b3} = \text{minimum thickness (Table UG-45) + } C_a + \text{ext. Ca} = \mathbf{0.2695 \text{ in.}}$$

Nozzle Minimum Thickness Based on Host and Table UG-45

$$t_b = \min[t_{b3}, \max(t_{b1}, t_{b2})] = \mathbf{0.2506 \text{ in.}}$$

$$t_{UG-45} = \max(t_a, t_b) = \mathbf{0.2506 \text{ in.}}$$

Wall thickness = $t_n * 0.875(\text{pipe}) = \mathbf{0.2950}$ is greater than or equal to UG-45 value of **0.2506**

PLATINUM ENERGY SERVICES ULC

4" 150# RFSO (N7C)

Job No: 30137 & 30138
 Number: 12
 ID Number: 12

Vessel Number: 01
 Mark Number: N7C

Date Printed: 2/12/2016

Limits of Reinforcement (UG-40)

$$\begin{aligned}
 L_{par} &= \max(d, R_n + t + t_h) = \max(4.5710, 1.9755 + 0.3125 + 0.2745) &= \mathbf{4.5710 \text{ in.}} \\
 L_{noro} &= \min(2.5 t, 2.5 t_h + t_e) = \min(2.5 * 0.3125, 2.5 * 0.2745 + 0.0000) &= \mathbf{0.6863 \text{ in.}} \\
 L_{nori} &= \min(2.5 t, 2.5 t_i) = \min(2.5 * 0.3125, 2.5 * 0.2120) &= \mathbf{0.5300 \text{ in.}}
 \end{aligned}$$

Nozzle Reinforcement Calculations (Internal Pressure)

$$\mathbf{A} = \max\{C [d t_r F + 2 t_n t_r F (1 - f_{r1})], 0\} = \max\{1.0000 * [4.5710 * 0.1881 * 1.00 + 2 * 0.2745 * 0.1881 * 1.00 * (1 - 0.8550)], 0\} \\
 = \mathbf{0.8748 \text{ sq. in.}}$$

$$\begin{aligned}
 \mathbf{A1} &= \max\{2 L_{par} - d (E_1 t - F t_r) - 2 t_n (E_1 t - F t_r) (1 - f_{r1}), 0\} = \\
 &\max\{2 * 4.5710 - 4.5710 * (1.0000 * 0.3125 - 1.00 * 0.1881) - 2 * 0.2745 * (1.0000 * 0.3125 - 1.00 * 0.1881) * (1 - 0.8550), 0\} \\
 &= \mathbf{0.5587 \text{ sq. in.}}
 \end{aligned}$$

$$\begin{aligned}
 \mathbf{A2} &= \max\{2 \min(h_o, L_{noro}) [\min(t_h, L_{par} - 0.5 d) - t_{rn}] f_{r2}, 0\} = \\
 &\max\{2 * \min(6.0000, 0.6863) * [\min(0.2745, 4.5710 - 0.5 * 4.5710) - 0.0091] * 0.8550, 0\} \\
 &= \mathbf{0.3114 \text{ sq. in.}}
 \end{aligned}$$

$$\begin{aligned}
 \mathbf{A3} &= \max\{2 \min(h, L_{nori}) \min(t_i, L_{par} - 0.5 d) f_{r2}, 0\} = \\
 &\max\{2 * \min(0.4375, 0.5300) * \min(0.2120, 4.5710 - 0.5 * 4.5710) * 0.8550, 0\} \\
 &= \mathbf{0.1586 \text{ sq. in.}}
 \end{aligned}$$

$$\begin{aligned}
 \mathbf{A41} &= f_{r2} [L_{41}^2 - (L_{41} - L_{41pareff})^2 - (L_{41} - L_{41noreff})^2] = \\
 &0.8550 * [0.3750^2 - (0.3750 - 0.3750)^2 - (0.3750 - 0.3750)^2] \\
 &= \mathbf{0.1202 \text{ sq. in.}}
 \end{aligned}$$

$$\begin{aligned}
 \mathbf{A42} &= f_{r4} L_{42pareff} L_{42noreff} = \\
 &0.0000 * 0.0000 * 0.0000 \\
 &= \mathbf{0.0000 \text{ sq. in.}}
 \end{aligned}$$

$$\begin{aligned}
 \mathbf{A43} &= f_{r2} [L_{43}^2 - (L_{43} - L_{43pareff})^2 - (L_{43} - L_{43noreff})^2] = \\
 &0.8550 * [0.2857^2 - (0.2857 - 0.2857)^2 - (0.2857 - 0.2857)^2] \\
 &= \mathbf{0.0698 \text{ sq. in.}}
 \end{aligned}$$

$$\begin{aligned}
 \mathbf{A5} &= \\
 &= \mathbf{0.0000 \text{ sq. in.}}
 \end{aligned}$$

$$\mathbf{Area \text{ Available (Internal Pressure)} = A1 + A2 + A3 + A41 + A42 + A43 + A5 = 1.2188 \text{ sq. in., which is } \geq A (0.8748)}$$

PLATINUM ENERGY SERVICES ULC

1" 150# RFSO (N8)

Job No: 30137 & 30138
 Number: 13
 ID Number: 13

Vessel Number: 01
 Mark Number: N8

Date Printed: 2/12/2016

Nozzle Design Information

Design Pressure:	75.00 PSI	Design Temperature:	350 °F
Static Head:	3.50 PSI	Nozzle Efficiency (E):	100 %
Nozzle Material:	SA-106 Gr. B	Joint Efficiency (E ₁):	1.00
		Factor B Chart:	CS-2
External Projection:	6.0000 in.	Allowable Stress at Design Temperature (S):	17100 PSI
Internal Projection:	0.0000 in.	Allowable Stress at Ambient Temperature:	17100 PSI
Inside Corrosion Allowance:	0.0625 in.	Correction Factor (F):	1.00
External Corrosion Allowance:	0.0000 in.	Nozzle Path:	None
Nozzle Pipe Size:	1	Nozzle Pipe Schedule:	160
Nozzle ID (new):	0.8150 in.	Nozzle Wall Thickness(new):	0.2500 in.
Nozzle ID (corroded):	0.9400 in.	Nozzle Wall Thickness(corroded):	0.1875 in.
Developed Opening:	0.8497 in.	Tangential Dimension L:	13.5000 in.
External Limit of Reinforcement:	0.4688 in.	Upper Weld Leg Size(Weld 41):	0.3750 in.
Internal Limit of Reinforcement:	0.3125 in.	Internal Weld Leg Size(Weld 43):	0.0000 in.
Parallel Limit of Reinf (2Lpar):	1.9598 in.	Outside Groove Weld Depth:	0.3750 in.

Minimum Design Metal Temperature

Min. Temp. Curve: B	Pressure at MDMT:	75.00 PSI
UCS-66(b) reduction: Yes	Minimum Design Metal Temperature:	-20 °F
UCS-68(c) reduction: No	Computed Minimum Temperature:	-155 °F

Host Component: Shell 1 - 8'-0" OD x 30'-0" LONG SHELL

Material:	SA-516 Gr. 70	Shell wall thickness(new):	0.3750 in.
Material Stress(S _y):	20000 PSI	Shell wall thickness(corroded):	0.3125 in.


Nozzle Detail Information

Fig. UW-16.1 (c)

Upper Weld Leg Size(Weld 41): 0.3750 in.

Nozzle Wall Thickness(t_n): 0.2500 in.

Outside Groove Weld Depth: 0.3750 in.

tangential to the vessel wall, attached by a groove weld.

Pipe Size: 1 Schedule: 160

Nozzle is adequate for UG-45 requirements.

Opening is adequately reinforced for Internal Pressure.

Reinforcement calculations are not required per UG-36(c)(3)(a) See Uw-14 for exceptions.

Weld Strength Paths are adequate.

PLATINUM ENERGY SERVICES ULC

1" 150# RFSO (N8)

Job No: 30137 & 30138
 Number: 13
 ID Number: 13

Vessel Number: 01
 Mark Number: N8

Date Printed: 2/12/2016

Required Shell Thickness per Paragraph UG-37(a)

$$t_r = \frac{P R_o}{S E + 0.4 P} = \frac{78.50 * 48.0000}{20000 * 1 + 0.4 * 78.50} = \mathbf{0.1881 \text{ in.}}$$

Nozzle Required Thickness Calculations**Required Nozzle Thickness for Internal Pressure per Paragraph UG-37(a)**

$$t_{rn} = \frac{P R_n}{S E - 0.6 P} = \frac{78.50 * 0.4700}{17100 * 1 - 0.6 * 78.50} = \mathbf{0.0022 \text{ in.}}$$

Strength Reduction Factors

$$f_{r1} = \min \left[\frac{S_n}{S_v}, 1.0000 \right] = \min \left[\frac{17100}{20000}, 1.0000 \right] = 0.8550 \quad f_{r2} = \min \left[\frac{S_n}{S_v}, 1.0000 \right] = \min \left[\frac{17100}{20000}, 1.0000 \right] = 0.8550$$

UG-45 Thickness Calculations**Nozzle Thickness for Pressure Loading (plus corrosion)**

$$t_a = \frac{P R_n}{S E - 0.6 P} + C_a + \text{ext. Ca} = \frac{78.50 * 0.4700}{17100 * 1.00 - 0.6 * 78.50} + 0.0625 + 0.0000 = \mathbf{0.0647 \text{ in.}}$$

Nozzle Thickness for Internal Pressure (plus corrosion) Based on Host

$$t_{b1} = \frac{P R_o}{S E + 0.4 P} + C_a + \text{ext. Ca} = \frac{78.50 * 48.0000}{20000 * 1 + 0.4 * 78.50} + 0.0625 + 0.0000 = \mathbf{0.2506 \text{ in.}}$$

Minimum Thickness (plus corrosion) per Table UG-45

$$t_{b3} = \text{minimum thickness (Table UG-45) + } C_a + \text{ext. Ca} = \mathbf{0.1785 \text{ in.}}$$

Nozzle Minimum Thickness Based on Host and Table UG-45

$$t_b = \min[t_{b3}, \max(t_{b1}, t_{b2})] = \mathbf{0.1785 \text{ in.}}$$

$$t_{UG-45} = \max(t_a, t_b) = \mathbf{0.1785 \text{ in.}}$$

Wall thickness = $t_n * 0.875(\text{pipe}) = \mathbf{0.2190}$ is greater than or equal to UG-45 value of **0.1785**

PLATINUM ENERGY SERVICES ULC

1" 150# RFSO (N9)

Job No: 30137 & 30138
 Number: 14
 ID Number: 14

Vessel Number: 01
 Mark Number: N9

Date Printed: 2/12/2016

Nozzle Design Information

Design Pressure:	75.00 PSI	Design Temperature:	350 °F
Static Head:	3.50 PSI	Nozzle Efficiency (E):	100 %
Nozzle Material:	SA-106 Gr. B	Joint Efficiency (E ₁):	1.00
		Factor B Chart:	CS-2
External Projection:	6.0000 in.	Allowable Stress at Design Temperature (S):	17100 PSI
Internal Projection:	0.0000 in.	Allowable Stress at Ambient Temperature:	17100 PSI
Inside Corrosion Allowance:	0.0625 in.	Correction Factor (F):	1.00
External Corrosion Allowance:	0.0000 in.	Nozzle Path:	None
Nozzle Pipe Size:	1	Nozzle Pipe Schedule:	160
Nozzle ID (new):	0.8150 in.	Nozzle Wall Thickness(new):	0.2500 in.
Nozzle ID (corroded):	0.9400 in.	Nozzle Wall Thickness(corroded):	0.1875 in.
Developed Opening:	0.8497 in.	Tangential Dimension L:	13.5000 in.
External Limit of Reinforcement:	0.4688 in.	Upper Weld Leg Size(Weld 41):	0.3750 in.
Internal Limit of Reinforcement:	0.3125 in.	Internal Weld Leg Size(Weld 43):	0.0000 in.
Parallel Limit of Reinf (2Lpar):	1.9598 in.	Outside Groove Weld Depth:	0.3750 in.

Minimum Design Metal Temperature

Min. Temp. Curve: B	Pressure at MDMT:	75.00 PSI
UCS-66(b) reduction: Yes	Minimum Design Metal Temperature:	-20 °F
UCS-68(c) reduction: No	Computed Minimum Temperature:	-155 °F

Host Component: Shell 1 - 8'-0" OD x 30'-0" LONG SHELL

Material:	SA-516 Gr. 70	Shell wall thickness(new):	0.3750 in.
Material Stress(S _y):	20000 PSI	Shell wall thickness(corroded):	0.3125 in.


Nozzle Detail Information

Fig. UW-16.1 (c)

Upper Weld Leg Size(Weld 41): 0.3750 in.

Nozzle Wall Thickness(t_n): 0.2500 in.

Outside Groove Weld Depth: 0.3750 in.

tangential to the vessel wall, attached by a groove weld.

Pipe Size: 1 Schedule: 160

Nozzle is adequate for UG-45 requirements.

Opening is adequately reinforced for Internal Pressure.

Reinforcement calculations are not required per UG-36(c)(3)(a) See Uw-14 for exceptions.

Weld Strength Paths are adequate.

PLATINUM ENERGY SERVICES ULC

1" 150# RFSO (N9)

Job No: 30137 & 30138
 Number: 14
 ID Number: 14

Vessel Number: 01
 Mark Number: N9

Date Printed: 2/12/2016

Required Shell Thickness per Paragraph UG-37(a)

$$t_r = \frac{P R_o}{S E + 0.4 P} = \frac{78.50 * 48.0000}{20000 * 1 + 0.4 * 78.50} = \mathbf{0.1881 \text{ in.}}$$

Nozzle Required Thickness Calculations**Required Nozzle Thickness for Internal Pressure per Paragraph UG-37(a)**

$$t_{rn} = \frac{P R_n}{S E - 0.6 P} = \frac{78.50 * 0.4700}{17100 * 1 - 0.6 * 78.50} = \mathbf{0.0022 \text{ in.}}$$

Strength Reduction Factors

$$f_{r1} = \min \left\{ \frac{S_n}{S_v}, 1.0000 \right\} = \min \left\{ \frac{17100}{20000}, 1.0000 \right\} = 0.8550 \quad f_{r2} = \min \left\{ \frac{S_n}{S_v}, 1.0000 \right\} = \min \left\{ \frac{17100}{20000}, 1.0000 \right\} = 0.8550$$

UG-45 Thickness Calculations**Nozzle Thickness for Pressure Loading (plus corrosion)**

$$t_a = \frac{P R_n}{S E - 0.6 P} + C_a + \text{ext. Ca} = \frac{78.50 * 0.4700}{17100 * 1.00 - 0.6 * 78.50} + 0.0625 + 0.0000 = \mathbf{0.0647 \text{ in.}}$$

Nozzle Thickness for Internal Pressure (plus corrosion) Based on Host

$$t_{b1} = \frac{P R_o}{S E + 0.4 P} + C_a + \text{ext. Ca} = \frac{78.50 * 48.0000}{20000 * 1 + 0.4 * 78.50} + 0.0625 + 0.0000 = \mathbf{0.2506 \text{ in.}}$$

Minimum Thickness (plus corrosion) per Table UG-45

$$t_{b3} = \text{minimum thickness (Table UG-45) + } C_a + \text{ext. Ca} = \mathbf{0.1785 \text{ in.}}$$

Nozzle Minimum Thickness Based on Host and Table UG-45

$$t_b = \min[t_{b3}, \max(t_{b1}, t_{b2})] = \mathbf{0.1785 \text{ in.}}$$

$$t_{UG-45} = \max(t_a, t_b) = \mathbf{0.1785 \text{ in.}}$$

Wall thickness = $t_n * 0.875(\text{pipe}) = \mathbf{0.2190}$ is greater than or equal to UG-45 value of **0.1785**

2" 150# RFSO (N10A)

Job No: 30137 & 30138
Number: 15
ID Number: 15

Vessel Number: 01
Mark Number: N10A

Date Printed: 2/12/2016

Nozzle Design Information

Design Pressure:	75.00	PSI	Design Temperature:	350	°F
Static Head:	3.50	PSI	Nozzle Efficiency (E):	100	%
Nozzle Material:	SA-106 Gr. B		Joint Efficiency (E ₁):	1.00	
			Factor B Chart:	CS-2	
External Projection:	6.0000	in.	Allowable Stress at Design Temperature (S):	17100	PSI
Internal Projection:	12.0000	in.	Allowable Stress at Ambient Temperature:	17100	PSI
Inside Corrosion Allowance:	0.0625	in.	Correction Factor (F):	1.00	
External Corrosion Allowance:	0.0000	in.	Nozzle Path:	None	
Nozzle Pipe Size:	2		Nozzle Pipe Schedule:	160	
Nozzle ID (new):	1.6870	in.	Nozzle Wall Thickness(new):	0.3440	in.
Nozzle ID (corroded):	1.8120	in.	Nozzle Wall Thickness(corroded):	0.2815	in.
Developed Opening:	1.7251	in.	Tangential Dimension L:	20.0000 in.	
External Limit of Reinforcement:	0.7038	in.	Upper Weld Leg Size(Weld 41):	0.3750 in.	
Internal Limit of Reinforcement:	0.5475	in.	Internal Weld Leg Size(Weld 43):	0.3750 in.	
Parallel Limit of Reinf (2Lpar):	3.7002	in.	Outside Groove Weld Depth:	0.4375 in.	

Minimum Design Metal Temperature

Min. Temp. Curve: B	Pressure at MDMT:	75.00	PSI
UCS-66(b) reduction: Yes	Minimum Design Metal Temperature:	-20	°F
UCS-68(c) reduction: No	Computed Minimum Temperature:	-155	°F

Host Component: Head 1 - 96" OD FLANGED & DISHED HEAD C/W 1.5" SF (RIGHT SIDE)

Material:	SA-516 Gr. 70	Head wall thickness(new):	0.4375 in.
Material Stress(S_v):	20000 PSI	Head wall thickness - thin out (corroded):	0.3750 in.

Nozzle Detail Information




Fig. UV-16.1 (c)

Upper Weld Leg Size(Weld 41): 0.3750 in.

Internal Weld Leg Size(Weld 43): 0.3750 in.

Nozzle Wall Thickness(t_n): 0.3440 in.

Outside Groove Weld Depth: 0.4375 in.

tangential to the vessel wall, attached by a groove weld.

Pipe Size: 2 Schedule: 160

Nozzle is adequate for UG-45 requirements.

Opening is adequately reinforced for Internal Pressure.

Reinforcement calculations are not required per UG-36(c)(3)(a) See Uw-14 for exceptions.

Weld Strength Paths are adequate.

PLATINUM ENERGY SERVICES ULC

2" 150# RFSO (N10A)

Job No: 30137 & 30138
 Number: 15
 ID Number: 15

Vessel Number: 01
 Mark Number: N10A

Date Printed: 2/12/2016

Required Head Thickness per Paragraph UG-37(a)

$$t_r = \frac{P L o M}{(2 S E + P * (M - 0.2))} = \frac{78.50 * 96.0000 * 1.0000}{(2 * 20000 * 1 + 78.50 * (1.0000 - 0.2))} = \mathbf{0.1881 \text{ in.}}$$

Nozzle Required Thickness Calculations**Required Nozzle Thickness for Internal Pressure per Paragraph UG-37(a)**

$$t_{rn} = \frac{P R n}{S E - 0.6 P} = \frac{78.50 * 0.9060}{17100 * 1 - 0.6 * 78.50} = \mathbf{0.0042 \text{ in.}}$$

Strength Reduction Factors

$$f_{r1} = \min \left\{ \frac{S_n}{S_v}, 1.0000 \right\} = \min \left\{ \frac{17100}{20000}, 1.0000 \right\} = 0.8550 \quad f_{r2} = \min \left\{ \frac{S_n}{S_v}, 1.0000 \right\} = \min \left\{ \frac{17100}{20000}, 1.0000 \right\} = 0.8550$$

UG-45 Thickness Calculations**Nozzle Thickness for Pressure Loading (plus corrosion)**

$$t_a = \frac{P R n}{S E - 0.6 P} + C_a + \text{ext. } C_a = \frac{78.50 * 0.9060}{17100 * 1.00 - 0.6 * 78.50} + 0.0625 + 0.0000 = \mathbf{0.0667 \text{ in.}}$$

Nozzle Thickness for Internal Pressure (plus corrosion) Based on Host

$$t_{b1} = \frac{P L o M}{(2 S E + P * (M - 0.2))} + C_a + \text{ext. } C_a = \frac{78.50 * 96.0000 * 1.7631}{(2 * 20000 * 1 + 78.50 * (1.7631 - 0.2))} + 0.0625 + 0.0000 = \mathbf{0.3937 \text{ in.}}$$

Minimum Thickness (plus corrosion) per Table UG-45

$$t_{b3} = \text{minimum thickness (Table UG-45) + } C_a + \text{ext. } C_a = \mathbf{0.1975 \text{ in.}}$$

Nozzle Minimum Thickness Based on Host and Table UG-45

$$t_b = \min[t_{b3}, \max(t_{b1}, t_{b2})] = \mathbf{0.1975 \text{ in.}}$$

$$t_{UG-45} = \max(t_a, t_b) = \mathbf{0.1975 \text{ in.}}$$

Wall thickness = $t_n * 0.875(\text{pipe}) = \mathbf{0.3010}$ is greater than or equal to UG-45 value of **0.1975**

PLATINUM ENERGY SERVICES ULC

2" 150# RFSO (N10B)

Job No: 30137 & 30138
 Number: 16
 ID Number: 16

Vessel Number: 01
 Mark Number: N10B

Date Printed: 2/12/2016

Nozzle Design Information

Design Pressure:	75.00 PSI	Design Temperature:	350 °F
Static Head:	3.50 PSI	Nozzle Efficiency (E):	100 %
Nozzle Material:	SA-106 Gr. B	Joint Efficiency (E ₁):	1.00
		Factor B Chart:	CS-2
External Projection:	6.0000 in.	Allowable Stress at Design Temperature (S):	17100 PSI
Internal Projection:	12.0000 in.	Allowable Stress at Ambient Temperature:	17100 PSI
Inside Corrosion Allowance:	0.0625 in.	Correction Factor (F):	1.00
External Corrosion Allowance:	0.0000 in.	Nozzle Path:	None
Nozzle Pipe Size:	2	Nozzle Pipe Schedule:	160
Nozzle ID (new):	1.6870 in.	Nozzle Wall Thickness(new):	0.3440 in.
Nozzle ID (corroded):	1.8120 in.	Nozzle Wall Thickness(corroded):	0.2815 in.
Developed Opening:	2.3750 in.	Tangential Dimension L:	8.0000 in.
External Limit of Reinforcement:	0.7038 in.	Upper Weld Leg Size(Weld 41):	0.3750 in.
Internal Limit of Reinforcement:	0.5475 in.	Internal Weld Leg Size(Weld 43):	0.3750 in.
Parallel Limit of Reinf (2Lpar):	5.0000 in.	Outside Groove Weld Depth:	0.5000 in.

Minimum Design Metal Temperature

Min. Temp. Curve: B	Pressure at MDMT:	75.00 PSI
UCS-66(b) reduction: Yes	Minimum Design Metal Temperature:	-20 °F
UCS-68(c) reduction: No	Computed Minimum Temperature:	-155 °F

Host Component: Head 2 - 8'-0" OD FLANGED & DISHED HEAD C/W 1.5" SF (LEFT SIDE)

Material: SA-516 Gr. 70	Head wall thickness(new):	0.5000 in.
Material Stress(S _v): 20000 PSI	Head wall thickness - thin out (corroded):	0.4375 in.


Nozzle Detail Information

Fig. UW-16.1 (c)

Upper Weld Leg Size(Weld 41): 0.3750 in.

Internal Weld Leg Size(Weld 43): 0.3750 in.

Nozzle Wall Thickness(t_n): 0.3440 in.

Outside Groove Weld Depth: 0.5000 in.

tangential to the vessel wall, attached by a groove weld.

Pipe Size: 2 Schedule: 160

Nozzle is adequate for UG-45 requirements.

Opening is adequately reinforced for Internal Pressure.

Reinforcement calculations are not required per UG-36(c)(3)(a) See Uw-14 for exceptions.

Weld Strength Paths are adequate.

PLATINUM ENERGY SERVICES ULC

2" 150# RFSO (N10B)

Job No: 30137 & 30138
 Number: 16
 ID Number: 16

Vessel Number: 01
 Mark Number: N10B

Date Printed: 2/12/2016

Required Head Thickness per Paragraph UG-37(a)

$$t_r = \frac{P L o M}{(2 S E + P * (M - 0.2))} = \frac{78.50 * 96.0000 * 1.7628}{(2 * 20000 * 1 + 78.50 * (1.7628 - 0.2))} = \mathbf{0.3311 \text{ in.}}$$

Nozzle Required Thickness Calculations**Required Nozzle Thickness for Internal Pressure per Paragraph UG-37(a)**

$$t_{rn} = \frac{P R n}{S E - 0.6 P} = \frac{78.50 * 0.9060}{17100 * 1 - 0.6 * 78.50} = \mathbf{0.0042 \text{ in.}}$$

Strength Reduction Factors

$$f r 1 = \min \left[\frac{S_n}{S_v}, 1.0000 \right] = \min \left[\frac{17100}{20000}, 1.0000 \right] = 0.8550 \quad f r 2 = \min \left[\frac{S_n}{S_v}, 1.0000 \right] = \min \left[\frac{17100}{20000}, 1.0000 \right] = 0.8550$$

UG-45 Thickness Calculations**Nozzle Thickness for Pressure Loading (plus corrosion)**

$$t_a = \frac{P R n}{S E - 0.6 P} + C a + \text{ext. Ca} = \frac{78.50 * 0.9060}{17100 * 1.00 - 0.6 * 78.50} + 0.0625 + 0.0000 = \mathbf{0.0667 \text{ in.}}$$

Nozzle Thickness for Internal Pressure (plus corrosion) Based on Host

$$t_{b1} = \frac{P L o M}{(2 S E + P * (M - 0.2))} + C a + \text{ext. Ca} = \frac{78.50 * 96.0000 * 1.7628}{(2 * 20000 * 1 + 78.50 * (1.7628 - 0.2))} + 0.0625 + 0.0000 = \mathbf{0.3936 \text{ in.}}$$

Minimum Thickness (plus corrosion) per Table UG-45

$$t_{b3} = \text{minimum thickness (Table UG-45) + Ca + ext. Ca} = \mathbf{0.1975 \text{ in.}}$$

Nozzle Minimum Thickness Based on Host and Table UG-45

$$t_b = \min[t_{b3}, \max(t_{b1}, t_{b2})] = \mathbf{0.1975 \text{ in.}}$$

$$t_{UG-45} = \max(t_a, t_b) = \mathbf{0.1975 \text{ in.}}$$

Wall thickness = $t_n * 0.875(\text{pipe}) = \mathbf{0.3010}$ is greater than or equal to UG-45 value of **0.1975**

PLATINUM ENERGY SERVICES ULC

1" 150# RFSO (N11A)

Job No: 30137 & 30138
 Number: 17
 ID Number: 17

Vessel Number: 01
 Mark Number: N11A

Date Printed: 2/12/2016

Nozzle Design Information

Design Pressure:	75.00 PSI	Design Temperature:	350 °F
Static Head:	3.50 PSI	Nozzle Efficiency (E):	100 %
Nozzle Material:	SA-106 Gr. B	Joint Efficiency (E ₁):	1.00
		Factor B Chart:	CS-2
External Projection:	6.0000 in.	Allowable Stress at Design Temperature (S):	17100 PSI
Internal Projection:	0.0000 in.	Allowable Stress at Ambient Temperature:	17100 PSI
Inside Corrosion Allowance:	0.0625 in.	Correction Factor (F):	1.00
External Corrosion Allowance:	0.0000 in.	Nozzle Path:	None
Nozzle Pipe Size:	1	Nozzle Pipe Schedule:	160
Nozzle ID (new):	0.8150 in.	Nozzle Wall Thickness(new):	0.2500 in.
Nozzle ID (corroded):	0.9400 in.	Nozzle Wall Thickness(corroded):	0.1875 in.
Developed Opening:	0.8252 in.	Tangential Dimension L:	15.0000 in.
External Limit of Reinforcement:	0.4688 in.	Upper Weld Leg Size(Weld 41):	0.3750 in.
Internal Limit of Reinforcement:	0.3125 in.	Internal Weld Leg Size(Weld 43):	0.0000 in.
Parallel Limit of Reinf (2Lpar):	2.0650 in.	Outside Groove Weld Depth:	0.4375 in.

Minimum Design Metal Temperature

Min. Temp. Curve: B	Pressure at MDMT:	75.00 PSI
UCS-66(b) reduction: Yes	Minimum Design Metal Temperature:	-20 °F
UCS-68(c) reduction: No	Computed Minimum Temperature:	-155 °F

Host Component: Head 1 - 96" OD FLANGED & DISHED HEAD C/W 1.5" SF (RIGHT SIDE)

Material: SA-516 Gr. 70	Head wall thickness(new):	0.4375 in.
Material Stress(S _y): 20000 PSI	Head wall thickness - thin out (corroded):	0.3750 in.


Nozzle Detail Information

Fig. UW-16.1 (c)

Upper Weld Leg Size(Weld 41): 0.3750 in.

Nozzle Wall Thickness(t_n): 0.2500 in.

Outside Groove Weld Depth: 0.4375 in.

tangential to the vessel wall, attached by a groove weld.

Pipe Size: 1 Schedule: 160

Nozzle is adequate for UG-45 requirements.

Opening is adequately reinforced for Internal Pressure.

Reinforcement calculations are not required per UG-36(c)(3)(a) See Uw-14 for exceptions.

Weld Strength Paths are adequate.

PLATINUM ENERGY SERVICES ULC

1" 150# RFSO (N11A)

Job No: 30137 & 30138
 Number: 17
 ID Number: 17

Vessel Number: 01
 Mark Number: N11A

Date Printed: 2/12/2016

Required Head Thickness per Paragraph UG-37(a)

$$t_r = \frac{P L o M}{(2 S E + P * (M - 0.2))} = \frac{78.50 * 96.0000 * 1.0000}{(2 * 20000 * 1 + 78.50 * (1.0000 - 0.2))} = \mathbf{0.1881 \text{ in.}}$$

Nozzle Required Thickness Calculations**Required Nozzle Thickness for Internal Pressure per Paragraph UG-37(a)**

$$t_{rn} = \frac{P R n}{S E - 0.6 P} = \frac{78.50 * 0.4700}{17100 * 1 - 0.6 * 78.50} = \mathbf{0.0022 \text{ in.}}$$

Strength Reduction Factors

$$f r 1 = \min \left\{ \frac{S_n}{S_v}, 1.0000 \right\} = \min \left\{ \frac{17100}{20000}, 1.0000 \right\} = 0.8550 \quad f r 2 = \min \left\{ \frac{S_n}{S_v}, 1.0000 \right\} = \min \left\{ \frac{17100}{20000}, 1.0000 \right\} = 0.8550$$

UG-45 Thickness Calculations**Nozzle Thickness for Pressure Loading (plus corrosion)**

$$t_a = \frac{P R n}{S E - 0.6 P} + C a + \text{ext. Ca} = \frac{78.50 * 0.4700}{17100 * 1.00 - 0.6 * 78.50} + 0.0625 + 0.0000 = \mathbf{0.0647 \text{ in.}}$$

Nozzle Thickness for Internal Pressure (plus corrosion) Based on Host

$$t_{b1} = \frac{P L o M}{(2 S E + P * (M - 0.2))} + C a + \text{ext. Ca} = \frac{78.50 * 96.0000 * 1.7631}{(2 * 20000 * 1 + 78.50 * (1.7631 - 0.2))} + 0.0625 + 0.0000 = \mathbf{0.3937 \text{ in.}}$$

Minimum Thickness (plus corrosion) per Table UG-45

$$t_{b3} = \text{minimum thickness (Table UG-45) + Ca + ext. Ca} = \mathbf{0.1785 \text{ in.}}$$

Nozzle Minimum Thickness Based on Host and Table UG-45

$$t_b = \min[t_{b3}, \max(t_{b1}, t_{b2})] = \mathbf{0.1785 \text{ in.}}$$

$$t_{UG-45} = \max(t_a, t_b) = \mathbf{0.1785 \text{ in.}}$$

Wall thickness = $t_n * 0.875(\text{pipe}) = \mathbf{0.2190}$ is greater than or equal to UG-45 value of **0.1785**

PLATINUM ENERGY SERVICES ULC

1" 150# RFSO (N11B)

Job No: 30137 & 30138
 Number: 18
 ID Number: 18

Vessel Number: 01
 Mark Number: N11B

Date Printed: 2/12/2016

Nozzle Design Information

Design Pressure:	75.00 PSI	Design Temperature:	350 °F
Static Head:	3.50 PSI	Nozzle Efficiency (E):	100 %
Nozzle Material:	SA-106 Gr. B	Joint Efficiency (E ₁):	1.00
		Factor B Chart:	CS-2
External Projection:	6.0000 in.	Allowable Stress at Design Temperature (S):	17100 PSI
Internal Projection:	0.0000 in.	Allowable Stress at Ambient Temperature:	17100 PSI
Inside Corrosion Allowance:	0.0625 in.	Correction Factor (F):	1.00
External Corrosion Allowance:	0.0000 in.	Nozzle Path:	None
Nozzle Pipe Size:	1	Nozzle Pipe Schedule:	160
Nozzle ID (new):	0.8150 in.	Nozzle Wall Thickness(new):	0.2500 in.
Nozzle ID (corroded):	0.9400 in.	Nozzle Wall Thickness(corroded):	0.1875 in.
Developed Opening:	0.8252 in.	Tangential Dimension L:	15.0000 in.
External Limit of Reinforcement:	0.4688 in.	Upper Weld Leg Size(Weld 41):	0.3750 in.
Internal Limit of Reinforcement:	0.3125 in.	Internal Weld Leg Size(Weld 43):	0.0000 in.
Parallel Limit of Reinf (2Lpar):	2.0650 in.	Outside Groove Weld Depth:	0.4375 in.

Minimum Design Metal Temperature

Min. Temp. Curve: B	Pressure at MDMT:	75.00 PSI
UCS-66(b) reduction: Yes	Minimum Design Metal Temperature:	-20 °F
UCS-68(c) reduction: No	Computed Minimum Temperature:	-155 °F

Host Component: Head 1 - 96" OD FLANGED & DISHED HEAD C/W 1.5" SF (RIGHT SIDE)

Material: SA-516 Gr. 70	Head wall thickness(new):	0.4375 in.
Material Stress(S _y): 20000 PSI	Head wall thickness - thin out (corroded):	0.3750 in.


Nozzle Detail Information

Fig. UW-16.1 (c)

Upper Weld Leg Size(Weld 41): 0.3750 in.

Nozzle Wall Thickness(t_n): 0.2500 in.

Outside Groove Weld Depth: 0.4375 in.

tangential to the vessel wall, attached by a groove weld.

Pipe Size: 1 Schedule: 160

Nozzle is adequate for UG-45 requirements.

Opening is adequately reinforced for Internal Pressure.

Reinforcement calculations are not required per UG-36(c)(3)(a) See Uw-14 for exceptions.

Weld Strength Paths are adequate.

PLATINUM ENERGY SERVICES ULC

1" 150# RFSO (N11B)

Job No: 30137 & 30138
 Number: 18
 ID Number: 18

Vessel Number: 01
 Mark Number: N11B

Date Printed: 2/12/2016

Required Head Thickness per Paragraph UG-37(a)

$$t_r = \frac{P L o M}{(2 S E + P * (M - 0.2))} = \frac{78.50 * 96.0000 * 1.0000}{(2 * 20000 * 1 + 78.50 * (1.0000 - 0.2))} = \mathbf{0.1881 \text{ in.}}$$

Nozzle Required Thickness Calculations**Required Nozzle Thickness for Internal Pressure per Paragraph UG-37(a)**

$$t_{rn} = \frac{P R n}{S E - 0.6 P} = \frac{78.50 * 0.4700}{17100 * 1 - 0.6 * 78.50} = \mathbf{0.0022 \text{ in.}}$$

Strength Reduction Factors

$$f r 1 = \min \left\{ \frac{S_n}{S_v}, 1.0000 \right\} = \min \left\{ \frac{17100}{20000}, 1.0000 \right\} = 0.8550 \quad f r 2 = \min \left\{ \frac{S_n}{S_v}, 1.0000 \right\} = \min \left\{ \frac{17100}{20000}, 1.0000 \right\} = 0.8550$$

UG-45 Thickness Calculations**Nozzle Thickness for Pressure Loading (plus corrosion)**

$$t_a = \frac{P R n}{S E - 0.6 P} + C a + \text{ext. Ca} = \frac{78.50 * 0.4700}{17100 * 1.00 - 0.6 * 78.50} + 0.0625 + 0.0000 = \mathbf{0.0647 \text{ in.}}$$

Nozzle Thickness for Internal Pressure (plus corrosion) Based on Host

$$t_{b1} = \frac{P L o M}{(2 S E + P * (M - 0.2))} + C a + \text{ext. Ca} = \frac{78.50 * 96.0000 * 1.7631}{(2 * 20000 * 1 + 78.50 * (1.7631 - 0.2))} + 0.0625 + 0.0000 = \mathbf{0.3937 \text{ in.}}$$

Minimum Thickness (plus corrosion) per Table UG-45

$$t_{b3} = \text{minimum thickness (Table UG-45) + Ca + ext. Ca} = \mathbf{0.1785 \text{ in.}}$$

Nozzle Minimum Thickness Based on Host and Table UG-45

$$t_b = \min[t_{b3}, \max(t_{b1}, t_{b2})] = \mathbf{0.1785 \text{ in.}}$$

$$t_{UG-45} = \max(t_a, t_b) = \mathbf{0.1785 \text{ in.}}$$

Wall thickness = $t_n * 0.875(\text{pipe}) = \mathbf{0.2190}$ is greater than or equal to UG-45 value of **0.1785**

PLATINUM ENERGY SERVICES ULC

1" 150# RFSO (N11C)

Job No: 30137 & 30138
 Number: 19
 ID Number: 19

Vessel Number: 01
 Mark Number: N11C

Date Printed: 2/12/2016

Nozzle Design Information

Design Pressure:	75.00 PSI	Design Temperature:	350 °F
Static Head:	3.50 PSI	Nozzle Efficiency (E):	100 %
Nozzle Material:	SA-106 Gr. B	Joint Efficiency (E ₁):	1.00
		Factor B Chart:	CS-2
External Projection:	6.0000 in.	Allowable Stress at Design Temperature (S):	17100 PSI
Internal Projection:	0.0000 in.	Allowable Stress at Ambient Temperature:	17100 PSI
Inside Corrosion Allowance:	0.0625 in.	Correction Factor (F):	1.00
External Corrosion Allowance:	0.0000 in.	Nozzle Path:	None
Nozzle Pipe Size:	1	Nozzle Pipe Schedule:	160
Nozzle ID (new):	0.8150 in.	Nozzle Wall Thickness(new):	0.2500 in.
Nozzle ID (corroded):	0.9400 in.	Nozzle Wall Thickness(corroded):	0.1875 in.
Developed Opening:	0.8252 in.	Tangential Dimension L:	15.0000 in.
External Limit of Reinforcement:	0.4688 in.	Upper Weld Leg Size(Weld 41):	0.3750 in.
Internal Limit of Reinforcement:	0.3125 in.	Internal Weld Leg Size(Weld 43):	0.0000 in.
Parallel Limit of Reinf (2Lpar):	2.0650 in.	Outside Groove Weld Depth:	0.4375 in.

Minimum Design Metal Temperature

Min. Temp. Curve: B
 UCS-66(b) reduction: Yes
 UCS-68(c) reduction: No

Pressure at MDMT: 75.00 PSI
 Minimum Design Metal Temperature: -20 °F
 Computed Minimum Temperature: -155 °F

Host Component: Head 1 - 96" OD FLANGED & DISHED HEAD C/W 1.5" SF (RIGHT SIDE)

Material: SA-516 Gr. 70
 Material Stress(S_y): 20000 PSI
 Head wall thickness(new): 0.4375 in.
 Head wall thickness - thin out (corroded): 0.3750 in.


Nozzle Detail Information

Fig. UW-16.1 (c)

Upper Weld Leg Size(Weld 41): 0.3750 in.

Nozzle Wall Thickness(t_n): 0.2500 in.

Outside Groove Weld Depth: 0.4375 in.

tangential to the vessel wall, attached by a groove weld.

Pipe Size: 1 Schedule: 160

Nozzle is adequate for UG-45 requirements.

Opening is adequately reinforced for Internal Pressure.

Reinforcement calculations are not required per UG-36(c)(3)(a) See Uw-14 for exceptions.

Weld Strength Paths are adequate.

PLATINUM ENERGY SERVICES ULC

1" 150# RFSO (N11C)

Job No: 30137 & 30138
 Number: 19
 ID Number: 19

Vessel Number: 01
 Mark Number: N11C

Date Printed: 2/12/2016

Required Head Thickness per Paragraph UG-37(a)

$$t_r = \frac{P L o M}{(2 S E + P * (M - 0.2))} = \frac{78.50 * 96.0000 * 1.0000}{(2 * 20000 * 1 + 78.50 * (1.0000 - 0.2))} = \mathbf{0.1881 \text{ in.}}$$

Nozzle Required Thickness Calculations**Required Nozzle Thickness for Internal Pressure per Paragraph UG-37(a)**

$$t_{rn} = \frac{P R n}{S E - 0.6 P} = \frac{78.50 * 0.4700}{17100 * 1 - 0.6 * 78.50} = \mathbf{0.0022 \text{ in.}}$$

Strength Reduction Factors

$$f r 1 = \min \left\{ \frac{S_n}{S_v}, 1.0000 \right\} = \min \left\{ \frac{17100}{20000}, 1.0000 \right\} = 0.8550 \quad f r 2 = \min \left\{ \frac{S_n}{S_v}, 1.0000 \right\} = \min \left\{ \frac{17100}{20000}, 1.0000 \right\} = 0.8550$$

UG-45 Thickness Calculations**Nozzle Thickness for Pressure Loading (plus corrosion)**

$$t_a = \frac{P R n}{S E - 0.6 P} + C a + \text{ext. Ca} = \frac{78.50 * 0.4700}{17100 * 1.00 - 0.6 * 78.50} + 0.0625 + 0.0000 = \mathbf{0.0647 \text{ in.}}$$

Nozzle Thickness for Internal Pressure (plus corrosion) Based on Host

$$t_{b1} = \frac{P L o M}{(2 S E + P * (M - 0.2))} + C a + \text{ext. Ca} = \frac{78.50 * 96.0000 * 1.7631}{(2 * 20000 * 1 + 78.50 * (1.7631 - 0.2))} + 0.0625 + 0.0000 = \mathbf{0.3937 \text{ in.}}$$

Minimum Thickness (plus corrosion) per Table UG-45

$$t_{b3} = \text{minimum thickness (Table UG-45) + Ca + ext. Ca} = \mathbf{0.1785 \text{ in.}}$$

Nozzle Minimum Thickness Based on Host and Table UG-45

$$t_b = \min[t_{b3}, \max(t_{b1}, t_{b2})] = \mathbf{0.1785 \text{ in.}}$$

$$t_{UG-45} = \max(t_a, t_b) = \mathbf{0.1785 \text{ in.}}$$

Wall thickness = $t_n * 0.875(\text{pipe}) = \mathbf{0.2190}$ is greater than or equal to UG-45 value of **0.1785**

PLATINUM ENERGY SERVICES ULC

1" 150# RFSO (N11D)

Job No: 30137 & 30138
 Number: 20
 ID Number: 20

Vessel Number: 01
 Mark Number: N11D

Date Printed: 2/12/2016

Nozzle Design Information

Design Pressure:	75.00 PSI	Design Temperature:	350 °F
Static Head:	3.50 PSI	Nozzle Efficiency (E):	100 %
Nozzle Material:	SA-106 Gr. B	Joint Efficiency (E ₁):	1.00
		Factor B Chart:	CS-2
External Projection:	6.0000 in.	Allowable Stress at Design Temperature (S):	17100 PSI
Internal Projection:	0.0000 in.	Allowable Stress at Ambient Temperature:	17100 PSI
Inside Corrosion Allowance:	0.0625 in.	Correction Factor (F):	1.00
External Corrosion Allowance:	0.0000 in.	Nozzle Path:	None
Nozzle Pipe Size:	1	Nozzle Pipe Schedule:	160
Nozzle ID (new):	0.8150 in.	Nozzle Wall Thickness(new):	0.2500 in.
Nozzle ID (corroded):	0.9400 in.	Nozzle Wall Thickness(corroded):	0.1875 in.
Developed Opening:	0.8252 in.	Tangential Dimension L:	15.0000 in.
External Limit of Reinforcement:	0.4688 in.	Upper Weld Leg Size(Weld 41):	0.3750 in.
Internal Limit of Reinforcement:	0.3125 in.	Internal Weld Leg Size(Weld 43):	0.0000 in.
Parallel Limit of Reinf (2Lpar):	2.0650 in.	Outside Groove Weld Depth:	0.4375 in.

Minimum Design Metal Temperature

Min. Temp. Curve: B	Pressure at MDMT:	75.00 PSI
UCS-66(b) reduction: Yes	Minimum Design Metal Temperature:	-20 °F
UCS-68(c) reduction: No	Computed Minimum Temperature:	-155 °F

Host Component: Head 1 - 96" OD FLANGED & DISHED HEAD C/W 1.5" SF (RIGHT SIDE)

Material: SA-516 Gr. 70	Head wall thickness(new):	0.4375 in.
Material Stress(S _y): 20000 PSI	Head wall thickness - thin out (corroded):	0.3750 in.


Nozzle Detail Information

Fig. UW-16.1 (c)

Upper Weld Leg Size(Weld 41): 0.3750 in.

Nozzle Wall Thickness(t_n): 0.2500 in.

Outside Groove Weld Depth: 0.4375 in.

tangential to the vessel wall, attached by a groove weld.

Pipe Size: 1 Schedule: 160

Nozzle is adequate for UG-45 requirements.

Opening is adequately reinforced for Internal Pressure.

Reinforcement calculations are not required per UG-36(c)(3)(a) See Uw-14 for exceptions.

Weld Strength Paths are adequate.

PLATINUM ENERGY SERVICES ULC

1" 150# RFSO (N11D)

Job No: 30137 & 30138
 Number: 20
 ID Number: 20

Vessel Number: 01
 Mark Number: N11D

Date Printed: 2/12/2016

Required Head Thickness per Paragraph UG-37(a)

$$t_r = \frac{P L o M}{(2 S E + P * (M - 0.2))} = \frac{78.50 * 96.0000 * 1.7631}{(2 * 20000 * 1 + 78.50 * (1.7631 - 0.2))} = \mathbf{0.3312 \text{ in.}}$$

Nozzle Required Thickness Calculations**Required Nozzle Thickness for Internal Pressure per Paragraph UG-37(a)**

$$t_{rn} = \frac{P R n}{S E - 0.6 P} = \frac{78.50 * 0.4700}{17100 * 1 - 0.6 * 78.50} = \mathbf{0.0022 \text{ in.}}$$

Strength Reduction Factors

$$f r 1 = \min \left\{ \frac{S_n}{S_v}, 1.0000 \right\} = \min \left\{ \frac{17100}{20000}, 1.0000 \right\} = 0.8550 \quad f r 2 = \min \left\{ \frac{S_n}{S_v}, 1.0000 \right\} = \min \left\{ \frac{17100}{20000}, 1.0000 \right\} = 0.8550$$

UG-45 Thickness Calculations**Nozzle Thickness for Pressure Loading (plus corrosion)**

$$t_a = \frac{P R n}{S E - 0.6 P} + C a + \text{ext. } C a = \frac{78.50 * 0.4700}{17100 * 1.00 - 0.6 * 78.50} + 0.0625 + 0.0000 = \mathbf{0.0647 \text{ in.}}$$

Nozzle Thickness for Internal Pressure (plus corrosion) Based on Host

$$t_{b1} = \frac{P L o M}{(2 S E + P * (M - 0.2))} + C a + \text{ext. } C a = \frac{78.50 * 96.0000 * 1.7631}{(2 * 20000 * 1 + 78.50 * (1.7631 - 0.2))} + 0.0625 + 0.0000 = \mathbf{0.3937 \text{ in.}}$$

Minimum Thickness (plus corrosion) per Table UG-45

$$t_{b3} = \text{minimum thickness (Table UG-45) + } C a + \text{ext. } C a = \mathbf{0.1785 \text{ in.}}$$

Nozzle Minimum Thickness Based on Host and Table UG-45

$$t_b = \min[t_{b3}, \max(t_{b1}, t_{b2})] = \mathbf{0.1785 \text{ in.}}$$

$$t_{UG-45} = \max(t_a, t_b) = \mathbf{0.1785 \text{ in.}}$$

Wall thickness = $t_n * 0.875(\text{pipe}) = \mathbf{0.2190}$ is greater than or equal to UG-45 value of **0.1785**

PLATINUM ENERGY SERVICES ULC

1" 150# RFSO (N12)

Job No: 30137 & 30138
 Number: 21
 ID Number: 21

Vessel Number: 01
 Mark Number: N12

Date Printed: 2/12/2016

Nozzle Design Information

Design Pressure:	75.00 PSI	Design Temperature:	350 °F
Static Head:	3.50 PSI	Nozzle Efficiency (E):	100 %
Nozzle Material:	SA-106 Gr. B	Joint Efficiency (E ₁):	1.00
		Factor B Chart:	CS-2
External Projection:	6.0000 in.	Allowable Stress at Design Temperature (S):	17100 PSI
Internal Projection:	0.0000 in.	Allowable Stress at Ambient Temperature:	17100 PSI
Inside Corrosion Allowance:	0.0625 in.	Correction Factor (F):	1.00
External Corrosion Allowance:	0.0000 in.	Nozzle Path:	None
Nozzle Pipe Size:	1	Nozzle Pipe Schedule:	160
Nozzle ID (new):	0.8150 in.	Nozzle Wall Thickness(new):	0.2500 in.
Nozzle ID (corroded):	0.9400 in.	Nozzle Wall Thickness(corroded):	0.1875 in.
Developed Opening:	0.8260 in.	Tangential Dimension L:	16.0000 in.
External Limit of Reinforcement:	0.4688 in.	Upper Weld Leg Size(Weld 41):	0.3750 in.
Internal Limit of Reinforcement:	0.3125 in.	Internal Weld Leg Size(Weld 43):	0.0000 in.
Parallel Limit of Reinf (2Lpar):	2.0650 in.	Outside Groove Weld Depth:	0.4375 in.

Minimum Design Metal Temperature

Min. Temp. Curve: B	Pressure at MDMT:	75.00 PSI
UCS-66(b) reduction: Yes	Minimum Design Metal Temperature:	-20 °F
UCS-68(c) reduction: No	Computed Minimum Temperature:	-155 °F

Host Component: Head 1 - 96" OD FLANGED & DISHED HEAD C/W 1.5" SF (RIGHT SIDE)

Material: SA-516 Gr. 70	Head wall thickness(new):	0.4375 in.
Material Stress(S _y): 20000 PSI	Head wall thickness - thin out (corroded):	0.3750 in.


Nozzle Detail Information

Fig. UW-16.1 (c)

Upper Weld Leg Size(Weld 41): 0.3750 in.

Nozzle Wall Thickness(t_n): 0.2500 in.

Outside Groove Weld Depth: 0.4375 in.

tangential to the vessel wall, attached by a groove weld.

Pipe Size: 1 Schedule: 160

Nozzle is adequate for UG-45 requirements.

Opening is adequately reinforced for Internal Pressure.

Reinforcement calculations are not required per UG-36(c)(3)(a) See Uw-14 for exceptions.

Weld Strength Paths are adequate.

PLATINUM ENERGY SERVICES ULC

1" 150# RFSO (N12)

Job No: 30137 & 30138
 Number: 21
 ID Number: 21

Vessel Number: 01
 Mark Number: N12

Date Printed: 2/12/2016

Required Head Thickness per Paragraph UG-37(a)

$$t_r = \frac{P L o M}{(2 S E + P * (M - 0.2))} = \frac{78.50 * 96.0000 * 1.7631}{(2 * 20000 * 1 + 78.50 * (1.7631 - 0.2))} = \mathbf{0.3312 \text{ in.}}$$

Nozzle Required Thickness Calculations**Required Nozzle Thickness for Internal Pressure per Paragraph UG-37(a)**

$$t_{rn} = \frac{P R n}{S E - 0.6 P} = \frac{78.50 * 0.4700}{17100 * 1 - 0.6 * 78.50} = \mathbf{0.0022 \text{ in.}}$$

Strength Reduction Factors

$$f r 1 = \min \left\{ \frac{S_n}{S_v}, 1.0000 \right\} = \min \left\{ \frac{17100}{20000}, 1.0000 \right\} = 0.8550 \quad f r 2 = \min \left\{ \frac{S_n}{S_v}, 1.0000 \right\} = \min \left\{ \frac{17100}{20000}, 1.0000 \right\} = 0.8550$$

UG-45 Thickness Calculations**Nozzle Thickness for Pressure Loading (plus corrosion)**

$$t_a = \frac{P R n}{S E - 0.6 P} + C a + \text{ext. } C a = \frac{78.50 * 0.4700}{17100 * 1.00 - 0.6 * 78.50} + 0.0625 + 0.0000 = \mathbf{0.0647 \text{ in.}}$$

Nozzle Thickness for Internal Pressure (plus corrosion) Based on Host

$$t_{b1} = \frac{P L o M}{(2 S E + P * (M - 0.2))} + C a + \text{ext. } C a = \frac{78.50 * 96.0000 * 1.7631}{(2 * 20000 * 1 + 78.50 * (1.7631 - 0.2))} + 0.0625 + 0.0000 = \mathbf{0.3937 \text{ in.}}$$

Minimum Thickness (plus corrosion) per Table UG-45

$$t_{b3} = \text{minimum thickness (Table UG-45) + } C a + \text{ext. } C a = \mathbf{0.1785 \text{ in.}}$$

Nozzle Minimum Thickness Based on Host and Table UG-45

$$t_b = \min[t_{b3}, \max(t_{b1}, t_{b2})] = \mathbf{0.1785 \text{ in.}}$$

$$t_{UG-45} = \max(t_a, t_b) = \mathbf{0.1785 \text{ in.}}$$

Wall thickness = $t_n * 0.875(\text{pipe}) = \mathbf{0.2190}$ is greater than or equal to UG-45 value of **0.1785**

PLATINUM ENERGY SERVICES ULC

1" 150# RFSO (N13)

Job No: 30137 & 30138
 Number: 22
 ID Number: 22

Vessel Number: 01
 Mark Number: N13

Date Printed: 2/12/2016

Nozzle Design Information

Design Pressure:	75.00 PSI	Design Temperature:	350 °F
Static Head:	3.50 PSI	Nozzle Efficiency (E):	100 %
Nozzle Material:	SA-106 Gr. B	Joint Efficiency (E ₁):	1.00
		Factor B Chart:	CS-2
External Projection:	6.0000 in.	Allowable Stress at Design Temperature (S):	17100 PSI
Internal Projection:	0.0000 in.	Allowable Stress at Ambient Temperature:	17100 PSI
Inside Corrosion Allowance:	0.0625 in.	Correction Factor (F):	1.00
External Corrosion Allowance:	0.0000 in.	Nozzle Path:	None
Nozzle Pipe Size:	1	Nozzle Pipe Schedule:	160
Nozzle ID (new):	0.8150 in.	Nozzle Wall Thickness(new):	0.2500 in.
Nozzle ID (corroded):	0.9400 in.	Nozzle Wall Thickness(corroded):	0.1875 in.
Developed Opening:	0.8497 in.	Tangential Dimension L:	13.5000 in.
External Limit of Reinforcement:	0.4688 in.	Upper Weld Leg Size(Weld 41):	0.3750 in.
Internal Limit of Reinforcement:	0.3125 in.	Internal Weld Leg Size(Weld 43):	0.0000 in.
Parallel Limit of Reinf (2Lpar):	1.9598 in.	Outside Groove Weld Depth:	0.3750 in.

Minimum Design Metal Temperature

Min. Temp. Curve: B	Pressure at MDMT:	75.00 PSI
UCS-66(b) reduction: Yes	Minimum Design Metal Temperature:	-20 °F
UCS-68(c) reduction: No	Computed Minimum Temperature:	-155 °F

Host Component: Shell 1 - 8'-0" OD x 30'-0" LONG SHELL

Material:	SA-516 Gr. 70	Shell wall thickness(new):	0.3750 in.
Material Stress(S _y):	20000 PSI	Shell wall thickness(corroded):	0.3125 in.


Nozzle Detail Information

Fig. UW-16.1 (c)

Upper Weld Leg Size(Weld 41): 0.3750 in.

Nozzle Wall Thickness(t_n): 0.2500 in.

Outside Groove Weld Depth: 0.3750 in.

tangential to the vessel wall, attached by a groove weld.

Pipe Size: 1 Schedule: 160

Nozzle is adequate for UG-45 requirements.

Opening is adequately reinforced for Internal Pressure.

Reinforcement calculations are not required per UG-36(c)(3)(a) See Uw-14 for exceptions.

Weld Strength Paths are adequate.

PLATINUM ENERGY SERVICES ULC

1" 150# RFSO (N13)

Job No: 30137 & 30138
 Number: 22
 ID Number: 22

Vessel Number: 01
 Mark Number: N13

Date Printed: 2/12/2016

Required Shell Thickness per Paragraph UG-37(a)

$$t_r = \frac{P R_o}{S E + 0.4 P} = \frac{78.50 * 48.0000}{20000 * 1 + 0.4 * 78.50} = \mathbf{0.1881 \text{ in.}}$$

Nozzle Required Thickness Calculations**Required Nozzle Thickness for Internal Pressure per Paragraph UG-37(a)**

$$t_{rn} = \frac{P R_n}{S E - 0.6 P} = \frac{78.50 * 0.4700}{17100 * 1 - 0.6 * 78.50} = \mathbf{0.0022 \text{ in.}}$$

Strength Reduction Factors

$$f_{r1} = \min \left[\frac{S_n}{S_v}, 1.0000 \right] = \min \left[\frac{17100}{20000}, 1.0000 \right] = 0.8550 \quad f_{r2} = \min \left[\frac{S_n}{S_v}, 1.0000 \right] = \min \left[\frac{17100}{20000}, 1.0000 \right] = 0.8550$$

UG-45 Thickness Calculations**Nozzle Thickness for Pressure Loading (plus corrosion)**

$$t_a = \frac{P R_n}{S E - 0.6 P} + C_a + \text{ext. Ca} = \frac{78.50 * 0.4700}{17100 * 1.00 - 0.6 * 78.50} + 0.0625 + 0.0000 = \mathbf{0.0647 \text{ in.}}$$

Nozzle Thickness for Internal Pressure (plus corrosion) Based on Host

$$t_{b1} = \frac{P R_o}{S E + 0.4 P} + C_a + \text{ext. Ca} = \frac{78.50 * 48.0000}{20000 * 1 + 0.4 * 78.50} + 0.0625 + 0.0000 = \mathbf{0.2506 \text{ in.}}$$

Minimum Thickness (plus corrosion) per Table UG-45

$$t_{b3} = \text{minimum thickness (Table UG-45) + } C_a + \text{ext. Ca} = \mathbf{0.1785 \text{ in.}}$$

Nozzle Minimum Thickness Based on Host and Table UG-45

$$t_b = \min[t_{b3}, \max(t_{b1}, t_{b2})] = \mathbf{0.1785 \text{ in.}}$$

$$t_{UG-45} = \max(t_a, t_b) = \mathbf{0.1785 \text{ in.}}$$

Wall thickness = $t_n * 0.875(\text{pipe}) = \mathbf{0.2190}$ is greater than or equal to UG-45 value of **0.1785**

1" 150# RF SO (N14)

Vessel Number:01
Mark Number: N14

Date Printed: 2/12/2016

External Projection:	6.0000	in.	Allowable Stress at Design Temperature (\$):	17100	PSI
Internal Projection:	0.0000	in.	Allowable Stress at Ambient Temperature:	17100	PSI
Inside Corrosion Allowance:	0.0625	in.	Correction Factor (F):	1.00	
External Corrosion Allowance:	0.0000	in.	Nozzle Path:	None	
Nozzle Pipe Size:	1		Nozzle Pipe Schedule:	160	
Nozzle ID (new):	0.8150	in.	Nozzle Wall Thickness(new):	0.2500	in.
Nozzle ID (corroded):	0.9400	in.	Nozzle Wall Thickness(corroded):	0.1875	in.
Developed Opening:	0.8160	in.	Tangential Dimension L:	9.0000	in.
External Limit of Reinforcement:	0.4688	in.	Upper Weld Leg Size(Weld 41):	0.3750	in.
Internal Limit of Reinforcement:	0.3125	in.	Internal Weld Leg Size(Weld 43):	0.0000	in.
Parallel Limit of Reinf (2Lpar):	2.0650	in.	Outside Groove Weld Depth:	0.4375	in.

Material:	SA-516 Gr. 70	Head wall thickness(new):	0.4375 in.
Material Stress(S_v):	20000 PSI	Head wall thickness - thin out (corroded):	0.3750 in.

Outside Groove Weld Depth: 0.4375 in.

Weld Strength Paths are adequate.

PLATINUM ENERGY SERVICES ULC

1" 150# RFSO (N14)

Job No: 30137 & 30138
 Number: 23
 ID Number: 23

Vessel Number: 01
 Mark Number: N14

Date Printed: 2/12/2016

Required Head Thickness per Paragraph UG-37(a)

$$t_r = \frac{P L o M}{(2 S E + P * (M - 0.2))} = \frac{78.50 * 96.0000 * 1.7631}{(2 * 20000 * 1 + 78.50 * (1.7631 - 0.2))} = \mathbf{0.3312 \text{ in.}}$$

Nozzle Required Thickness Calculations**Required Nozzle Thickness for Internal Pressure per Paragraph UG-37(a)**

$$t_{rn} = \frac{P R n}{S E - 0.6 P} = \frac{78.50 * 0.4700}{17100 * 1 - 0.6 * 78.50} = \mathbf{0.0022 \text{ in.}}$$

Strength Reduction Factors

$$f r 1 = \min \left\{ \frac{S_n}{S_v}, 1.0000 \right\} = \min \left\{ \frac{17100}{20000}, 1.0000 \right\} = 0.8550 \quad f r 2 = \min \left\{ \frac{S_n}{S_v}, 1.0000 \right\} = \min \left\{ \frac{17100}{20000}, 1.0000 \right\} = 0.8550$$

UG-45 Thickness Calculations**Nozzle Thickness for Pressure Loading (plus corrosion)**

$$t_a = \frac{P R n}{S E - 0.6 P} + C a + \text{ext. Ca} = \frac{78.50 * 0.4700}{17100 * 1.00 - 0.6 * 78.50} + 0.0625 + 0.0000 = \mathbf{0.0647 \text{ in.}}$$

Nozzle Thickness for Internal Pressure (plus corrosion) Based on Host

$$t_{b1} = \frac{P L o M}{(2 S E + P * (M - 0.2))} + C a + \text{ext. Ca} = \frac{78.50 * 96.0000 * 1.7631}{(2 * 20000 * 1 + 78.50 * (1.7631 - 0.2))} + 0.0625 + 0.0000 = \mathbf{0.3937 \text{ in.}}$$

Minimum Thickness (plus corrosion) per Table UG-45

$$t_{b3} = \text{minimum thickness (Table UG-45) + Ca + ext. Ca} = \mathbf{0.1785 \text{ in.}}$$

Nozzle Minimum Thickness Based on Host and Table UG-45

$$t_b = \min[t_{b3}, \max(t_{b1}, t_{b2})] = \mathbf{0.1785 \text{ in.}}$$

$$t_{UG-45} = \max(t_a, t_b) = \mathbf{0.1785 \text{ in.}}$$

Wall thickness = $t_n * 0.875(\text{pipe}) = \mathbf{0.2190}$ is greater than or equal to UG-45 value of **0.1785**

PLATINUM ENERGY SERVICES ULC

1" 150# RFSO (N15A)

Job No: 30137 & 30138
 Number: 24
 ID Number: 24

Vessel Number: 01
 Mark Number: N15A

Date Printed: 2/12/2016

Nozzle Design Information

Design Pressure:	75.00 PSI	Design Temperature:	350 °F
Static Head:	3.50 PSI	Nozzle Efficiency (E):	100 %
Nozzle Material:	SA-106 Gr. B	Joint Efficiency (E ₁):	1.00
		Factor B Chart:	CS-2
External Projection:	6.0000 in.	Allowable Stress at Design Temperature (S):	17100 PSI
Internal Projection:	0.0000 in.	Allowable Stress at Ambient Temperature:	17100 PSI
Inside Corrosion Allowance:	0.0625 in.	Correction Factor (F):	1.00
External Corrosion Allowance:	0.0000 in.	Nozzle Path:	None
Nozzle Pipe Size:	1	Nozzle Pipe Schedule:	160
Nozzle ID (new):	0.8150 in.	Nozzle Wall Thickness(new):	0.2500 in.
Nozzle ID (corroded):	0.9400 in.	Nozzle Wall Thickness(corroded):	0.1875 in.
Developed Opening:	0.8252 in.	Tangential Dimension L:	15.0000 in.
External Limit of Reinforcement:	0.4688 in.	Upper Weld Leg Size(Weld 41):	0.3750 in.
Internal Limit of Reinforcement:	0.3125 in.	Internal Weld Leg Size(Weld 43):	0.0000 in.
Parallel Limit of Reinf (2Lpar):	2.0650 in.	Outside Groove Weld Depth:	0.4375 in.

Minimum Design Metal Temperature

Min. Temp. Curve: B	Pressure at MDMT:	75.00 PSI
UCS-66(b) reduction: Yes	Minimum Design Metal Temperature:	-20 °F
UCS-68(c) reduction: No	Computed Minimum Temperature:	-155 °F

Host Component: Head 1 - 96" OD FLANGED & DISHED HEAD C/W 1.5" SF (RIGHT SIDE)

Material: SA-516 Gr. 70	Head wall thickness(new):	0.4375 in.
Material Stress(S _y): 20000 PSI	Head wall thickness - thin out (corroded):	0.3750 in.


Nozzle Detail Information

Fig. UW-16.1 (c)

Upper Weld Leg Size(Weld 41): 0.3750 in.

Nozzle Wall Thickness(t_n): 0.2500 in.

Outside Groove Weld Depth: 0.4375 in.

tangential to the vessel wall, attached by a groove weld.

Pipe Size: 1 Schedule: 160

Nozzle is adequate for UG-45 requirements.

Opening is adequately reinforced for Internal Pressure.

Reinforcement calculations are not required per UG-36(c)(3)(a) See Uw-14 for exceptions.

Weld Strength Paths are adequate.

PLATINUM ENERGY SERVICES ULC

1" 150# RFSO (N15A)

Job No: 30137 & 30138
 Number: 24
 ID Number: 24

Vessel Number: 01
 Mark Number: N15A

Date Printed: 2/12/2016

Required Head Thickness per Paragraph UG-37(a)

$$t_r = \frac{P L o M}{(2 S E + P * (M - 0.2))} = \frac{78.50 * 96.0000 * 1.0000}{(2 * 20000 * 1 + 78.50 * (1.0000 - 0.2))} = \mathbf{0.1881 \text{ in.}}$$

Nozzle Required Thickness Calculations**Required Nozzle Thickness for Internal Pressure per Paragraph UG-37(a)**

$$t_{rn} = \frac{P R n}{S E - 0.6 P} = \frac{78.50 * 0.4700}{17100 * 1 - 0.6 * 78.50} = \mathbf{0.0022 \text{ in.}}$$

Strength Reduction Factors

$$f_{r1} = \min \left\{ \frac{S_n}{S_v}, 1.0000 \right\} = \min \left\{ \frac{17100}{20000}, 1.0000 \right\} = 0.8550 \quad f_{r2} = \min \left\{ \frac{S_n}{S_v}, 1.0000 \right\} = \min \left\{ \frac{17100}{20000}, 1.0000 \right\} = 0.8550$$

UG-45 Thickness Calculations**Nozzle Thickness for Pressure Loading (plus corrosion)**

$$t_a = \frac{P R n}{S E - 0.6 P} + C_a + \text{ext. Ca} = \frac{78.50 * 0.4700}{17100 * 1.00 - 0.6 * 78.50} + 0.0625 + 0.0000 = \mathbf{0.0647 \text{ in.}}$$

Nozzle Thickness for Internal Pressure (plus corrosion) Based on Host

$$t_{b1} = \frac{P L o M}{(2 S E + P * (M - 0.2))} + C_a + \text{ext. Ca} = \frac{78.50 * 96.0000 * 1.7631}{(2 * 20000 * 1 + 78.50 * (1.7631 - 0.2))} + 0.0625 + 0.0000 = \mathbf{0.3937 \text{ in.}}$$

Minimum Thickness (plus corrosion) per Table UG-45

$$t_{b3} = \text{minimum thickness (Table UG-45) + } C_a + \text{ext. Ca} = \mathbf{0.1785 \text{ in.}}$$

Nozzle Minimum Thickness Based on Host and Table UG-45

$$t_b = \min[t_{b3}, \max(t_{b1}, t_{b2})] = \mathbf{0.1785 \text{ in.}}$$

$$t_{UG-45} = \max(t_a, t_b) = \mathbf{0.1785 \text{ in.}}$$

Wall thickness = $t_n * 0.875(\text{pipe}) = \mathbf{0.2190}$ is greater than or equal to UG-45 value of **0.1785**

PLATINUM ENERGY SERVICES ULC

1" 150# RFSO (N15B)

Job No: 30137 & 30138
 Number: 25
 ID Number: 25

Vessel Number: 01
 Mark Number: N15B

Date Printed: 2/12/2016

Nozzle Design Information

Design Pressure:	75.00 PSI	Design Temperature:	350 °F
Static Head:	3.50 PSI	Nozzle Efficiency (E):	100 %
Nozzle Material:	SA-106 Gr. B	Joint Efficiency (E ₁):	1.00
		Factor B Chart:	CS-2
External Projection:	6.0000 in.	Allowable Stress at Design Temperature (S):	17100 PSI
Internal Projection:	0.0000 in.	Allowable Stress at Ambient Temperature:	17100 PSI
Inside Corrosion Allowance:	0.0625 in.	Correction Factor (F):	1.00
External Corrosion Allowance:	0.0000 in.	Nozzle Path:	None
Nozzle Pipe Size:	1	Nozzle Pipe Schedule:	160
Nozzle ID (new):	0.8150 in.	Nozzle Wall Thickness(new):	0.2500 in.
Nozzle ID (corroded):	0.9400 in.	Nozzle Wall Thickness(corroded):	0.1875 in.
Developed Opening:	0.8180 in.	Tangential Dimension L:	32.0000 in.
External Limit of Reinforcement:	0.4688 in.	Upper Weld Leg Size(Weld 41):	0.3750 in.
Internal Limit of Reinforcement:	0.3125 in.	Internal Weld Leg Size(Weld 43):	0.0000 in.
Parallel Limit of Reinf (2Lpar):	2.0650 in.	Outside Groove Weld Depth:	0.4375 in.

Minimum Design Metal Temperature

Min. Temp. Curve: B	Pressure at MDMT:	75.00 PSI
UCS-66(b) reduction: Yes	Minimum Design Metal Temperature:	-20 °F
UCS-68(c) reduction: No	Computed Minimum Temperature:	-155 °F

Host Component: Head 1 - 96" OD FLANGED & DISHED HEAD C/W 1.5" SF (RIGHT SIDE)

Material: SA-516 Gr. 70	Head wall thickness(new):	0.4375 in.
Material Stress(S _y): 20000 PSI	Head wall thickness - thin out (corroded):	0.3750 in.


Nozzle Detail Information

Fig. UW-16.1 (c)

Upper Weld Leg Size(Weld 41): 0.3750 in.

Nozzle Wall Thickness(t_n): 0.2500 in.

Outside Groove Weld Depth: 0.4375 in.

tangential to the vessel wall, attached by a groove weld.

Pipe Size: 1 Schedule: 160

Nozzle is adequate for UG-45 requirements.

Opening is adequately reinforced for Internal Pressure.

Reinforcement calculations are not required per UG-36(c)(3)(a) See Uw-14 for exceptions.

Weld Strength Paths are adequate.

PLATINUM ENERGY SERVICES ULC

1" 150# RFSO (N15B)

Job No: 30137 & 30138
 Number: 25
 ID Number: 25

Vessel Number: 01
 Mark Number: N15B

Date Printed: 2/12/2016

Required Head Thickness per Paragraph UG-37(a)

$$t_r = \frac{P L o M}{(2 S E + P * (M - 0.2))} = \frac{78.50 * 96.0000 * 1.7631}{(2 * 20000 * 1 + 78.50 * (1.7631 - 0.2))} = \mathbf{0.3312 \text{ in.}}$$

Nozzle Required Thickness Calculations**Required Nozzle Thickness for Internal Pressure per Paragraph UG-37(a)**

$$t_{rn} = \frac{P R n}{S E - 0.6 P} = \frac{78.50 * 0.4700}{17100 * 1 - 0.6 * 78.50} = \mathbf{0.0022 \text{ in.}}$$

Strength Reduction Factors

$$f r 1 = \min \left\{ \frac{S_n}{S_v}, 1.0000 \right\} = \min \left\{ \frac{17100}{20000}, 1.0000 \right\} = 0.8550 \quad f r 2 = \min \left\{ \frac{S_n}{S_v}, 1.0000 \right\} = \min \left\{ \frac{17100}{20000}, 1.0000 \right\} = 0.8550$$

UG-45 Thickness Calculations**Nozzle Thickness for Pressure Loading (plus corrosion)**

$$t_a = \frac{P R n}{S E - 0.6 P} + C a + \text{ext. Ca} = \frac{78.50 * 0.4700}{17100 * 1.00 - 0.6 * 78.50} + 0.0625 + 0.0000 = \mathbf{0.0647 \text{ in.}}$$

Nozzle Thickness for Internal Pressure (plus corrosion) Based on Host

$$t_{b1} = \frac{P L o M}{(2 S E + P * (M - 0.2))} + C a + \text{ext. Ca} = \frac{78.50 * 96.0000 * 1.7631}{(2 * 20000 * 1 + 78.50 * (1.7631 - 0.2))} + 0.0625 + 0.0000 = \mathbf{0.3937 \text{ in.}}$$

Minimum Thickness (plus corrosion) per Table UG-45

$$t_{b3} = \text{minimum thickness (Table UG-45) + Ca + ext. Ca} = \mathbf{0.1785 \text{ in.}}$$

Nozzle Minimum Thickness Based on Host and Table UG-45

$$t_b = \min[t_{b3}, \max(t_{b1}, t_{b2})] = \mathbf{0.1785 \text{ in.}}$$

$$t_{UG-45} = \max(t_a, t_b) = \mathbf{0.1785 \text{ in.}}$$

Wall thickness = $t_n * 0.875(\text{pipe}) = \mathbf{0.2190}$ is greater than or equal to UG-45 value of **0.1785**

PLATINUM ENERGY SERVICES ULC

1" 150# RFSO (N15C)

Job No: 30137 & 30138
 Number: 26
 ID Number: 26

Vessel Number: 01
 Mark Number: N15C

Date Printed: 2/12/2016

Nozzle Design Information

Design Pressure:	75.00 PSI	Design Temperature:	350 °F
Static Head:	3.50 PSI	Nozzle Efficiency (E):	100 %
Nozzle Material:	SA-106 Gr. B	Joint Efficiency (E ₁):	1.00
		Factor B Chart:	CS-2
External Projection:	6.0000 in.	Allowable Stress at Design Temperature (S):	17100 PSI
Internal Projection:	0.0000 in.	Allowable Stress at Ambient Temperature:	17100 PSI
Inside Corrosion Allowance:	0.0625 in.	Correction Factor (F):	1.00
External Corrosion Allowance:	0.0000 in.	Nozzle Path:	None
Nozzle Pipe Size:	1	Nozzle Pipe Schedule:	160
Nozzle ID (new):	0.8150 in.	Nozzle Wall Thickness(new):	0.2500 in.
Nozzle ID (corroded):	0.9400 in.	Nozzle Wall Thickness(corroded):	0.1875 in.
Developed Opening:	0.8701 in.	Tangential Dimension L:	26.0000 in.
External Limit of Reinforcement:	0.4688 in.	Upper Weld Leg Size(Weld 41):	0.3750 in.
Internal Limit of Reinforcement:	0.3125 in.	Internal Weld Leg Size(Weld 43):	0.0000 in.
Parallel Limit of Reinf (2Lpar):	2.0650 in.	Outside Groove Weld Depth:	0.4375 in.

Minimum Design Metal Temperature

Min. Temp. Curve: B	Pressure at MDMT:	75.00 PSI
UCS-66(b) reduction: Yes	Minimum Design Metal Temperature:	-20 °F
UCS-68(c) reduction: No	Computed Minimum Temperature:	-155 °F

Host Component: Head 1 - 96" OD FLANGED & DISHED HEAD C/W 1.5" SF (RIGHT SIDE)

Material: SA-516 Gr. 70	Head wall thickness(new):	0.4375 in.
Material Stress(S _y): 20000 PSI	Head wall thickness - thin out (corroded):	0.3750 in.


Nozzle Detail Information

Fig. UW-16.1 (c)

Upper Weld Leg Size(Weld 41): 0.3750 in.

Nozzle Wall Thickness(t_n): 0.2500 in.

Outside Groove Weld Depth: 0.4375 in.

tangential to the vessel wall, attached by a groove weld.

Pipe Size: 1 Schedule: 160

Nozzle is adequate for UG-45 requirements.

Opening is adequately reinforced for Internal Pressure.

Reinforcement calculations are not required per UG-36(c)(3)(a) See Uw-14 for exceptions.

Weld Strength Paths are adequate.

PLATINUM ENERGY SERVICES ULC

1" 150# RFSO (N15C)

Job No: 30137 & 30138
 Number: 26
 ID Number: 26

Vessel Number: 01
 Mark Number: N15C

Date Printed: 2/12/2016

Required Head Thickness per Paragraph UG-37(a)

$$t_r = \frac{P L o M}{(2 S E + P * (M - 0.2))} = \frac{78.50 * 96.0000 * 1.7631}{(2 * 20000 * 1 + 78.50 * (1.7631 - 0.2))} = \mathbf{0.3312 \text{ in.}}$$

Nozzle Required Thickness Calculations**Required Nozzle Thickness for Internal Pressure per Paragraph UG-37(a)**

$$t_{rn} = \frac{P R n}{S E - 0.6 P} = \frac{78.50 * 0.4700}{17100 * 1 - 0.6 * 78.50} = \mathbf{0.0022 \text{ in.}}$$

Strength Reduction Factors

$$f_{r1} = \min \left\{ \frac{S_n}{S_v}, 1.0000 \right\} = \min \left\{ \frac{17100}{20000}, 1.0000 \right\} = 0.8550 \quad f_{r2} = \min \left\{ \frac{S_n}{S_v}, 1.0000 \right\} = \min \left\{ \frac{17100}{20000}, 1.0000 \right\} = 0.8550$$

UG-45 Thickness Calculations**Nozzle Thickness for Pressure Loading (plus corrosion)**

$$t_a = \frac{P R n}{S E - 0.6 P} + C_a + \text{ext. } C_a = \frac{78.50 * 0.4700}{17100 * 1.00 - 0.6 * 78.50} + 0.0625 + 0.0000 = \mathbf{0.0647 \text{ in.}}$$

Nozzle Thickness for Internal Pressure (plus corrosion) Based on Host

$$t_{b1} = \frac{P L o M}{(2 S E + P * (M - 0.2))} + C_a + \text{ext. } C_a = \frac{78.50 * 96.0000 * 1.7631}{(2 * 20000 * 1 + 78.50 * (1.7631 - 0.2))} + 0.0625 + 0.0000 = \mathbf{0.3937 \text{ in.}}$$

Minimum Thickness (plus corrosion) per Table UG-45

$$t_{b3} = \text{minimum thickness (Table UG-45) + } C_a + \text{ext. } C_a = \mathbf{0.1785 \text{ in.}}$$

Nozzle Minimum Thickness Based on Host and Table UG-45

$$t_b = \min[t_{b3}, \max(t_{b1}, t_{b2})] = \mathbf{0.1785 \text{ in.}}$$

$$t_{UG-45} = \max(t_a, t_b) = \mathbf{0.1785 \text{ in.}}$$

Wall thickness = $t_n * 0.875(\text{pipe}) = \mathbf{0.2190}$ is greater than or equal to UG-45 value of **0.1785**

PLATINUM ENERGY SERVICES ULC

1" 150# RFSO (N15D)

Job No: 30137 & 30138
 Number: 27
 ID Number: 27

Vessel Number: 01
 Mark Number: N15D

Date Printed: 2/12/2016

Nozzle Design Information

Design Pressure:	75.00 PSI	Design Temperature:	350 °F
Static Head:	3.50 PSI	Nozzle Efficiency (E):	100 %
Nozzle Material:	SA-106 Gr. B	Joint Efficiency (E ₁):	1.00
		Factor B Chart:	CS-2
External Projection:	6.0000 in.	Allowable Stress at Design Temperature (S):	17100 PSI
Internal Projection:	0.0000 in.	Allowable Stress at Ambient Temperature:	17100 PSI
Inside Corrosion Allowance:	0.0625 in.	Correction Factor (F):	1.00
External Corrosion Allowance:	0.0000 in.	Nozzle Path:	None
Nozzle Pipe Size:	1	Nozzle Pipe Schedule:	160
Nozzle ID (new):	0.8150 in.	Nozzle Wall Thickness(new):	0.2500 in.
Nozzle ID (corroded):	0.9400 in.	Nozzle Wall Thickness(corroded):	0.1875 in.
Developed Opening:	0.9000 in.	Tangential Dimension L:	20.0000 in.
External Limit of Reinforcement:	0.4688 in.	Upper Weld Leg Size(Weld 41):	0.3750 in.
Internal Limit of Reinforcement:	0.3125 in.	Internal Weld Leg Size(Weld 43):	0.0000 in.
Parallel Limit of Reinf (2Lpar):	2.0650 in.	Outside Groove Weld Depth:	0.4375 in.

Minimum Design Metal Temperature

Min. Temp. Curve: B	Pressure at MDMT:	75.00 PSI
UCS-66(b) reduction: Yes	Minimum Design Metal Temperature:	-20 °F
UCS-68(c) reduction: No	Computed Minimum Temperature:	-155 °F

Host Component: Head 1 - 96" OD FLANGED & DISHED HEAD C/W 1.5" SF (RIGHT SIDE)

Material: SA-516 Gr. 70	Head wall thickness(new):	0.4375 in.
Material Stress(S _y): 20000 PSI	Head wall thickness - thin out (corroded):	0.3750 in.


Nozzle Detail Information

Fig. UW-16.1 (c)

Upper Weld Leg Size(Weld 41): 0.3750 in.

Nozzle Wall Thickness(t_n): 0.2500 in.

Outside Groove Weld Depth: 0.4375 in.

tangential to the vessel wall, attached by a groove weld.

Pipe Size: 1 Schedule: 160

Nozzle is adequate for UG-45 requirements.

Opening is adequately reinforced for Internal Pressure.

Reinforcement calculations are not required per UG-36(c)(3)(a) See Uw-14 for exceptions.

Weld Strength Paths are adequate.

PLATINUM ENERGY SERVICES ULC

1" 150# RFSO (N15D)

Job No: 30137 & 30138
 Number: 27
 ID Number: 27

Vessel Number: 01
 Mark Number: N15D

Date Printed: 2/12/2016

Required Head Thickness per Paragraph UG-37(a)

$$t_r = \frac{P L o M}{(2 S E + P * (M - 0.2))} = \frac{78.50 * 96.0000 * 1.7631}{(2 * 20000 * 1 + 78.50 * (1.7631 - 0.2))} = \mathbf{0.3312 \text{ in.}}$$

Nozzle Required Thickness Calculations**Required Nozzle Thickness for Internal Pressure per Paragraph UG-37(a)**

$$t_{rn} = \frac{P R n}{S E - 0.6 P} = \frac{78.50 * 0.4700}{17100 * 1 - 0.6 * 78.50} = \mathbf{0.0022 \text{ in.}}$$

Strength Reduction Factors

$$f r 1 = \min \left\{ \frac{S_n}{S_v}, 1.0000 \right\} = \min \left\{ \frac{17100}{20000}, 1.0000 \right\} = 0.8550 \quad f r 2 = \min \left\{ \frac{S_n}{S_v}, 1.0000 \right\} = \min \left\{ \frac{17100}{20000}, 1.0000 \right\} = 0.8550$$

UG-45 Thickness Calculations**Nozzle Thickness for Pressure Loading (plus corrosion)**

$$t_a = \frac{P R n}{S E - 0.6 P} + C a + \text{ext. Ca} = \frac{78.50 * 0.4700}{17100 * 1.00 - 0.6 * 78.50} + 0.0625 + 0.0000 = \mathbf{0.0647 \text{ in.}}$$

Nozzle Thickness for Internal Pressure (plus corrosion) Based on Host

$$t_{b1} = \frac{P L o M}{(2 S E + P * (M - 0.2))} + C a + \text{ext. Ca} = \frac{78.50 * 96.0000 * 1.7631}{(2 * 20000 * 1 + 78.50 * (1.7631 - 0.2))} + 0.0625 + 0.0000 = \mathbf{0.3937 \text{ in.}}$$

Minimum Thickness (plus corrosion) per Table UG-45

$$t_{b3} = \text{minimum thickness (Table UG-45) + Ca + ext. Ca} = \mathbf{0.1785 \text{ in.}}$$

Nozzle Minimum Thickness Based on Host and Table UG-45

$$t_b = \min[t_{b3}, \max(t_{b1}, t_{b2})] = \mathbf{0.1785 \text{ in.}}$$

$$t_{UG-45} = \max(t_a, t_b) = \mathbf{0.1785 \text{ in.}}$$

Wall thickness = $t_n * 0.875(\text{pipe}) = \mathbf{0.2190}$ is greater than or equal to UG-45 value of **0.1785**

PLATINUM ENERGY SERVICES ULC

1" 150# RFSO (N15E)

Job No: 30137 & 30138
 Number: 28
 ID Number: 28

Vessel Number: 01
 Mark Number: N15E

Date Printed: 2/12/2016

Nozzle Design Information

Design Pressure:	75.00 PSI	Design Temperature:	350 °F
Static Head:	3.50 PSI	Nozzle Efficiency (E):	100 %
Nozzle Material:	SA-106 Gr. B	Joint Efficiency (E ₁):	1.00
		Factor B Chart:	CS-2
External Projection:	6.0000 in.	Allowable Stress at Design Temperature (S):	17100 PSI
Internal Projection:	0.0000 in.	Allowable Stress at Ambient Temperature:	17100 PSI
Inside Corrosion Allowance:	0.0625 in.	Correction Factor (F):	1.00
External Corrosion Allowance:	0.0000 in.	Nozzle Path:	None
Nozzle Pipe Size:	1	Nozzle Pipe Schedule:	160
Nozzle ID (new):	0.8150 in.	Nozzle Wall Thickness(new):	0.2500 in.
Nozzle ID (corroded):	0.9400 in.	Nozzle Wall Thickness(corroded):	0.1875 in.
Developed Opening:	0.8180 in.	Tangential Dimension L:	32.0000 in.
External Limit of Reinforcement:	0.4688 in.	Upper Weld Leg Size(Weld 41):	0.3750 in.
Internal Limit of Reinforcement:	0.3125 in.	Internal Weld Leg Size(Weld 43):	0.0000 in.
Parallel Limit of Reinf (2Lpar):	2.0650 in.	Outside Groove Weld Depth:	0.4375 in.

Minimum Design Metal Temperature

Min. Temp. Curve: B	Pressure at MDMT:	75.00 PSI
UCS-66(b) reduction: Yes	Minimum Design Metal Temperature:	-20 °F
UCS-68(c) reduction: No	Computed Minimum Temperature:	-155 °F

Host Component: Head 1 - 96" OD FLANGED & DISHED HEAD C/W 1.5" SF (RIGHT SIDE)

Material: SA-516 Gr. 70	Head wall thickness(new):	0.4375 in.
Material Stress(S _y): 20000 PSI	Head wall thickness - thin out (corroded):	0.3750 in.


Nozzle Detail Information

Fig. UW-16.1 (c)

Upper Weld Leg Size(Weld 41): 0.3750 in.

Nozzle Wall Thickness(t_n): 0.2500 in.

Outside Groove Weld Depth: 0.4375 in.

tangential to the vessel wall, attached by a groove weld.

Pipe Size: 1 Schedule: 160

Nozzle is adequate for UG-45 requirements.

Opening is adequately reinforced for Internal Pressure.

Reinforcement calculations are not required per UG-36(c)(3)(a) See Uw-14 for exceptions.

Weld Strength Paths are adequate.

PLATINUM ENERGY SERVICES ULC

1" 150# RFSO (N15E)

Job No: 30137 & 30138
 Number: 28
 ID Number: 28

Vessel Number: 01
 Mark Number: N15E

Date Printed: 2/12/2016

Required Head Thickness per Paragraph UG-37(a)

$$t_r = \frac{P L o M}{(2 S E + P * (M - 0.2))} = \frac{78.50 * 96.0000 * 1.7631}{(2 * 20000 * 1 + 78.50 * (1.7631 - 0.2))} = 0.3312 \text{ in.}$$

Nozzle Required Thickness Calculations**Required Nozzle Thickness for Internal Pressure per Paragraph UG-37(a)**

$$t_{rn} = \frac{P R n}{S E - 0.6 P} = \frac{78.50 * 0.4700}{17100 * 1 - 0.6 * 78.50} = 0.0022 \text{ in.}$$

Strength Reduction Factors

$$f r 1 = \min \left\{ \frac{S_n}{S_v}, 1.0000 \right\} = \min \left\{ \frac{17100}{20000}, 1.0000 \right\} = 0.8550 \quad f r 2 = \min \left\{ \frac{S_n}{S_v}, 1.0000 \right\} = \min \left\{ \frac{17100}{20000}, 1.0000 \right\} = 0.8550$$

UG-45 Thickness Calculations**Nozzle Thickness for Pressure Loading (plus corrosion)**

$$t_a = \frac{P R n}{S E - 0.6 P} + C a + \text{ext. Ca} = \frac{78.50 * 0.4700}{17100 * 1.00 - 0.6 * 78.50} + 0.0625 + 0.0000 = 0.0647 \text{ in.}$$

Nozzle Thickness for Internal Pressure (plus corrosion) Based on Host

$$t_{b1} = \frac{P L o M}{(2 S E + P * (M - 0.2))} + C a + \text{ext. Ca} = \frac{78.50 * 96.0000 * 1.7631}{(2 * 20000 * 1 + 78.50 * (1.7631 - 0.2))} + 0.0625 + 0.0000 = 0.3937 \text{ in.}$$

Minimum Thickness (plus corrosion) per Table UG-45

$$t_{b3} = \text{minimum thickness (Table UG-45) + Ca + ext. Ca} = 0.1785 \text{ in.}$$

Nozzle Minimum Thickness Based on Host and Table UG-45

$$t_b = \min[t_{b3}, \max(t_{b1}, t_{b2})] = 0.1785 \text{ in.}$$

$$t_{UG-45} = \max(t_a, t_b) = 0.1785 \text{ in.}$$

Wall thickness = $t_n * 0.875(\text{pipe}) = 0.2190$ is greater than or equal to UG-45 value of **0.1785**

PLATINUM ENERGY SERVICES ULC

3" 150# RFSO (N16)

Job No: 30137 & 30138
 Number: 29
 ID Number: 29

Vessel Number: 01
 Mark Number: N29

Date Printed: 2/12/2016

Nozzle Design Information

Design Pressure:	75.00 PSI	Design Temperature:	350 °F
Static Head:	3.50 PSI	Nozzle Efficiency (E):	100 %
Nozzle Material:	SA-106 Gr. B	Joint Efficiency (E ₁):	1.00
		Factor B Chart:	CS-2
External Projection:	6.0000 in.	Allowable Stress at Design Temperature (S _d):	17100 PSI
Internal Projection:	0.0000 in.	Allowable Stress at Ambient Temperature:	17100 PSI
Inside Corrosion Allowance:	0.0625 in.	Correction Factor (F):	1.00
External Corrosion Allowance:	0.0000 in.	Nozzle Path:	None
Nozzle Pipe Size:	3	Nozzle Pipe Schedule:	80
Nozzle ID (new):	2.9000 in.	Nozzle Wall Thickness(new):	0.3000 in.
Nozzle ID (corroded):	3.0250 in.	Nozzle Wall Thickness(corroded):	0.2375 in.
External Limit of Reinforcement:	0.5938 in.	Upper Weld Leg Size(Weld 41):	0.3750 in.
Internal Limit of Reinforcement:	0.4375 in.	Internal Weld Leg Size(Weld 43):	0.0000 in.
Parallel Limit of Reinf (2Lpar):	6.0500 in.	Outside Groove Weld Depth:	0.3750 in.

Minimum Design Metal Temperature

Min. Temp. Curve:	B	Pressure at MDMT:	75.00 PSI
UCS-66(b) reduction:	Yes	Minimum Design Metal Temperature:	-20 °F
UCS-68(c) reduction:	No	Computed Minimum Temperature:	-155 °F

Host Component: Shell 1 - 8'-0" OD x 30'-0" LONG SHELL

Material:	SA-516 Gr. 70	Shell wall thickness(new):	0.3750 in.
Material Stress(S _y):	20000 PSI	Shell wall thickness(corroded):	0.3125 in.

Nozzle Detail Information

Backing strip if used may
 be removed after welding




Fig. UW-16.1 (c)

Upper Weld Leg Size(Weld 41): 0.3750 in.

Nozzle Wall Thickness(t_n): 0.3000 in.

Outside Groove Weld Depth: 0.3750 in.

Nozzle passes through the vessel, attached by a groove weld.

Pipe Size: 3 Schedule: 80

Nozzle is adequate for UG-45 requirements.

Opening is adequately reinforced for Internal Pressure.

Reinforcement calculations are not required per UG-36(c)(3)(a) See Uw-14 for exceptions.

Weld Strength Paths are adequate.

PLATINUM ENERGY SERVICES ULC

3" 150# RFSO (N16)

Job No: 30137 & 30138
 Number: 29
 ID Number: 29

Vessel Number: 01
 Mark Number: N29

Date Printed: 2/12/2016

Required Shell Thickness per Paragraph UG-37(a)

$$t_r = \frac{P R_o}{S E + 0.4 P} = \frac{78.50 * 48.0000}{20000 * 1 + 0.4 * 78.50} = \mathbf{0.1881 \text{ in.}}$$

Nozzle Required Thickness Calculations**Required Nozzle Thickness for Internal Pressure per Paragraph UG-37(a)**

$$t_{rn} = \frac{P R_n}{S E - 0.6 P} = \frac{78.50 * 1.5125}{17100 * 1 - 0.6 * 78.50} = \mathbf{0.0070 \text{ in.}}$$

Strength Reduction Factors

$$f_{r1} = \min \left\{ \frac{S_n}{S_v}, 1.0000 \right\} = \min \left\{ \frac{17100}{20000}, 1.0000 \right\} = 0.8550 \quad f_{r2} = \min \left\{ \frac{S_n}{S_v}, 1.0000 \right\} = \min \left\{ \frac{17100}{20000}, 1.0000 \right\} = 0.8550$$

UG-45 Thickness Calculations**Nozzle Thickness for Pressure Loading (plus corrosion)**

$$t_a = \frac{P R_n}{S E - 0.6 P} + C_a + \text{ext. Ca} = \frac{78.50 * 1.5125}{17100 * 1.00 - 0.6 * 78.50} + 0.0625 + 0.0000 = \mathbf{0.0695 \text{ in.}}$$

Nozzle Thickness for Internal Pressure (plus corrosion) Based on Host

$$t_{b1} = \frac{P R_o}{S E + 0.4 P} + C_a + \text{ext. Ca} = \frac{78.50 * 48.0000}{20000 * 1 + 0.4 * 78.50} + 0.0625 + 0.0000 = \mathbf{0.2506 \text{ in.}}$$

Minimum Thickness (plus corrosion) per Table UG-45

$$t_{b3} = \text{minimum thickness (Table UG-45) + } C_a + \text{ext. Ca} = \mathbf{0.2515 \text{ in.}}$$

Nozzle Minimum Thickness Based on Host and Table UG-45

$$t_b = \min[t_{b3}, \max(t_{b1}, t_{b2})] = \mathbf{0.2506 \text{ in.}}$$

$$t_{UG-45} = \max(t_a, t_b) = \mathbf{0.2506 \text{ in.}}$$

Wall thickness = $t_n * 0.875(\text{pipe}) = \mathbf{0.2620}$ is greater than or equal to UG-45 value of **0.2506**

PLATINUM ENERGY SERVICES ULC

3" 150# RFSO (N17)

Job No: 30137 & 30138
 Number: 30
 ID Number: 30

Vessel Number: 01
 Mark Number: N17

Date Printed: 2/12/2016

Nozzle Design Information

Design Pressure:	75.00 PSI	Design Temperature:	350 °F
Static Head:	3.50 PSI	Nozzle Efficiency (E):	100 %
Nozzle Material:	SA-106 Gr. B	Joint Efficiency (E ₁):	1.00
		Factor B Chart:	CS-2
External Projection:	6.0000 in.	Allowable Stress at Design Temperature (S _d):	17100 PSI
Internal Projection:	0.0000 in.	Allowable Stress at Ambient Temperature:	17100 PSI
Inside Corrosion Allowance:	0.0625 in.	Correction Factor (F):	1.00
External Corrosion Allowance:	0.0000 in.	Nozzle Path:	None
Nozzle Pipe Size:	3	Nozzle Pipe Schedule:	80
Nozzle ID (new):	2.9000 in.	Nozzle Wall Thickness(new):	0.3000 in.
Nozzle ID (corroded):	3.0250 in.	Nozzle Wall Thickness(corroded):	0.2375 in.
External Limit of Reinforcement:	0.5938 in.	Upper Weld Leg Size(Weld 41):	0.3750 in.
Internal Limit of Reinforcement:	0.4375 in.	Internal Weld Leg Size(Weld 43):	0.0000 in.
Parallel Limit of Reinf (2Lpar):	6.0500 in.	Outside Groove Weld Depth:	0.3750 in.

Minimum Design Metal Temperature

Min. Temp. Curve:	B	Pressure at MDMT:	75.00 PSI
UCS-66(b) reduction:	Yes	Minimum Design Metal Temperature:	-20 °F
UCS-68(c) reduction:	No	Computed Minimum Temperature:	-155 °F

Host Component: Shell 1 - 8'-0" OD x 30'-0" LONG SHELL

Material:	SA-516 Gr. 70	Shell wall thickness(new):	0.3750 in.
Material Stress(S _y):	20000 PSI	Shell wall thickness(corroded):	0.3125 in.

Nozzle Detail Information

Backing strip if used may
 be removed after welding




Fig. UW-16.1 (c)

Upper Weld Leg Size(Weld 41): 0.3750 in.

Nozzle Wall Thickness(t_n): 0.3000 in.

Outside Groove Weld Depth: 0.3750 in.

Nozzle passes through the vessel, attached by a groove weld.

Pipe Size: 3 Schedule: 80

Nozzle is adequate for UG-45 requirements.

Opening is adequately reinforced for Internal Pressure.

Reinforcement calculations are not required per UG-36(c)(3)(a) See Uw-14 for exceptions.

Weld Strength Paths are adequate.

PLATINUM ENERGY SERVICES ULC

3" 150# RFSO (N17)

Job No: 30137 & 30138
 Number: 30
 ID Number: 30

Vessel Number: 01
 Mark Number: N17

Date Printed: 2/12/2016

Required Shell Thickness per Paragraph UG-37(a)

$$t_r = \frac{P R_o}{S E + 0.4 P} = \frac{78.50 * 48.0000}{20000 * 1 + 0.4 * 78.50} = \mathbf{0.1881 \text{ in.}}$$

Nozzle Required Thickness Calculations**Required Nozzle Thickness for Internal Pressure per Paragraph UG-37(a)**

$$t_{rn} = \frac{P R_n}{S E - 0.6 P} = \frac{78.50 * 1.5125}{17100 * 1 - 0.6 * 78.50} = \mathbf{0.0070 \text{ in.}}$$

Strength Reduction Factors

$$f_{r1} = \min \left[\frac{S_n}{S_v}, 1.0000 \right] = \min \left[\frac{17100}{20000}, 1.0000 \right] = 0.8550 \quad f_{r2} = \min \left[\frac{S_n}{S_v}, 1.0000 \right] = \min \left[\frac{17100}{20000}, 1.0000 \right] = 0.8550$$

UG-45 Thickness Calculations**Nozzle Thickness for Pressure Loading (plus corrosion)**

$$t_a = \frac{P R_n}{S E - 0.6 P} + C_a + \text{ext. Ca} = \frac{78.50 * 1.5125}{17100 * 1.00 - 0.6 * 78.50} + 0.0625 + 0.0000 = \mathbf{0.0695 \text{ in.}}$$

Nozzle Thickness for Internal Pressure (plus corrosion) Based on Host

$$t_{b1} = \frac{P R_o}{S E + 0.4 P} + C_a + \text{ext. Ca} = \frac{78.50 * 48.0000}{20000 * 1 + 0.4 * 78.50} + 0.0625 + 0.0000 = \mathbf{0.2506 \text{ in.}}$$

Minimum Thickness (plus corrosion) per Table UG-45

$$t_{b3} = \text{minimum thickness (Table UG-45) + } C_a + \text{ext. Ca} = \mathbf{0.2515 \text{ in.}}$$

Nozzle Minimum Thickness Based on Host and Table UG-45

$$t_b = \min[t_{b3}, \max(t_{b1}, t_{b2})] = \mathbf{0.2506 \text{ in.}}$$

$$t_{UG-45} = \max(t_a, t_b) = \mathbf{0.2506 \text{ in.}}$$

Wall thickness = $t_n * 0.875(\text{pipe}) = \mathbf{0.2620}$ is greater than or equal to UG-45 value of **0.2506**

PLATINUM ENERGY SERVICES ULC

3" 150# RFSO (N18)

Job No: 30137 & 30138
 Number: 31
 ID Number: 31

Vessel Number: 01
 Mark Number: N18

Date Printed: 2/12/2016

Nozzle Design Information

Design Pressure:	75.00 PSI	Design Temperature:	350 °F
Static Head:	3.50 PSI	Nozzle Efficiency (E):	100 %
Nozzle Material:	SA-106 Gr. B	Joint Efficiency (E ₁):	1.00
		Factor B Chart:	CS-2
External Projection:	6.0000 in.	Allowable Stress at Design Temperature (S _d):	17100 PSI
Internal Projection:	0.0000 in.	Allowable Stress at Ambient Temperature:	17100 PSI
Inside Corrosion Allowance:	0.0625 in.	Correction Factor (F):	1.00
External Corrosion Allowance:	0.0000 in.	Nozzle Path:	None
Nozzle Pipe Size:	3	Nozzle Pipe Schedule:	80
Nozzle ID (new):	2.9000 in.	Nozzle Wall Thickness(new):	0.3000 in.
Nozzle ID (corroded):	3.0250 in.	Nozzle Wall Thickness(corroded):	0.2375 in.
External Limit of Reinforcement:	0.5938 in.	Upper Weld Leg Size(Weld 41):	0.3750 in.
Internal Limit of Reinforcement:	0.4375 in.	Internal Weld Leg Size(Weld 43):	0.0000 in.
Parallel Limit of Reinf (2Lpar):	6.0500 in.	Outside Groove Weld Depth:	0.3750 in.

Minimum Design Metal Temperature

Min. Temp. Curve:	B	Pressure at MDMT:	75.00 PSI
UCS-66(b) reduction:	Yes	Minimum Design Metal Temperature:	-20 °F
UCS-68(c) reduction:	No	Computed Minimum Temperature:	-155 °F

Host Component: Shell 1 - 8'-0" OD x 30'-0" LONG SHELL

Material:	SA-516 Gr. 70	Shell wall thickness(new):	0.3750 in.
Material Stress(S _y):	20000 PSI	Shell wall thickness(corroded):	0.3125 in.

Nozzle Detail Information

Backing strip if used may
 be removed after welding




Fig. UW-16.1 (c)

Upper Weld Leg Size(Weld 41): 0.3750 in.

Nozzle Wall Thickness(t_n): 0.3000 in.

Outside Groove Weld Depth: 0.3750 in.

Nozzle passes through the vessel, attached by a groove weld.

Pipe Size: 3 Schedule: 80

Nozzle is adequate for UG-45 requirements.

Opening is adequately reinforced for Internal Pressure.

Reinforcement calculations are not required per UG-36(c)(3)(a) See Uw-14 for exceptions.

Weld Strength Paths are adequate.

PLATINUM ENERGY SERVICES ULC

3" 150# RFSO (N18)

Job No: 30137 & 30138
 Number: 31
 ID Number: 31

Vessel Number: 01
 Mark Number: N18

Date Printed: 2/12/2016

Required Shell Thickness per Paragraph UG-37(a)

$$t_r = \frac{P R_o}{S E + 0.4 P} = \frac{78.50 * 48.0000}{20000 * 1 + 0.4 * 78.50} = \mathbf{0.1881 \text{ in.}}$$

Nozzle Required Thickness Calculations**Required Nozzle Thickness for Internal Pressure per Paragraph UG-37(a)**

$$t_{rn} = \frac{P R_n}{S E - 0.6 P} = \frac{78.50 * 1.5125}{17100 * 1 - 0.6 * 78.50} = \mathbf{0.0070 \text{ in.}}$$

Strength Reduction Factors

$$f_{r1} = \min \left\{ \frac{S_n}{S_v}, 1.0000 \right\} = \min \left\{ \frac{17100}{20000}, 1.0000 \right\} = 0.8550 \quad f_{r2} = \min \left\{ \frac{S_n}{S_v}, 1.0000 \right\} = \min \left\{ \frac{17100}{20000}, 1.0000 \right\} = 0.8550$$

UG-45 Thickness Calculations**Nozzle Thickness for Pressure Loading (plus corrosion)**

$$t_a = \frac{P R_n}{S E - 0.6 P} + C_a + \text{ext. Ca} = \frac{78.50 * 1.5125}{17100 * 1.00 - 0.6 * 78.50} + 0.0625 + 0.0000 = \mathbf{0.0695 \text{ in.}}$$

Nozzle Thickness for Internal Pressure (plus corrosion) Based on Host

$$t_{b1} = \frac{P R_o}{S E + 0.4 P} + C_a + \text{ext. Ca} = \frac{78.50 * 48.0000}{20000 * 1 + 0.4 * 78.50} + 0.0625 + 0.0000 = \mathbf{0.2506 \text{ in.}}$$

Minimum Thickness (plus corrosion) per Table UG-45

$$t_{b3} = \text{minimum thickness (Table UG-45) + } C_a + \text{ext. Ca} = \mathbf{0.2515 \text{ in.}}$$

Nozzle Minimum Thickness Based on Host and Table UG-45

$$t_b = \min[t_{b3}, \max(t_{b1}, t_{b2})] = \mathbf{0.2506 \text{ in.}}$$

$$t_{UG-45} = \max(t_a, t_b) = \mathbf{0.2506 \text{ in.}}$$

Wall thickness = $t_n * 0.875(\text{pipe}) = \mathbf{0.2620}$ is greater than or equal to UG-45 value of **0.2506**

PLATINUM ENERGY SERVICES ULC

3" 150# RFSO (N19)

Job No: 30137 & 30138
 Number: 32
 ID Number: 32

Vessel Number: 01
 Mark Number: N19

Date Printed: 2/12/2016

Nozzle Design Information

Design Pressure:	75.00 PSI	Design Temperature:	350 °F
Static Head:	3.50 PSI	Nozzle Efficiency (E):	100 %
Nozzle Material:	SA-106 Gr. B	Joint Efficiency (E ₁):	1.00
		Factor B Chart:	CS-2
External Projection:	6.0000 in.	Allowable Stress at Design Temperature (S):	17100 PSI
Internal Projection:	0.0000 in.	Allowable Stress at Ambient Temperature:	17100 PSI
Inside Corrosion Allowance:	0.0625 in.	Correction Factor (F):	1.00
External Corrosion Allowance:	0.0000 in.	Nozzle Path:	None
Nozzle Pipe Size:	3	Nozzle Pipe Schedule:	80
Nozzle ID (new):	2.9000 in.	Nozzle Wall Thickness(new):	0.3000 in.
Nozzle ID (corroded):	3.0250 in.	Nozzle Wall Thickness(corroded):	0.2375 in.
Developed Opening:	2.9000 in.	Tangential Dimension L:	39.0000 in.
External Limit of Reinforcement:	0.5938 in.	Upper Weld Leg Size(Weld 41):	0.3750 in.
Internal Limit of Reinforcement:	0.4375 in.	Internal Weld Leg Size(Weld 43):	0.0000 in.
Parallel Limit of Reinf (2Lpar):	6.0500 in.	Outside Groove Weld Depth:	0.4375 in.

Minimum Design Metal Temperature

Min. Temp. Curve: B	Pressure at MDMT:	75.00 PSI
UCS-66(b) reduction: Yes	Minimum Design Metal Temperature:	-20 °F
UCS-68(c) reduction: No	Computed Minimum Temperature:	-155 °F

Host Component: Head 1 - 96" OD FLANGED & DISHED HEAD C/W 1.5" SF (RIGHT SIDE)

Material: SA-516 Gr. 70	Head wall thickness(new):	0.4375 in.
Material Stress(S _y): 20000 PSI	Head wall thickness - thin out (corroded):	0.3750 in.


Nozzle Detail Information

Fig. UW-16.1 (c)

Upper Weld Leg Size(Weld 41): 0.3750 in.

Nozzle Wall Thickness(t_n): 0.3000 in.

Outside Groove Weld Depth: 0.4375 in.

tangential to the vessel wall, attached by a groove weld.

Pipe Size: 3 Schedule: 80

Nozzle is adequate for UG-45 requirements.

Opening is adequately reinforced for Internal Pressure.

Reinforcement calculations are not required per UG-36(c)(3)(a) See Uw-14 for exceptions.

Weld Strength Paths are adequate.

PLATINUM ENERGY SERVICES ULC

3" 150# RFSO (N19)

Job No: 30137 & 30138
 Number: 32
 ID Number: 32

Vessel Number: 01
 Mark Number: N19

Date Printed: 2/12/2016

Required Head Thickness per Paragraph UG-37(a)

$$t_r = \frac{P L o M}{(2 S E + P * (M - 0.2))} = \frac{78.50 * 96.0000 * 1.7631}{(2 * 20000 * 1 + 78.50 * (1.7631 - 0.2))} = \mathbf{0.3312 \text{ in.}}$$

Nozzle Required Thickness Calculations**Required Nozzle Thickness for Internal Pressure per Paragraph UG-37(a)**

$$t_{rn} = \frac{P R n}{S E - 0.6 P} = \frac{78.50 * 1.5125}{17100 * 1 - 0.6 * 78.50} = \mathbf{0.0070 \text{ in.}}$$

Strength Reduction Factors

$$f r 1 = \min \left\{ \frac{S_n}{S_v}, 1.0000 \right\} = \min \left\{ \frac{17100}{20000}, 1.0000 \right\} = 0.8550 \quad f r 2 = \min \left\{ \frac{S_n}{S_v}, 1.0000 \right\} = \min \left\{ \frac{17100}{20000}, 1.0000 \right\} = 0.8550$$

UG-45 Thickness Calculations**Nozzle Thickness for Pressure Loading (plus corrosion)**

$$t_a = \frac{P R n}{S E - 0.6 P} + C a + \text{ext. } C a = \frac{78.50 * 1.5125}{17100 * 1.00 - 0.6 * 78.50} + 0.0625 + 0.0000 = \mathbf{0.0695 \text{ in.}}$$

Nozzle Thickness for Internal Pressure (plus corrosion) Based on Host

$$t_{b1} = \frac{P L o M}{(2 S E + P * (M - 0.2))} + C a + \text{ext. } C a = \frac{78.50 * 96.0000 * 1.7631}{(2 * 20000 * 1 + 78.50 * (1.7631 - 0.2))} + 0.0625 + 0.0000 = \mathbf{0.3937 \text{ in.}}$$

Minimum Thickness (plus corrosion) per Table UG-45

$$t_{b3} = \text{minimum thickness (Table UG-45) + } C a + \text{ext. } C a = \mathbf{0.2515 \text{ in.}}$$

Nozzle Minimum Thickness Based on Host and Table UG-45

$$t_b = \min[t_{b3}, \max(t_{b1}, t_{b2})] = \mathbf{0.2515 \text{ in.}}$$

$$t_{UG-45} = \max(t_a, t_b) = \mathbf{0.2515 \text{ in.}}$$

Wall thickness = $t_n * 0.875(\text{pipe}) = \mathbf{0.2620}$ is greater than or equal to UG-45 value of **0.2515**

PLATINUM ENERGY SERVICES ULC

18" 150# RFSO (M1)

Job No: 30137 & 30138
 Number: 33
 ID Number: 33

Vessel Number: 01
 Mark Number: M1

Date Printed: 2/12/2016

Nozzle Design Information

Design Pressure:	75.00 PSI	Design Temperature:	350 °F
Static Head:	3.50 PSI	Nozzle Efficiency (E):	100 %
Nozzle Material:	SA-106 Gr. B	Joint Efficiency (E ₁):	1.00
		Factor B Chart:	CS-2
External Projection:	10.0000 in.	Allowable Stress at Design Temperature (S):	17100 PSI
Internal Projection:	0.3750 in.	Allowable Stress at Ambient Temperature:	17100 PSI
Inside Corrosion Allowance:	0.0625 in.	Correction Factor (F):	1.00
External Corrosion Allowance:	0.0000 in.	Nozzle Path:	None
Nozzle Pipe Size:	18	Nozzle Pipe Schedule:	40
Nozzle ID (new):	16.8760 in.	Nozzle Wall Thickness(new):	0.5620 in.
Nozzle ID (corroded):	17.0010 in.	Nozzle Wall Thickness(corroded):	0.4995 in.
Developed Opening:	17.6561 in.	Tangential Dimension L:	28.0000 in.
External Limit of Reinforcement:	0.9375 in.	Upper Weld Leg Size(Weld 41):	0.3750 in.
Internal Limit of Reinforcement:	0.9375 in.	Internal Weld Leg Size(Weld 43):	0.3750 in.
Parallel Limit of Reinf (2Lpar):	35.5622 in.	Outside Groove Weld Depth:	0.4375 in.

Minimum Design Metal Temperature

Min. Temp. Curve: B	Pressure at MDMT:	75.00 PSI
UCS-66(b) reduction: Yes	Minimum Design Metal Temperature:	-20 °F
UCS-68(c) reduction: No	Computed Minimum Temperature:	-153 °F

Host Component: Head 1 - 96" OD FLANGED & DISHED HEAD C/W 1.5" SF (RIGHT SIDE)

Material: SA-516 Gr. 70	Head wall thickness(new):	0.4375 in.
Material Stress(S _y): 20000 PSI	Head wall thickness - thin out (corroded):	0.3750 in.


Nozzle Detail Information

Fig. UW-16.1 (c)

Upper Weld Leg Size(Weld 41): 0.3750 in.

Internal Weld Leg Size(Weld 43): 0.3750 in.

Nozzle Wall Thickness(t_n): 0.5620 in.

Outside Groove Weld Depth: 0.4375 in.

tangential to the vessel wall, attached by a groove weld.

Pipe Size: 18 Schedule: 40

Nozzle is adequate for UG-45 requirements.

Opening is adequately reinforced for Internal Pressure.

Weld Strength Paths are adequate.

PLATINUM ENERGY SERVICES ULC

18" 150# RFSO (M1)

Job No: 30137 & 30138
 Number: 33
 ID Number: 33

Vessel Number: 01
 Mark Number: M1

Date Printed: 2/12/2016

Required Head Thickness per Paragraph UG-37(a)

$$t_r = \frac{P L o M}{(2 S E + P * (M - 0.2))} = \frac{78.50 * 96.0000 * 1.0000}{(2 * 20000 * 1 + 78.50 * (1.0000 - 0.2))} = \mathbf{0.1881 \text{ in.}}$$

Nozzle Required Thickness Calculations**Required Nozzle Thickness for Internal Pressure per Paragraph UG-37(a)**

$$t_{rn} = \frac{P R n}{S E - 0.6 P} = \frac{78.50 * 8.5005}{17100 * 1 - 0.6 * 78.50} = \mathbf{0.0391 \text{ in.}}$$

Strength Reduction Factors

$$f r 1 = \min \left\{ \frac{S_n}{S_v}, 1.0000 \right\} = \min \left\{ \frac{17100}{20000}, 1.0000 \right\} = 0.8550 \quad f r 2 = \min \left\{ \frac{S_n}{S_v}, 1.0000 \right\} = \min \left\{ \frac{17100}{20000}, 1.0000 \right\} = 0.8550$$

UG-45 Thickness Calculations**Nozzle Thickness for Pressure Loading (plus corrosion)**

$$t_a = \frac{P R n}{S E - 0.6 P} + C a + \text{ext. Ca} = \frac{78.50 * 8.5005}{17100 * 1.00 - 0.6 * 78.50} + 0.0625 + 0.0000 = \mathbf{0.1016 \text{ in.}}$$

Nozzle Thickness for Internal Pressure (plus corrosion) Based on Host

$$t_{b1} = \frac{P L o M}{(2 S E + P * (M - 0.2))} + C a + \text{ext. Ca} = \frac{78.50 * 96.0000 * 1.7631}{(2 * 20000 * 1 + 78.50 * (1.7631 - 0.2))} + 0.0625 + 0.0000 = \mathbf{0.3937 \text{ in.}}$$

Minimum Thickness (plus corrosion) per Table UG-45

$$t_{b3} = \text{minimum thickness (Table UG-45) + Ca + ext. Ca} = \mathbf{0.3905 \text{ in.}}$$

Nozzle Minimum Thickness Based on Host and Table UG-45

$$t_b = \min[t_{b3}, \max(t_{b1}, t_{b2})] = \mathbf{0.3905 \text{ in.}}$$

$$t_{UG-45} = \max(t_a, t_b) = \mathbf{0.3905 \text{ in.}}$$

Wall thickness = $t_n * 0.875(\text{pipe}) = \mathbf{0.4920}$ is greater than or equal to UG-45 value of **0.3905**

PLATINUM ENERGY SERVICES ULC

18" 150# RFSO (M1)

Job No: 30137 & 30138
 Number: 33
 ID Number: 33

Vessel Number: 01
 Mark Number: M1

Date Printed: 2/12/2016

Limits of Reinforcement (UG-40)

$$\begin{aligned}
 L_{par} &= \max(d, R_n + t + t_h) = \max(17.7811, 8.5005 + 0.3750 + 0.4995) &= 17.7811 \text{ in.} \\
 L_{noro} &= \min(2.5 t, 2.5 t_h + t_e) = \min(2.5 * 0.3750, 2.5 * 0.4995 + 0.0000) &= 0.9375 \text{ in.} \\
 L_{nori} &= \min(2.5 t, 2.5 t_i) = \min(2.5 * 0.3750, 2.5 * 0.4370) &= 0.9375 \text{ in.}
 \end{aligned}$$

Nozzle Reinforcement Calculations (Internal Pressure)

$$A = \max\{C [d t_r F + 2 t_n t_r F (1 - f_{r1})], 0\} = \max\{1.0000 * [17.7811 * 0.1881 * 1.00 + 2 * 0.4995 * 0.1881 * 1.00 * (1 - 0.8550)], 0\} \\
 = 3.3719 \text{ sq. in.}$$

$$\begin{aligned}
 A1 &= \max\{2 L_{par} - d\} (E_1 t - F t_r) - 2 t_n (E_1 t - F t_r) (1 - f_{r1}), 0\} = \\
 &\max\{2 * 17.7811 - 17.7811\} * (1.0000 * 0.3750 - 1.00 * 0.1881) - 2 * 0.4995 * (1.0000 * 0.3750 - 1.00 * 0.1881) * (1 - 0.8550), 0\} \\
 &= 3.2962 \text{ sq. in.}
 \end{aligned}$$

$$\begin{aligned}
 A2 &= \max\{2 \min(h_o, L_{noro}) [\min(t_h, L_{par} - 0.5 d) - t_{rn}] f_{r2}, 0\} = \\
 &\max\{2 * \min(10.0000, 0.9375) * [\min(0.4995, 17.7811 - 0.5 * 17.7811) - 0.0391] * 0.8550, 0\} \\
 &= 0.7381 \text{ sq. in.}
 \end{aligned}$$

$$\begin{aligned}
 A3 &= \max\{2 \min(h, L_{nori}) \min(t_i, L_{par} - 0.5 d) f_{r2}, 0\} = \\
 &\max\{2 * \min(0.3125, 0.9375) * \min(0.4370, 17.7811 - 0.5 * 17.7811) * 0.8550, 0\} \\
 &= 0.2335 \text{ sq. in.}
 \end{aligned}$$

$$\begin{aligned}
 A41 &= f_{r2} [L_{41}^2 - (L_{41} - L_{41pareff})^2 - (L_{41} - L_{41noreff})^2] = \\
 &0.8550 * [0.3750^2 - (0.3750 - 0.3750)^2 - (0.3750 - 0.3750)^2] \\
 &= 0.1202 \text{ sq. in.}
 \end{aligned}$$

$$\begin{aligned}
 A42 &= f_{r4} L_{42pareff} L_{42noreff} = \\
 &0.0000 * 0.0000 * 0.0000 \\
 &= 0.0000 \text{ sq. in.}
 \end{aligned}$$

$$\begin{aligned}
 A43 &= f_{r2} [L_{43}^2 - (L_{43} - L_{43pareff})^2 - (L_{43} - L_{43noreff})^2] = \\
 &0.8550 * [0.2857^2 - (0.2857 - 0.2857)^2 - (0.2857 - 0.2857)^2] \\
 &= 0.0698 \text{ sq. in.}
 \end{aligned}$$

$$\begin{aligned}
 A5 &= \\
 &= 0.0000 \text{ sq. in.}
 \end{aligned}$$

$$\text{Area Available (Internal Pressure)} = A1 + A2 + A3 + A41 + A42 + A43 + A5 = 4.4578 \text{ sq. in., which is } \geq A (3.3719)$$

PLATINUM ENERGY SERVICES ULC

18" 150# RFSO (M2)

Job No: 30137 & 30138
 Number: 34
 ID Number: 34

Vessel Number: 01
 Mark Number: M2

Date Printed: 2/12/2016

Nozzle Design Information

Design Pressure:	75.00 PSI	Design Temperature:	350 °F
Static Head:	3.50 PSI	Nozzle Efficiency (E):	100 %
Nozzle Material:	SA-106 Gr. B	Joint Efficiency (E ₁):	1.00
		Factor B Chart:	CS-2
External Projection:	10.0000 in.	Allowable Stress at Design Temperature (S):	17100 PSI
Internal Projection:	1.0000 in.	Allowable Stress at Ambient Temperature:	17100 PSI
Inside Corrosion Allowance:	0.0625 in.	Correction Factor (F):	1.00
External Corrosion Allowance:	0.0000 in.	Nozzle Path:	None
Nozzle Pipe Size:	18	Nozzle Pipe Schedule:	40
Nozzle ID (new):	16.8760 in.	Nozzle Wall Thickness(new):	0.5620 in.
Nozzle ID (corroded):	17.0010 in.	Nozzle Wall Thickness(corroded):	0.4995 in.
External Limit of Reinforcement:	0.7813 in.	Upper Weld Leg Size(Weld 41):	0.5000 in.
Internal Limit of Reinforcement:	0.7813 in.	Internal Weld Leg Size(Weld 43):	0.5000 in.
Parallel Limit of Reinf (2Lpar):	34.0020 in.	Outside Groove Weld Depth:	0.3750 in.

Minimum Design Metal Temperature

Min. Temp. Curve: B	Pressure at MDMT:	75.00 PSI
UCS-66(b) reduction: Yes	Minimum Design Metal Temperature:	-20 °F
UCS-68(c) reduction: No	Computed Minimum Temperature:	-155 °F

Host Component: Shell 1 - 8'-0" OD x 30'-0" LONG SHELL

Material:	SA-516 Gr. 70	Shell wall thickness(new):	0.3750 in.
Material Stress(S _y):	20000 PSI	Shell wall thickness(corroded):	0.3125 in.


Nozzle Detail Information

Fig. UW-16.1 (c)

Upper Weld Leg Size(Weld 41): 0.5000 in.

Internal Weld Leg Size(Weld 43): 0.5000 in.

Nozzle Wall Thickness(t_n): 0.5620 in.

Outside Groove Weld Depth: 0.3750 in.

Nozzle passes through the vessel, attached by a groove weld.

Pipe Size: 18 Schedule: 40

Nozzle is adequate for UG-45 requirements.

Opening is adequately reinforced for Internal Pressure.

Weld Strength Paths are adequate.

PLATINUM ENERGY SERVICES ULC

18" 150# RFSO (M2)

Job No: 30137 & 30138
 Number: 34
 ID Number: 34

Vessel Number: 01
 Mark Number: M2

Date Printed: 2/12/2016

Required Shell Thickness per Paragraph UG-37(a)

$$t_r = \frac{P R_o}{S E + 0.4 P} = \frac{78.50 * 48.0000}{20000 * 1 + 0.4 * 78.50} = \mathbf{0.1881 \text{ in.}}$$

Nozzle Required Thickness Calculations**Required Nozzle Thickness for Internal Pressure per Paragraph UG-37(a)**

$$t_{rn} = \frac{P R_n}{S E - 0.6 P} = \frac{78.50 * 8.5005}{17100 * 1 - 0.6 * 78.50} = \mathbf{0.0391 \text{ in.}}$$

Strength Reduction Factors

$$f_{r1} = \min \left\{ \frac{S_n}{S_v}, 1.0000 \right\} = \min \left\{ \frac{17100}{20000}, 1.0000 \right\} = 0.8550 \quad f_{r2} = \min \left\{ \frac{S_n}{S_v}, 1.0000 \right\} = \min \left\{ \frac{17100}{20000}, 1.0000 \right\} = 0.8550$$

UG-45 Thickness Calculations**Nozzle Thickness for Pressure Loading (plus corrosion)**

$$t_a = \frac{P R_n}{S E - 0.6 P} + C_a + \text{ext. Ca} = \frac{78.50 * 8.5005}{17100 * 1.00 - 0.6 * 78.50} + 0.0625 + 0.0000 = \mathbf{0.1016 \text{ in.}}$$

Nozzle Thickness for Internal Pressure (plus corrosion) Based on Host

$$t_{b1} = \frac{P R_o}{S E + 0.4 P} + C_a + \text{ext. Ca} = \frac{78.50 * 48.0000}{20000 * 1 + 0.4 * 78.50} + 0.0625 + 0.0000 = \mathbf{0.2506 \text{ in.}}$$

Minimum Thickness (plus corrosion) per Table UG-45

$$t_{b3} = \text{minimum thickness (Table UG-45) + } C_a + \text{ext. Ca} = \mathbf{0.3905 \text{ in.}}$$

Nozzle Minimum Thickness Based on Host and Table UG-45

$$t_b = \min[t_{b3}, \max(t_{b1}, t_{b2})] = \mathbf{0.2506 \text{ in.}}$$

$$t_{UG-45} = \max(t_a, t_b) = \mathbf{0.2506 \text{ in.}}$$

Wall thickness = $t_n * 0.875(\text{pipe}) = \mathbf{0.4920}$ is greater than or equal to UG-45 value of **0.2506**

PLATINUM ENERGY SERVICES ULC

18" 150# RFSO (M2)

Job No: 30137 & 30138
 Number: 34
 ID Number: 34

Vessel Number: 01
 Mark Number: M2

Date Printed: 2/12/2016

Limits of Reinforcement (UG-40)

$$\begin{aligned}
 L_{par} &= \max(d, R_n + t + t_h) = \max(17.0010, 8.5005 + 0.3125 + 0.4995) &= 17.0010 \text{ in.} \\
 L_{noro} &= \min(2.5 t, 2.5 t_h + t_e) = \min(2.5 * 0.3125, 2.5 * 0.4995 + 0.0000) &= 0.7813 \text{ in.} \\
 L_{nori} &= \min(2.5 t, 2.5 t_i) = \min(2.5 * 0.3125, 2.5 * 0.4370) &= 0.7813 \text{ in.}
 \end{aligned}$$

Nozzle Reinforcement Calculations (Internal Pressure)

$$A = \max\{C [d t_r F + 2 t_n t_r F (1 - f_{r1})], 0\} = \max\{1.0000 * [17.0010 * 0.1881 * 1.00 + 2 * 0.4995 * 0.1881 * 1.00 * (1 - 0.8550)], 0\} \\
 = 3.2251 \text{ sq. in.}$$

$$\begin{aligned}
 A1 &= \max\{[2 L_{par} - d] (E_1 t - F t_r) - 2 t_n (E_1 t - F t_r) (1 - f_{r1}), 0\} = \\
 &\max\{[2 * 17.0010 - 17.0010] * (1.0000 * 0.3125 - 1.00 * 0.1881) - 2 * 0.4995 * (1.0000 * 0.3125 - 1.00 * 0.1881) * (1 - 0.8550), 0\} \\
 &= 2.0969 \text{ sq. in.}
 \end{aligned}$$

$$\begin{aligned}
 A2 &= \max\{2 \min(h_o, L_{noro}) [\min(t_h, L_{par} - 0.5 d) - t_{rn}] f_{r2}, 0\} = \\
 &\max\{2 * \min(10.0000, 0.7813) * [\min(0.4995, 17.0010 - 0.5 * 17.0010) - 0.0391] * 0.8550, 0\} \\
 &= 0.6151 \text{ sq. in.}
 \end{aligned}$$

$$\begin{aligned}
 A3 &= \max\{2 \min(h, L_{nori}) \min(t_i, L_{par} - 0.5 d) f_{r2}, 0\} = \\
 &\max\{2 * \min(0.9375, 0.7813) * \min(0.4370, 17.0010 - 0.5 * 17.0010) * 0.8550, 0\} \\
 &= 0.5838 \text{ sq. in.}
 \end{aligned}$$

$$\begin{aligned}
 A41 &= f_{r2} [L_{41}^2 - (L_{41} - L_{41pareff})^2 - (L_{41} - L_{41noreff})^2] = \\
 &0.8550 * [0.5000^2 - (0.5000 - 0.5000)^2 - (0.5000 - 0.5000)^2] \\
 &= 0.2138 \text{ sq. in.}
 \end{aligned}$$

$$\begin{aligned}
 A42 &= f_{r4} L_{42pareff} L_{42noreff} = \\
 &0.0000 * 0.0000 * 0.0000 \\
 &= 0.0000 \text{ sq. in.}
 \end{aligned}$$

$$\begin{aligned}
 A43 &= f_{r2} [L_{43}^2 - (L_{43} - L_{43pareff})^2 - (L_{43} - L_{43noreff})^2] = \\
 &0.8550 * [0.4107^2 - (0.4107 - 0.4107)^2 - (0.4107 - 0.4107)^2] \\
 &= 0.1442 \text{ sq. in.}
 \end{aligned}$$

$$\begin{aligned}
 A5 &= \\
 &= 0.0000 \text{ sq. in.}
 \end{aligned}$$

$$\text{Area Available (Internal Pressure)} = A1 + A2 + A3 + A41 + A42 + A43 + A5 = 3.6538 \text{ sq. in., which is } \geq A (3.2251)$$

PLATINUM ENERGY SERVICES ULC

2" 6000# CPLG (C1)

Job No: 30137 & 30138
 Number: 35
 ID Number: 35

Vessel Number: 01
 Mark Number: C1

Date Printed: 2/12/2016

Nozzle Design Information

Design Pressure:	75.00 PSI	Design Temperature:	350 °F
Static Head:	3.50 PSI	Nozzle Efficiency (E):	100 %
Nozzle Material:	SA-105	Joint Efficiency (E ₁):	1.00
		Factor B Chart:	CS-2
External Projection:	4.0000 in.	Allowable Stress at Design Temperature (S _d):	20000 PSI
Internal Projection:	0.0000 in.	Allowable Stress at Ambient Temperature:	20000 PSI
Inside Corrosion Allowance:	0.0625 in.	Correction Factor (F):	1.00
External Corrosion Allowance:	0.0000 in.	Nozzle Path:	None
Nozzle ID (new):	2.3750 in.	Nozzle Wall Thickness(new):	0.6250 in.
Nozzle ID (corroded):	2.5000 in.	Nozzle Wall Thickness(corroded):	0.5625 in.
Developed Opening:	2.5646 in.	Tangential Dimension L:	18.0000 in.
External Limit of Reinforcement:	0.7813 in.	Upper Weld Leg Size(Weld 41):	0.3750 in.
Internal Limit of Reinforcement:	0.7813 in.	Internal Weld Leg Size(Weld 43):	0.0000 in.
Parallel Limit of Reinf (2Lpar):	5.3980 in.	Outside Groove Weld Depth:	0.3750 in.

Minimum Design Metal Temperature

Min. Temp. Curve:	B	Pressure at MDMT:	75.00 PSI
UCS-66(b) reduction:	Yes	Minimum Design Metal Temperature:	-20 °F
UCS-68(c) reduction:	No	Computed Minimum Temperature:	-155 °F

Host Component: Shell 1 - 8'-0" OD x 30'-0" LONG SHELL

Material:	SA-516 Gr. 70	Shell wall thickness(new):	0.3750 in.
Material Stress(S _y):	20000 PSI	Shell wall thickness(corroded):	0.3125 in.


Nozzle Detail Information

Fig. UW-16.1 (c)

Upper Weld Leg Size(Weld 41): 0.3750 in.

Nozzle Wall Thickness(t_n): 0.6250 in.

Outside Groove Weld Depth: 0.3750 in.

tangential to the vessel wall, attached by a groove weld.

Nozzle is adequate for UG-45 requirements.

Opening is adequately reinforced for Internal Pressure.

Reinforcement calculations are not required per UG-36(c)(3)(a) See Uw-14 for exceptions.

Weld Strength Paths are adequate.

PLATINUM ENERGY SERVICES ULC

2" 6000# CPLG (C1)

Job No: 30137 & 30138
 Number: 35
 ID Number: 35

Vessel Number: 01
 Mark Number: C1

Date Printed: 2/12/2016

Required Shell Thickness per Paragraph UG-37(a)

$$t_r = \frac{P R_o}{S E + 0.4 P} = \frac{78.50 * 48.0000}{20000 * 1 + 0.4 * 78.50} = \mathbf{0.1881 \text{ in.}}$$

Nozzle Required Thickness Calculations**Required Nozzle Thickness for Internal Pressure per Paragraph UG-37(a)**

$$t_{rn} = \frac{P R_n}{S E - 0.6 P} = \frac{78.50 * 1.2500}{20000 * 1 - 0.6 * 78.50} = \mathbf{0.0049 \text{ in.}}$$

Strength Reduction Factors

$$f_{r1} = \min \left\{ \frac{S_n}{S_v}, 1.0000 \right\} = \min \left\{ \frac{20000}{20000}, 1.0000 \right\} = 1.0000 \quad f_{r2} = \min \left\{ \frac{S_n}{S_v}, 1.0000 \right\} = \min \left\{ \frac{20000}{20000}, 1.0000 \right\} = 1.0000$$

UG-45 Thickness Calculations**Nozzle Thickness for Pressure Loading (plus corrosion)**

$$t_a = \frac{P R_n}{S E - 0.6 P} + C_a + \text{ext. Ca} = \frac{78.50 * 1.2500}{20000 * 1.00 - 0.6 * 78.50} + 0.0625 + 0.0000 = \mathbf{0.0674 \text{ in.}}$$

Nozzle Thickness for Internal Pressure (plus corrosion) Based on Host

$$t_{b1} = \frac{P R_o}{S E + 0.4 P} + C_a + \text{ext. Ca} = \frac{78.50 * 48.0000}{20000 * 1 + 0.4 * 78.50} + 0.0625 + 0.0000 = \mathbf{0.2506 \text{ in.}}$$

Minimum Thickness (plus corrosion) per Table UG-45

$$t_{b3} = \text{minimum thickness (Table UG-45) + } C_a + \text{ext. Ca} = \mathbf{0.2605 \text{ in.}}$$

Nozzle Minimum Thickness Based on Host and Table UG-45

$$t_b = \min[t_{b3}, \max(t_{b1}, t_{b2})] = \mathbf{0.2506 \text{ in.}}$$

$$t_{UG-45} = \max(t_a, t_b) = \mathbf{0.2506 \text{ in.}}$$

Wall thickness = $t_n = \mathbf{0.6250}$ is greater than or equal to UG-45 value of $\mathbf{0.2506}$

PLATINUM ENERGY SERVICES ULC
TWO (2) SUPPORT SADDLES

Job No: 30137 & 30138
Number: 1

Vessel Number: 01
Mark Number: SDL1

Date Printed: 2/12/2016

Saddle Design Information

Design Temperature: 350 °F	Support Type: Type II
Material: SA-36	Stiffener Quantity: 4
Condition:	Material Stress (hot): 16600 PSI
Length (d): 83.7880 in.	Material Stress (cold): 16600 PSI
Top Width (b'): 24.0000 in.	Yield Strength: 31300 PSI
Bottom Width (b _b): 9.0000 in.	Density: 0.2800 lb/in. ³
Outside Stiffener Thickness (t _o): 0.5000 in.	Web Plate Thickness (t _w): 0.5000 in.
Inside Stiffener Thickness (t _i): 0.5000 in.	Vessel Centerline Height (h): 61.0000 in.
Saddle Angle of contact (n): 120.0 °	Elevation above grade (g): 0.0000 in.
Dist. from saddle centerline to tang. line (A): 36.0000 in.	
Support Design Condition: Shell unstiffened (A/R > 1/2)	

Wear Plate Information

Design Temperature: 350 °F	Material Stress (hot): 20000 PSI
Material: SA-516 Gr. 70	Material Stress (cold): 20000 PSI
Condition: Normalized	Use for S2: Yes
Extension (j _w): 5.0000 in.	Use for S3: Yes
Width (b _w): 25.0000 in.	Use for S5: Yes
Thickness (t _{wp}): 0.3750 in.	

Base Plate Information

Design Temperature: 350 °F	Ultimate 28 Day Concrete Strength: 3000.00 PSI
Material: SA-36	Yield Strength: 31300 PSI
Condition:	Length (m): 87.0000 in.
Width (b _b): 10.0000 in.	Thickness (t _b): 1.0000 in.

Anchor Bolt Information

Material: SA-449 Gr. 1	Material Stress (hot): 20200 PSI
Condition:	Material Stress (cold): 20200 PSI
Size: 1"	Number of Threads per in. : 8.0000
Quantity: 2	Root Area: 0.5510 sq. in.
Anchor bolt slot width: 1.2500 in.	Slot Length: 1.6954 in.
Sliding saddle to support longitudinal Loads: Yes	
Coeff. of thermal exp. from 70° to MDMT: 6.40 10 ⁻⁶ in/in/°F	
Coeff. therm. exp. from 70° to design temp: 7.00 10 ⁻⁶ in/in/°F	

PLATINUM ENERGY SERVICES ULC
TWO (2) 8'-0" OD x 30'-0" LONG TREATERS

Job No: 30137 & 30138

Vessel Number:01

Date Printed: 2/12/2016

ASME Flange Design Information

Host	Description	Type	Size (in.)	Material	ASME Class	Material Group	MAP (PSI)
4" 150# RFSO (N1)	4" 150# RFSO (N1)	Slip On	3	SA-105	150	1.1	215.00
18" 150# RFSO (M1)	18" 150# RFSO (M1)	Weld Neck	18	SA-105	150	1.1	215.00
18" 150# RFSO (M1)	18" 150# RFBLIND FLAN	Blind	18	SA-105	150	1.1	215.00
18" 150# RFSO (M2)	18" 150# RFSO (M2)	Weld Neck	18	SA-105	150	1.1	215.00
18" 150# RFSO (M2)	18" 150# RF BLIND	Blind	18	SA-105	150	1.1	215.00

PLATINUM ENERGY SERVICES ULC

Job No: 30137 & 30138

Vessel Number:01

Date Printed: 2/12/2016

Loading Summary

Type	Starting Point (in.)	Ending Point (in.)	Depth (in.)	Density (lb./Ft^3)	Wind Diameter (in.)
Liquid	-	-	108.0000	61.9000	-

PLATINUM ENERGY SERVICES ULC

Job No: 30137 & 30138

Vessel Number:01

Date Printed: 2/12/2016

Zick Analysis**ASCE 7-10 Wind Design Information**

Basic Wind Speed (V): 90 MPH

ASCE 7-10 Seismic Design Information0.2 s Spectral Response Accel (S_s): 0.2501 s Spectral Response Accel. (S_1): 0.100

Response Modification Factor (R): 2.000

Occupancy/Risk Category: IV

Site Class: D

Seismic Design Category: D

Operating Pressurized Condition - Occasional Loads - Seismic Case 8**Seismic Information**

$$V = C_s W = 0.2400 * 111892.00$$

$$= 26854 \text{ lb.}$$

$$F_{LS} = V C_{eh} = 26854.0800 * 0.70$$

$$= 18798 \text{ lb.}$$

$$F_{TS} = \frac{F_{LS}}{2} = \frac{18798}{2}$$

$$= 9399 \text{ lb.}$$

Saddle Support Loads

$$F_L = F_{LS} = 18798$$

$$= 18798 \text{ lb.}$$

$$F_T = F_{TS} = 9399$$

$$= 9399 \text{ lb.}$$

$$Q_L = \frac{F_L h}{L - 2A} = \frac{18798 * 61.0000}{363.0000 - 2 * 36.0000}$$

$$= 3940 \text{ lb.}$$

$$Q_T = \frac{1.5 F_T h}{d} = \frac{1.5 * 9399 * 61.0000}{83.7880}$$

$$= 10264 \text{ lb.}$$

$$Q_W = \frac{W(C_{de} + 0.2 S_{DS} C_{ev})}{2} = \frac{111892(0.60 + 0.2 * 0.2667 * -0.70)}{2}$$

$$= 31479 \text{ lb.}$$

$$Q_N = Q_W = 31479$$

$$= 31479 \text{ lb.}$$

$$Q_C = Q_N + \text{Max}(Q_L, Q_T) = 31479 + \text{Max}(3940, 10264)$$

$$= 41743 \text{ lb.}$$

Saddle Load for Vessel Stress Analysis

$$Q = Q_C = 41743$$

$$= 41743 \text{ lb.}$$

Saddle Load for Support Stress Analysis

$$Q_S = Q_C = 41743$$

$$= 41743 \text{ lb.}$$

PLATINUM ENERGY SERVICES ULC

Job No: 30137 & 30138

Vessel Number:01

Date Printed: 2/12/2016

Zick Calculations

Longitudinal Stress Due to Internal Pressure

$$S_p = \frac{P R}{2 t} = \frac{76.90 * 47.8438}{2 * 0.3125} = 5887 \text{ PSI}$$

Longitudinal Compressive Stress Due to External Pressure

$$S_{pe} = \frac{-P_e R}{2 t} = \frac{-0.00 * 47.8438}{2 * 0.3125} = 0 \text{ PSI}$$

Longitudinal Bending Stress in the Shell at the Midpoint

$$Z_1 = m R^2 t = 3.1416 * 47.8438^2 * 0.3125 = 2247 \text{ in.}^3$$

$$S_1 = \frac{K_1 Q L}{4 Z_1} = \frac{0.57596 * 41743 * 363.0000}{4 * 2247} = 971 \text{ PSI}$$

Longitudinal Bending Stress in the Shell in the Plane of the Saddle

$$S_1' = \frac{K_1' Q L}{4 Z_1} = \frac{0.28585 * 41743 * 363.0000}{4 * 2247} = 482 \text{ PSI}$$

Saddle Plane Tangential Shear Stress

$$t_e = t + t_{wp} = 0.3125 + 0.3750 = 0.6875 \text{ in.}$$

$$S_2 = \frac{K_2 Q}{R t_e} \frac{L - 2 A}{L + \frac{4}{3} H} = \frac{1.17074 * 41743}{47.8438 * 0.6875} \frac{363.0000 - 2 * 36.0000}{363.0000 + \frac{4}{3} * 16.2564} = 1124 \text{ PSI}$$

$$S_{2w} = \frac{K_{2w} Q}{R t} \frac{L - 2 A}{L + \frac{4}{3} H} = \frac{0.99845 * 41743}{47.8438 * 0.3125} \frac{363.0000 - 2 * 36.0000}{363.0000 + \frac{4}{3} * 16.2564} = 2109 \text{ PSI}$$

Circumferential Stress at the Horn of the Saddle

$$t_e^2 = t^2 + t_{wp}^2 = 0.3125^2 + 0.3750^2 = 0.2383 \text{ sq. in.}$$

$$S_3 = - \frac{Q}{4 t_e (b + 1.56 \sqrt{R t})} \frac{L}{L t_e^2} = - \frac{41743}{4 * 0.6875 * (24.0000 + 1.56 * \sqrt{47.8438 * 0.3125})} \frac{12 * 0.03322 * 41743 * 47.8438}{363.0000 * 0.2383} = -9710 \text{ PSI}$$

Circumferential Stress at End of the Wear Plate

$$S_{3w} = - \frac{Q}{4 t (b_w + 1.56 \sqrt{R t})} \frac{L}{L t^2} = - \frac{41743}{4 * 0.3125 * (25.0000 + 1.56 * \sqrt{47.8438 * 0.3125})} \frac{12 * 0.02740 * 41743 * 47.8438}{363.0000 * 0.3125^2} = -19600 \text{ PSI}$$

PLATINUM ENERGY SERVICES ULC

Job No: 30137 & 30138

Vessel Number:01

Date Printed: 2/12/2016

Ring Compression in the Shell Over the Saddle

$$t_e = t + t_{wp} = 0.3125 + 0.3750$$

$$= 0.6875 \text{ in.}$$

$$S_5 = \frac{K_5 Q}{t_e (b + 1.56 \sqrt{R t})} = \frac{0.76027 * 41743}{0.6875 * (0.5000 + 1.56 * \sqrt{47.8438 * 0.3125})}$$

$$= 7067 \text{ PSI}$$

Maximum Splitting Force

$$F_s = K_8 Q_s = 0.20352 * 41743$$

$$= 8496 \text{ lb.}$$

Vessel Stress Ratio Calculations

Any ratio greater than 1 represents an overstressed condition

$$R_{1t} = \frac{S_1 + S_p}{S_{\text{Shell}} E} = \frac{971 + 5887}{20000 * 1.00}$$

$$= 0.3429$$

$$R_{1C} = \frac{-S_1}{-\text{Min}(S_{\text{Shell}}, B_{\text{Shell}})} = \frac{-971}{-\text{Min}(20000, 10942)}$$

$$= 0.0887$$

$$R_{1t}' = \frac{S_1' + S_p}{S_{\text{Shell}} E} = \frac{482 + 5887}{20000 * 1.00}$$

$$= 0.3185$$

$$R_{1C}' = \frac{-S_1'}{-\text{Min}(S_{\text{Shell}}, B_{\text{Shell}})} = \frac{-482}{-\text{Min}(20000, 10942)}$$

$$= 0.0441$$

$$R_2 = \frac{S_2}{0.8 S_{\text{Shell}}} = \frac{1124}{0.8 * 20000}$$

$$= 0.0703$$

$$R_{2W} = \frac{S_{2W}}{0.8 S_{\text{Shell}}} = \frac{2109}{0.8 * 20000}$$

$$= 0.1318$$

$$R_3 = \frac{S_3}{-(1.25 S_{\text{Shell}})} = \frac{-9710}{-(1.25 * 20000)}$$

$$= 0.3884$$

$$R_{3W} = \frac{S_{3W}}{-(1.25 S_{\text{Shell}})} = \frac{-19600}{-(1.25 * 20000)}$$

$$= 0.7840$$

$$R_5 = \frac{S_5}{0.5 Y_{\text{Shell}}} = \frac{7067}{0.5 * 33050}$$

$$= 0.4277$$

Operating Pressurized Condition - Occasional Loads - Wind Case 7

Wind Calculations

$$q_z = 0.00256 K_z K_{zt} K_d V^2 I = 0.00256 * 0.85 * 1.000 * 1.00 * 90^2 * 1.0000 \quad = 17.626$$

$$P = q_z G C_f = 17.626 * 0.89 * 0.70 \quad = 11.0 \text{ lb./Ft.}^2$$

$$F_{LW} = P A_L C_{wi} = 11.0 * 50.2655 * 1.00 \quad = 552 \text{ lb.}$$

$$F_{TW} = \frac{P A_T C_{wi}}{2} = \frac{11.0 * 263.6752 * 1.0000}{2} \quad = 1448 \text{ lb.}$$

Saddle Support Loads

$$F_L = F_{LW} = 552 \quad = 552 \text{ lb.}$$

$$F_T = F_{TW} = 1448 \quad = 1448 \text{ lb.}$$

$$Q_L = \frac{F_L h}{L - 2A} = \frac{552 * 61.0000}{363.0000 - 2 * 36.0000} \quad = 116 \text{ lb.}$$

$$Q_T = \frac{1.5 F_T h}{d} = \frac{1.5 * 1448 * 61.0000}{83.7880} \quad = 1581 \text{ lb.}$$

$$Q_W = \frac{W C_{de}}{2} = \frac{111892 * 0.60}{2} \quad = 33568 \text{ lb.}$$

$$Q_N = Q_W = 33568 \quad = 33568 \text{ lb.}$$

$$Q_C = Q_N + \text{Max}(Q_L, Q_T) = 33568 + \text{Max}(116, 1581) \quad = 35149 \text{ lb.}$$

Saddle Load for Vessel Stress Analysis

$$Q = Q_C = 35149 \quad = 35149 \text{ lb.}$$

Saddle Load for Support Stress Analysis

$$Q_S = Q_C = 35149 \quad = 35149 \text{ lb.}$$

PLATINUM ENERGY SERVICES ULC

Job No: 30137 & 30138

Vessel Number:01

Date Printed: 2/12/2016

Zick Calculations

Longitudinal Stress Due to Internal Pressure

$$S_p = \frac{P R}{2 t} = \frac{77.10 * 47.8438}{2 * 0.3125} = 5902 \text{ PSI}$$

Longitudinal Compressive Stress Due to External Pressure

$$S_{pe} = \frac{-P_e R}{2 t} = \frac{-0.00 * 47.8438}{2 * 0.3125} = 0 \text{ PSI}$$

Longitudinal Bending Stress in the Shell at the Midpoint

$$Z_1 = m R^2 t = 3.1416 * 47.8438^2 * 0.3125 = 2247 \text{ in.}^3$$

$$S_1 = \frac{K_1 Q L}{4 Z_1} = \frac{0.57596 * 35149 * 363.0000}{4 * 2247} = 818 \text{ PSI}$$

Longitudinal Bending Stress in the Shell in the Plane of the Saddle

$$S_1' = \frac{K_1' Q L}{4 Z_1} = \frac{0.28585 * 35149 * 363.0000}{4 * 2247} = 406 \text{ PSI}$$

Saddle Plane Tangential Shear Stress

$$t_e = t + t_{wp} = 0.3125 + 0.3750 = 0.6875 \text{ in.}$$

$$S_2 = \frac{K_2 Q}{R t_e} \frac{L - 2 A}{L + \frac{4}{3} H} = \frac{1.17074 * 35149}{47.8438 * 0.6875} \frac{363.0000 - 2 * 36.0000}{363.0000 + \frac{4}{3} * 16.2564} = 946 \text{ PSI}$$

$$S_{2w} = \frac{K_{2w} Q}{R t} \frac{L - 2 A}{L + \frac{4}{3} H} = \frac{0.99845 * 35149}{47.8438 * 0.3125} \frac{363.0000 - 2 * 36.0000}{363.0000 + \frac{4}{3} * 16.2564} = 1776 \text{ PSI}$$

Circumferential Stress at the Horn of the Saddle

$$t_e^2 = t^2 + t_{wp}^2 = 0.3125^2 + 0.3750^2 = 0.2383 \text{ sq. in.}$$

$$S_3 = - \frac{Q}{4 t_e (b + 1.56 \sqrt{R t})} \frac{L}{L t_e^2} = - \frac{35149}{4 * 0.6875 * (24.0000 + 1.56 * \sqrt{47.8438 * 0.3125})} \frac{12 * 0.03322 * 35149 * 47.8438}{363.0000 * 0.2383} = -8176 \text{ PSI}$$

Circumferential Stress at End of the Wear Plate

$$S_{3w} = - \frac{Q}{4 t (b_w + 1.56 \sqrt{R t})} \frac{L}{L t^2} = - \frac{35149}{4 * 0.3125 * (25.0000 + 1.56 * \sqrt{47.8438 * 0.3125})} \frac{12 * 0.02740 * 35149 * 47.8438}{363.0000 * 0.3125^2} = -16504 \text{ PSI}$$

PLATINUM ENERGY SERVICES ULC

Job No: 30137 & 30138

Vessel Number:01

Date Printed: 2/12/2016

Ring Compression in the Shell Over the Saddle

$$t_e = t + t_{wp} = 0.3125 + 0.3750$$

$$= 0.6875 \text{ in.}$$

$$S_5 = \frac{K_5 Q}{t_e (b + 1.56 \sqrt{R t})} = \frac{0.76027 * 35149}{0.6875 * (0.5000 + 1.56 * \sqrt{47.8438 * 0.3125})}$$

$$= 5951 \text{ PSI}$$

Maximum Splitting Force

$$F_s = K_8 Q_s = 0.20352 * 35149$$

$$= 7154 \text{ lb.}$$

Vessel Stress Ratio Calculations

Any ratio greater than 1 represents an overstressed condition

$$R_{1t} = \frac{S_1 + S_p}{S_{\text{Shell}} E} = \frac{818 + 5902}{20000 * 1.00}$$

$$= 0.3360$$

$$R_{1C} = \frac{-S_1}{-\text{Min}(S_{\text{Shell}}, B_{\text{Shell}})} = \frac{-818}{-\text{Min}(20000, 10942)}$$

$$= 0.0748$$

$$R_{1t}' = \frac{S_1' + S_p}{S_{\text{Shell}} E} = \frac{406 + 5902}{20000 * 1.00}$$

$$= 0.3154$$

$$R_{1C}' = \frac{-S_1'}{-\text{Min}(S_{\text{Shell}}, B_{\text{Shell}})} = \frac{-406}{-\text{Min}(20000, 10942)}$$

$$= 0.0371$$

$$R_2 = \frac{S_2}{0.8 S_{\text{Shell}}} = \frac{946}{0.8 * 20000}$$

$$= 0.0591$$

$$R_{2W} = \frac{S_{2W}}{0.8 S_{\text{Shell}}} = \frac{1776}{0.8 * 20000}$$

$$= 0.1110$$

$$R_3 = \frac{S_3}{-(1.25 S_{\text{Shell}})} = \frac{-8176}{-(1.25 * 20000)}$$

$$= 0.3270$$

$$R_{3W} = \frac{S_{3W}}{-(1.25 S_{\text{Shell}})} = \frac{-16504}{-(1.25 * 20000)}$$

$$= 0.6602$$

$$R_5 = \frac{S_5}{0.5 Y_{\text{Shell}}} = \frac{5951}{0.5 * 33050}$$

$$= 0.3601$$

PLATINUM ENERGY SERVICES ULC

Job No: 30137 & 30138

Vessel Number:01

Date Printed: 2/12/2016

Operating Pressurized Condition - Sustained Loads

Saddle Support Loads

$$Q_L = \frac{F_L h}{L - 2A} = \frac{0 * 61.0000}{363.0000 - 2 * 36.0000} = 0 \text{ lb.}$$

$$Q_T = \frac{1.5 F_T h}{d} = \frac{1.5 * 0 * 61.0000}{83.7880} = 0 \text{ lb.}$$

$$Q_W = \frac{W}{2} = \frac{111892}{2} = 55946 \text{ lb.}$$

$$Q_N = Q_W = 55946 = 55946 \text{ lb.}$$

Saddle Load for Vessel Stress Analysis

$$Q = Q_N = 55946 = 55946 \text{ lb.}$$

Saddle Load for Support Stress Analysis

$$Q_S = Q_N = 55946 = 55946 \text{ lb.}$$

PLATINUM ENERGY SERVICES ULC

Job No: 30137 & 30138

Vessel Number:01

Date Printed: 2/12/2016

Zick Calculations

Longitudinal Stress Due to Internal Pressure

$$S_p = \frac{P R}{2 t} = \frac{78.50 * 47.8438}{2 * 0.3125} = 6009 \text{ PSI}$$

Longitudinal Compressive Stress Due to External Pressure

$$S_{pe} = \frac{-P_e R}{2 t} = \frac{-0.00 * 47.8438}{2 * 0.3125} = 0 \text{ PSI}$$

Longitudinal Bending Stress in the Shell at the Midpoint

$$Z_1 = m R^2 t = 3.1416 * 47.8438^2 * 0.3125 = 2247 \text{ in.}^3$$

$$S_1 = \frac{K_1 Q L}{4 Z_1} = \frac{0.57596 * 55946 * 363.0000}{4 * 2247} = 1301 \text{ PSI}$$

Longitudinal Bending Stress in the Shell in the Plane of the Saddle

$$S_1' = \frac{K_1' Q L}{4 Z_1} = \frac{0.28585 * 55946 * 363.0000}{4 * 2247} = 646 \text{ PSI}$$

Saddle Plane Tangential Shear Stress

$$t_e = t + t_{wp} = 0.3125 + 0.3750 = 0.6875 \text{ in.}$$

$$S_2 = \frac{K_2 Q}{R t_e} \frac{L - 2 A}{L + \frac{4}{3} H} = \frac{1.17074 * 55946}{47.8438 * 0.6875} \frac{363.0000 - 2 * 36.0000}{363.0000 + \frac{4}{3} * 16.2564} = 1506 \text{ PSI}$$

$$S_{2w} = \frac{K_{2w} Q}{R t} \frac{L - 2 A}{L + \frac{4}{3} H} = \frac{0.99845 * 55946}{47.8438 * 0.3125} \frac{363.0000 - 2 * 36.0000}{363.0000 + \frac{4}{3} * 16.2564} = 2826 \text{ PSI}$$

Circumferential Stress at the Horn of the Saddle

$$t_e^2 = t^2 + t_{wp}^2 = 0.3125^2 + 0.3750^2 = 0.2383 \text{ sq. in.}$$

$$S_3 = - \frac{Q}{4 t_e (b + 1.56 \sqrt{R t})} - \frac{12 K_3 Q R}{L t_e^2} = - \frac{55946}{4 * 0.6875 * (24.0000 + 1.56 * \sqrt{47.8438 * 0.3125})} - \frac{12 * 0.03322 * 55946 * 47.8438}{363.0000 * 0.2383} = -13014 \text{ PSI}$$

Circumferential Stress at End of the Wear Plate

$$S_{3w} = - \frac{Q}{4 t (b_w + 1.56 \sqrt{R t})} - \frac{12 K_{3w} Q R}{L t^2} = - \frac{55946}{4 * 0.3125 * (25.0000 + 1.56 * \sqrt{47.8438 * 0.3125})} - \frac{12 * 0.02740 * 55946 * 47.8438}{363.0000 * 0.3125^2} = -26269 \text{ PSI}$$

PLATINUM ENERGY SERVICES ULC

Job No: 30137 & 30138

Vessel Number:01

Date Printed: 2/12/2016

Ring Compression in the Shell Over the Saddle

$$t_e = t + t_{wp} = 0.3125 + 0.3750 = 0.6875 \text{ in.}$$

$$S_5 = \frac{K_5 Q}{t_e (b + 1.56 \sqrt{R t})} = \frac{0.76027 * 55946}{0.6875 * (0.5000 + 1.56 * \sqrt{47.8438 * 0.3125})} = 9471 \text{ PSI}$$

Maximum Splitting Force

$$F_s = K_8 Q_s = 0.20352 * 55946 = 11386 \text{ lb.}$$

Vessel Stress Ratio Calculations

Any ratio greater than 1 represents an overstressed condition

$$R_{1t} = \frac{S_1 + S_p}{S_{Shell} E} = \frac{1301 + 6009}{20000 * 1.00} = 0.3655$$

$$R_{1C} = \frac{-S_1}{- \text{Min}(S_{Shell}, B_{Shell})} = \frac{-1301}{- \text{Min}(20000, 10942)} = 0.1189$$

$$R_{1t'} = \frac{S_1' + S_p}{S_{Shell} E} = \frac{646 + 6009}{20000 * 1.00} = 0.3328$$

$$R_{1C'} = \frac{-S_1'}{- \text{Min}(S_{Shell}, B_{Shell})} = \frac{-646}{- \text{Min}(20000, 10942)} = 0.0590$$

$$R_2 = \frac{S_2}{0.8 S_{Shell}} = \frac{1506}{0.8 * 20000} = 0.0941$$

$$R_{2W} = \frac{S_{2W}}{0.8 S_{Shell}} = \frac{2826}{0.8 * 20000} = 0.1766$$

$$R_3 = \frac{S_3}{- (1.25 S_{Shell})} = \frac{-13014}{- (1.25 * 20000)} = 0.5206$$

$$R_{3W} = \frac{S_{3W}}{- (1.25 S_{Shell})} = \frac{-26269}{- (1.25 * 20000)} = 1.0508$$

$$R_5 = \frac{S_5}{0.5 Y_{Shell}} = \frac{9471}{0.5 * 33050} = 0.5731$$

PLATINUM ENERGY SERVICES ULC

Job No: 30137 & 30138

Vessel Number:01

Date Printed: 2/12/2016

Operating Unpressurized Condition - Sustained Loads

Saddle Support Loads

$$Q_L = \frac{F_L h}{L - 2A} = \frac{0 * 61.0000}{363.0000 - 2 * 36.0000} = 0 \text{ lb.}$$

$$Q_T = \frac{1.5 F_T h}{d} = \frac{1.5 * 0 * 61.0000}{83.7880} = 0 \text{ lb.}$$

$$Q_W = \frac{W}{2} = \frac{111892}{2} = 55946 \text{ lb.}$$

$$Q_N = Q_W = 55946 = 55946 \text{ lb.}$$

Saddle Load for Vessel Stress Analysis

$$Q = Q_N = 55946 = 55946 \text{ lb.}$$

Saddle Load for Support Stress Analysis

$$Q_S = Q_N = 55946 = 55946 \text{ lb.}$$

Zick Calculations

Longitudinal Stress Due to Internal Pressure

$$S_p = \frac{P R}{2 t} = \frac{3.50 * 47.8438}{2 * 0.3125} = 268 \text{ PSI}$$

Longitudinal Compressive Stress Due to External Pressure

$$S_{pe} = 0 \text{ PSI}$$

Longitudinal Bending Stress in the Shell at the Midpoint

$$Z_1 = m R^2 t = 3.1416 * 47.8438^2 * 0.3125 = 2247 \text{ in.}^3$$

$$S_1 = \frac{K_1 Q L}{4 Z_1} = \frac{0.57596 * 55946 * 363.0000}{4 * 2247} = 1301 \text{ PSI}$$

Longitudinal Bending Stress in the Shell in the Plane of the Saddle

$$S_1' = \frac{K_1' Q L}{4 Z_1} = \frac{0.28585 * 55946 * 363.0000}{4 * 2247} = 646 \text{ PSI}$$

Saddle Plane Tangential Shear Stress

$$t_e = t + t_{wp} = 0.3125 + 0.3750 = 0.6875 \text{ in.}$$

$$S_2 = \frac{i}{\phi} \frac{K_2 Q}{R t_e} \frac{\epsilon}{\alpha} \frac{L - 2 A}{L + \frac{4}{3} H} = \frac{i}{\phi} \frac{1.17074 * 55946}{47.8438 * 0.6875} \frac{\epsilon}{\alpha} \frac{363.0000 - 2 * 36.0000}{363.0000 + \frac{4}{3} * 16.2564} = 1506 \text{ PSI}$$

$$S_{2w} = \frac{i}{\phi} \frac{K_{2w} Q}{R t} \frac{\epsilon}{\alpha} \frac{L - 2 A}{L + \frac{4}{3} H} = \frac{i}{\phi} \frac{0.99845 * 55946}{47.8438 * 0.3125} \frac{\epsilon}{\alpha} \frac{363.0000 - 2 * 36.0000}{363.0000 + \frac{4}{3} * 16.2564} = 2826 \text{ PSI}$$

Circumferential Stress at the Horn of the Saddle

$$t_e^2 = t^2 + t_{wp}^2 = 0.3125^2 + 0.3750^2 = 0.2383 \text{ sq. in.}$$

$$S_3 = - \frac{i}{\phi} \frac{Q}{4 t_e (b + 1.56 \sqrt{R t})} \frac{\epsilon}{\alpha} - \frac{i}{\phi} \frac{12 K_3 Q R}{L t_e^2} \frac{\epsilon}{\alpha}$$

$$= - \frac{i}{\phi} \frac{55946}{4 * 0.6875 * (24.0000 + 1.56 * \sqrt{47.8438 * 0.3125})} \frac{\epsilon}{\alpha} - \frac{i}{\phi} \frac{12 * 0.03322 * 55946 * 47.8438}{363.0000 * 0.2383} \frac{\epsilon}{\alpha} = -13014 \text{ PSI}$$

Circumferential Stress at End of the Wear Plate

$$S_{3w} = - \frac{i}{\phi} \frac{Q}{4 t (b_w + 1.56 \sqrt{R t})} \frac{\epsilon}{\alpha} - \frac{i}{\phi} \frac{12 K_{3w} Q R}{L t^2} \frac{\epsilon}{\alpha}$$

$$= - \frac{i}{\phi} \frac{55946}{4 * 0.3125 * (25.0000 + 1.56 * \sqrt{47.8438 * 0.3125})} \frac{\epsilon}{\alpha} - \frac{i}{\phi} \frac{12 * 0.02740 * 55946 * 47.8438}{363.0000 * 0.3125^2} \frac{\epsilon}{\alpha} = -26269 \text{ PSI}$$

PLATINUM ENERGY SERVICES ULC

Job No: 30137 & 30138

Vessel Number:01

Date Printed: 2/12/2016

Ring Compression in the Shell Over the Saddle

$$t_e = t + t_{wp} = 0.3125 + 0.3750 \quad = \mathbf{0.6875 \text{ in.}}$$

$$S_5 = \frac{K_5 Q}{t_e (b + 1.56 \sqrt{R t})} = \frac{0.76027 * 55946}{0.6875 * (0.5000 + 1.56 * \sqrt{47.8438 * 0.3125})} \quad = \mathbf{9471 \text{ PSI}}$$

Maximum Splitting Force

$$F_s = K_8 Q_s = 0.20352 * 55946 \quad = \mathbf{11386 \text{ lb.}}$$

Vessel Stress Ratio Calculations

Any ratio greater than 1 represents an overstressed condition

$$R_{1t} = \frac{S_1 + S_p}{S_{Shell} E} = \frac{1301 + 268}{20000 * 1.00} \quad = \mathbf{0.0784}$$

$$R_{1C} = \frac{-S_1}{- \text{Min}(S_{Shell}, B_{Shell})} = \frac{-1301}{- \text{Min}(20000, 10942)} \quad = \mathbf{0.1189}$$

$$R_{1t'} = \frac{S_1' + S_p}{S_{Shell} E} = \frac{646 + 268}{20000 * 1.00} \quad = \mathbf{0.0457}$$

$$R_{1C'} = \frac{-S_1'}{- \text{Min}(S_{Shell}, B_{Shell})} = \frac{-646}{- \text{Min}(20000, 10942)} \quad = \mathbf{0.0590}$$

$$R_2 = \frac{S_2}{0.8 S_{Shell}} = \frac{1506}{0.8 * 20000} \quad = \mathbf{0.0941}$$

$$R_{2W} = \frac{S_{2W}}{0.8 S_{Shell}} = \frac{2826}{0.8 * 20000} \quad = \mathbf{0.1766}$$

$$R_3 = \frac{S_3}{- (1.25 S_{Shell})} = \frac{-13014}{- (1.25 * 20000)} \quad = \mathbf{0.5206}$$

$$R_{3W} = \frac{S_{3W}}{- (1.25 S_{Shell})} = \frac{-26269}{- (1.25 * 20000)} \quad = \mathbf{1.0508}$$

$$R_5 = \frac{S_5}{0.5 Y_{Shell}} = \frac{9471}{0.5 * 33050} \quad = \mathbf{0.5731}$$

PLATINUM ENERGY SERVICES ULC

Job No: 30137 & 30138

Vessel Number:01

Date Printed: 2/12/2016

Empty Pressurized Condition - Sustained Loads

Saddle Support Loads

$$Q_L = \frac{F_L h}{L - 2A} = \frac{0 * 61.0000}{363.0000 - 2 * 36.0000} = 0 \text{ lb.}$$

$$Q_T = \frac{1.5 F_T h}{d} = \frac{1.5 * 0 * 61.0000}{83.7880} = 0 \text{ lb.}$$

$$Q_W = \frac{W}{2} = \frac{13790}{2} = 6895 \text{ lb.}$$

$$Q_N = Q_W = 6895 = 6895 \text{ lb.}$$

Saddle Load for Vessel Stress Analysis

$$Q = Q_N = 6895 = 6895 \text{ lb.}$$

Saddle Load for Support Stress Analysis

$$Q_S = Q_N = 6895 = 6895 \text{ lb.}$$

PLATINUM ENERGY SERVICES ULC

Job No: 30137 & 30138

Vessel Number:01

Date Printed: 2/12/2016

Zick Calculations

Longitudinal Stress Due to Internal Pressure

$$S_p = \frac{P R}{2 t} = \frac{75.00 * 47.8438}{2 * 0.3125} = 5741 \text{ PSI}$$

Longitudinal Compressive Stress Due to External Pressure

$$S_{pe} = \frac{-P_e R}{2 t} = \frac{-0.00 * 47.8438}{2 * 0.3125} = 0 \text{ PSI}$$

Longitudinal Bending Stress in the Shell at the Midpoint

$$Z_1 = m R^2 t = 3.1416 * 47.8438^2 * 0.3125 = 2247 \text{ in.}^3$$

$$S_1 = \frac{K_1 Q L}{4 Z_1} = \frac{0.57596 * 6895 * 363.0000}{4 * 2247} = 160 \text{ PSI}$$

Longitudinal Bending Stress in the Shell in the Plane of the Saddle

$$S_1' = \frac{K_1' Q L}{4 Z_1} = \frac{0.28585 * 6895 * 363.0000}{4 * 2247} = 80 \text{ PSI}$$

Saddle Plane Tangential Shear Stress

$$t_e = t + t_{wp} = 0.3125 + 0.3750 = 0.6875 \text{ in.}$$

$$S_2 = \frac{K_2 Q}{R t_e} \frac{L - 2 A}{L + \frac{4}{3} H} = \frac{1.17074 * 6895}{47.8438 * 0.6875} \frac{363.0000 - 2 * 36.0000}{363.0000 + \frac{4}{3} * 16.2564} = 186 \text{ PSI}$$

$$S_{2w} = \frac{K_{2w} Q}{R t} \frac{L - 2 A}{L + \frac{4}{3} H} = \frac{0.99845 * 6895}{47.8438 * 0.3125} \frac{363.0000 - 2 * 36.0000}{363.0000 + \frac{4}{3} * 16.2564} = 348 \text{ PSI}$$

Circumferential Stress at the Horn of the Saddle

$$t_e^2 = t^2 + t_{wp}^2 = 0.3125^2 + 0.3750^2 = 0.2383 \text{ sq. in.}$$

$$S_3 = - \frac{Q}{4 t_e (b + 1.56 \sqrt{R t})} \frac{L}{L t_e^2} = - \frac{6895}{4 * 0.6875 * (24.0000 + 1.56 * \sqrt{47.8438 * 0.3125})} \frac{12 * 0.03322 * 6895 * 47.8438}{363.0000 * 0.2383} = -1604 \text{ PSI}$$

Circumferential Stress at End of the Wear Plate

$$S_{3w} = - \frac{Q}{4 t (b_w + 1.56 \sqrt{R t})} \frac{L}{L t^2} = - \frac{6895}{4 * 0.3125 * (25.0000 + 1.56 * \sqrt{47.8438 * 0.3125})} \frac{12 * 0.02740 * 6895 * 47.8438}{363.0000 * 0.3125^2} = -3237 \text{ PSI}$$

PLATINUM ENERGY SERVICES ULC

Job No: 30137 & 30138

Vessel Number:01

Date Printed: 2/12/2016

Ring Compression in the Shell Over the Saddle

$$t_e = t + t_{wp} = 0.3125 + 0.3750 \quad = \mathbf{0.6875 \text{ in.}}$$

$$S_5 = \frac{K_5 Q}{t_e (b + 1.56 \sqrt{R t})} = \frac{0.76027 * 6895}{0.6875 * (0.5000 + 1.56 * \sqrt{47.8438 * 0.3125})} \quad = \mathbf{1167 \text{ PSI}}$$

Maximum Splitting Force

$$F_s = K_8 Q_s = 0.20352 * 6895 \quad = \mathbf{1403 \text{ lb.}}$$

Vessel Stress Ratio Calculations

Any ratio greater than 1 represents an overstressed condition

$$R_{1t} = \frac{S_1 + S_p}{S_{\text{Shell}} E} = \frac{160 + 5741}{20000 * 1.00} \quad = \mathbf{0.2951}$$

$$R_{1C} = \frac{-S_1}{-\text{Min}(S_{\text{Shell}}, B_{\text{Shell}})} = \frac{-160}{-\text{Min}(20000, 10942)} \quad = \mathbf{0.0146}$$

$$R_{1t}' = \frac{S_1' + S_p}{S_{\text{Shell}} E} = \frac{80 + 5741}{20000 * 1.00} \quad = \mathbf{0.2911}$$

$$R_{1C}' = \frac{-S_1'}{-\text{Min}(S_{\text{Shell}}, B_{\text{Shell}})} = \frac{-80}{-\text{Min}(20000, 10942)} \quad = \mathbf{0.0073}$$

$$R_2 = \frac{S_2}{0.8 S_{\text{Shell}}} = \frac{186}{0.8 * 20000} \quad = \mathbf{0.0116}$$

$$R_{2W} = \frac{S_{2W}}{0.8 S_{\text{Shell}}} = \frac{348}{0.8 * 20000} \quad = \mathbf{0.0218}$$

$$R_3 = \frac{S_3}{-(1.25 S_{\text{Shell}})} = \frac{-1604}{-(1.25 * 20000)} \quad = \mathbf{0.0642}$$

$$R_{3W} = \frac{S_{3W}}{-(1.25 S_{\text{Shell}})} = \frac{-3237}{-(1.25 * 20000)} \quad = \mathbf{0.1295}$$

$$R_5 = \frac{S_5}{0.5 Y_{\text{Shell}}} = \frac{1167}{0.5 * 33050} \quad = \mathbf{0.0706}$$

PLATINUM ENERGY SERVICES ULC

Job No: 30137 & 30138

Vessel Number:01

Date Printed: 2/12/2016

Empty Unpressurized Condition - Occasional Loads - Seismic Case 8**Seismic Information**

$$\begin{aligned}
 V &= C_s W = 0.2400 * 13790.00 &= 3310 \text{ lb.} \\
 F_{LS} &= V C_{eh} = 3309.6000 * 0.70 &= 2317 \text{ lb.} \\
 F_{TS} &= \frac{F_{LS}}{2} = \frac{2317}{2} &= 1158 \text{ lb.}
 \end{aligned}$$

Saddle Support Loads

$$\begin{aligned}
 F_L &= F_{LS} = 2317 &= 2317 \text{ lb.} \\
 F_T &= F_{TS} = 1158 &= 1158 \text{ lb.} \\
 Q_L &= \frac{F_L h}{L - 2A} = \frac{2317 * 61.0000}{363.0000 - 2 * 36.0000} &= 486 \text{ lb.} \\
 Q_T &= \frac{1.5 F_T h}{d} = \frac{1.5 * 1158 * 61.0000}{83.7880} &= 1265 \text{ lb.} \\
 Q_W &= \frac{W(C_{de} + 0.2 S_{DS} C_{ev})}{2} = \frac{13790(0.60 + 0.2 * 0.2667 * -0.70)}{2} &= 3880 \text{ lb.} \\
 Q_N &= Q_W = 3880 &= 3880 \text{ lb.} \\
 Q_C &= Q_N + \text{Max}(Q_L, Q_T) = 3880 + \text{Max}(486, 1265) &= 5145 \text{ lb.}
 \end{aligned}$$

Saddle Load for Vessel Stress Analysis

$$Q = Q_C = 5145 \quad = 5145 \text{ lb.}$$

Saddle Load for Support Stress Analysis

$$Q_S = Q_C = 5145 \quad = 5145 \text{ lb.}$$

PLATINUM ENERGY SERVICES ULC

Job No: 30137 & 30138

Vessel Number:01

Date Printed: 2/12/2016

Zick Calculations

Longitudinal Stress Due to Internal Pressure

$$S_p = \quad \quad \quad = 0 \text{ PSI}$$

Longitudinal Compressive Stress Due to External Pressure

$$S_{pe} = \quad \quad \quad = 0 \text{ PSI}$$

Longitudinal Bending Stress in the Shell at the Midpoint

$$Z_1 = m R^2 t = 3.1416 * 47.8438^2 * 0.3125 \quad \quad \quad = 2247 \text{ in.}^3$$

$$S_1 = \frac{K_1 Q L}{4 Z_1} = \frac{0.57596 * 5145 * 363.0000}{4 * 2247} \quad \quad \quad = 120 \text{ PSI}$$

Longitudinal Bending Stress in the Shell in the Plane of the Saddle

$$S_1' = \frac{K_1' Q L}{4 Z_1} = \frac{0.28585 * 5145 * 363.0000}{4 * 2247} \quad \quad \quad = 59 \text{ PSI}$$

Saddle Plane Tangential Shear Stress

$$t_e = t + t_{wp} = 0.3125 + 0.3750 \quad \quad \quad = 0.6875 \text{ in.}$$

$$S_2 = \frac{i}{\phi} \frac{K_2 Q}{R t_e} \frac{\epsilon}{\alpha} \frac{i}{\phi} \frac{L - 2 A}{L + \frac{4}{3} H} \frac{\epsilon}{\alpha} = \frac{i}{\phi} \frac{1.17074 * 5145}{47.8438 * 0.6875} \frac{\epsilon}{\alpha} \frac{i}{\phi} \frac{363.0000 - 2 * 36.0000}{363.0000 + \frac{4}{3} * 16.2564} \frac{\epsilon}{\alpha} \quad \quad \quad = 139 \text{ PSI}$$

$$S_{2w} = \frac{i}{\phi} \frac{K_{2w} Q}{R t} \frac{\epsilon}{\alpha} \frac{i}{\phi} \frac{L - 2 A}{L + \frac{4}{3} H} \frac{\epsilon}{\alpha} = \frac{i}{\phi} \frac{0.99845 * 5145}{47.8438 * 0.3125} \frac{\epsilon}{\alpha} \frac{i}{\phi} \frac{363.0000 - 2 * 36.0000}{363.0000 + \frac{4}{3} * 16.2564} \frac{\epsilon}{\alpha} \quad \quad \quad = 260 \text{ PSI}$$

Circumferential Stress at the Horn of the Saddle

$$t_e^2 = t^2 + t_{wp}^2 = 0.3125^2 + 0.3750^2 \quad \quad \quad = 0.2383 \text{ sq. in.}$$

$$S_3 = - \frac{i}{\phi} \frac{Q}{4 t_e (b + 1.56 \sqrt{R t})} \frac{\epsilon}{\alpha} - \frac{i}{\phi} \frac{12 K_3 Q R}{L t_e^2} \frac{\epsilon}{\alpha}$$

$$= - \frac{i}{\phi} \frac{5145}{4 * 0.6875 * (24.0000 + 1.56 * \sqrt{47.8438 * 0.3125})} \frac{\epsilon}{\alpha} - \frac{i}{\phi} \frac{12 * 0.03322 * 5145 * 47.8438}{363.0000 * 0.2383} \frac{\epsilon}{\alpha} \quad \quad \quad = -1197 \text{ PSI}$$

Circumferential Stress at End of the Wear Plate

$$S_{3w} = - \frac{i}{\phi} \frac{Q}{4 t (b_w + 1.56 \sqrt{R t})} \frac{\epsilon}{\alpha} - \frac{i}{\phi} \frac{12 K_{3w} Q R}{L t^2} \frac{\epsilon}{\alpha}$$

$$= - \frac{i}{\phi} \frac{5145}{4 * 0.3125 * (25.0000 + 1.56 * \sqrt{47.8438 * 0.3125})} \frac{\epsilon}{\alpha} - \frac{i}{\phi} \frac{12 * 0.02740 * 5145 * 47.8438}{363.0000 * 0.3125^2} \frac{\epsilon}{\alpha} \quad \quad \quad = -2416 \text{ PSI}$$

PLATINUM ENERGY SERVICES ULC

Job No: 30137 & 30138

Vessel Number:01

Date Printed: 2/12/2016

Ring Compression in the Shell Over the Saddle

$$t_e = t + t_{wp} = 0.3125 + 0.3750$$

$$= 0.6875 \text{ in.}$$

$$S_5 = \frac{K_5 Q}{t_e (b + 1.56 \sqrt{R t})} = \frac{0.76027 * 5145}{0.6875 * (0.5000 + 1.56 * \sqrt{47.8438 * 0.3125})}$$

$$= 871 \text{ PSI}$$

Maximum Splitting Force

$$F_s = K_8 Q_s = 0.20352 * 5145$$

$$= 1047 \text{ lb.}$$

Vessel Stress Ratio Calculations

Any ratio greater than 1 represents an overstressed condition

$$R_{1t} = \frac{S_1 + S_p}{S_{\text{Shell}} E} = \frac{120 + 0}{20000 * 1.00}$$

$$= 0.0060$$

$$R_{1C} = \frac{-S_1}{-\text{Min}(S_{\text{Shell}}, B_{\text{Shell}})} = \frac{-120}{-\text{Min}(20000, 10942)}$$

$$= 0.0110$$

$$R_{1t}' = \frac{S_1' + S_p}{S_{\text{Shell}} E} = \frac{59 + 0}{20000 * 1.00}$$

$$= 0.0030$$

$$R_{1C}' = \frac{-S_1'}{-\text{Min}(S_{\text{Shell}}, B_{\text{Shell}})} = \frac{-59}{-\text{Min}(20000, 10942)}$$

$$= 0.0054$$

$$R_2 = \frac{S_2}{0.8 S_{\text{Shell}}} = \frac{139}{0.8 * 20000}$$

$$= 0.0087$$

$$R_{2W} = \frac{S_{2W}}{0.8 S_{\text{Shell}}} = \frac{260}{0.8 * 20000}$$

$$= 0.0163$$

$$R_3 = \frac{S_3}{-(1.25 S_{\text{Shell}})} = \frac{-1197}{-(1.25 * 20000)}$$

$$= 0.0479$$

$$R_{3W} = \frac{S_{3W}}{-(1.25 S_{\text{Shell}})} = \frac{-2416}{-(1.25 * 20000)}$$

$$= 0.0966$$

$$R_5 = \frac{S_5}{0.5 Y_{\text{Shell}}} = \frac{871}{0.5 * 33050}$$

$$= 0.0527$$

Empty Unpressurized Condition - Occasional Loads - Wind Case 7

Wind Calculations

$$q_z = 0.00256 K_z K_{zt} K_d V^2 I = 0.00256 * 0.85 * 1.000 * 1.00 * 90^2 * 1.0000 = 17.626$$

$$P = q_z G C_f = 17.626 * 0.89 * 0.70 = 11.0 \text{ lb./Ft.}^2$$

$$F_{LW} = P A_L C_{wi} = 11.0 * 50.2655 * 1.00 = 552 \text{ lb.}$$

$$F_{TW} = \frac{P A_T C_{wi}}{2} = \frac{11.0 * 263.6752 * 1.0000}{2} = 1448 \text{ lb.}$$

Saddle Support Loads

$$F_L = F_{LW} = 552 = 552 \text{ lb.}$$

$$F_T = F_{TW} = 1448 = 1448 \text{ lb.}$$

$$Q_L = \frac{F_L h}{L - 2A} = \frac{552 * 61.0000}{363.0000 - 2 * 36.0000} = 116 \text{ lb.}$$

$$Q_T = \frac{1.5 F_T h}{d} = \frac{1.5 * 1448 * 61.0000}{83.7880} = 1581 \text{ lb.}$$

$$Q_W = \frac{W C_{de}}{2} = \frac{13790 * 0.60}{2} = 4137 \text{ lb.}$$

$$Q_N = Q_W = 4137 = 4137 \text{ lb.}$$

$$Q_C = Q_N + \text{Max}(Q_L, Q_T) = 4137 + \text{Max}(116, 1581) = 5718 \text{ lb.}$$

Saddle Load for Vessel Stress Analysis

$$Q = Q_C = 5718 = 5718 \text{ lb.}$$

Saddle Load for Support Stress Analysis

$$Q_S = Q_C = 5718 = 5718 \text{ lb.}$$

Zick Calculations

Longitudinal Stress Due to Internal Pressure

$$S_p = \quad \quad \quad = 0 \text{ PSI}$$

Longitudinal Compressive Stress Due to External Pressure

$$S_{pe} = \quad \quad \quad = 0 \text{ PSI}$$

Longitudinal Bending Stress in the Shell at the Midpoint

$$Z_1 = m R^2 t = 3.1416 * 47.8438^2 * 0.3125 \quad \quad \quad = 2247 \text{ in.}^3$$

$$S_1 = \frac{K_1 Q L}{4 Z_1} = \frac{0.57596 * 5718 * 363.0000}{4 * 2247} \quad \quad \quad = 133 \text{ PSI}$$

Longitudinal Bending Stress in the Shell in the Plane of the Saddle

$$S_1' = \frac{K_1' Q L}{4 Z_1} = \frac{0.28585 * 5718 * 363.0000}{4 * 2247} \quad \quad \quad = 66 \text{ PSI}$$

Saddle Plane Tangential Shear Stress

$$t_e = t + t_{wp} = 0.3125 + 0.3750 \quad \quad \quad = 0.6875 \text{ in.}$$

$$S_2 = \frac{i}{\phi} \frac{K_2 Q}{R t_e} \frac{\epsilon}{\alpha} \frac{i}{\phi} \frac{L - 2 A}{L + \frac{4}{3} H} \frac{\epsilon}{\alpha} = \frac{i}{\phi} \frac{1.17074 * 5718}{47.8438 * 0.6875} \frac{\epsilon}{\alpha} \frac{i}{\phi} \frac{363.0000 - 2 * 36.0000}{363.0000 + \frac{4}{3} * 16.2564} \frac{\epsilon}{\alpha}$$

$$\quad \quad \quad = 154 \text{ PSI}$$

$$S_{2w} = \frac{i}{\phi} \frac{K_{2w} Q}{R t} \frac{\epsilon}{\alpha} \frac{i}{\phi} \frac{L - 2 A}{L + \frac{4}{3} H} \frac{\epsilon}{\alpha} = \frac{i}{\phi} \frac{0.99845 * 5718}{47.8438 * 0.3125} \frac{\epsilon}{\alpha} \frac{i}{\phi} \frac{363.0000 - 2 * 36.0000}{363.0000 + \frac{4}{3} * 16.2564} \frac{\epsilon}{\alpha}$$

$$\quad \quad \quad = 289 \text{ PSI}$$

Circumferential Stress at the Horn of the Saddle

$$t_e^2 = t^2 + t_{wp}^2 = 0.3125^2 + 0.3750^2 \quad \quad \quad = 0.2383 \text{ sq. in.}$$

$$S_3 = - \frac{i}{\phi} \frac{Q}{4 t_e (b + 1.56 \sqrt{R t})} \frac{\epsilon}{\alpha} - \frac{i}{\phi} \frac{12 K_3 Q R}{L t_e^2} \frac{\epsilon}{\alpha}$$

$$= - \frac{i}{\phi} \frac{5718}{4 * 0.6875 * (24.0000 + 1.56 * \sqrt{47.8438 * 0.3125})} \frac{\epsilon}{\alpha} - \frac{i}{\phi} \frac{12 * 0.03322 * 5718 * 47.8438}{363.0000 * 0.2383} \frac{\epsilon}{\alpha}$$

$$\quad \quad \quad = -1330 \text{ PSI}$$

Circumferential Stress at End of the Wear Plate

$$S_{3w} = - \frac{i}{\phi} \frac{Q}{4 t (b_w + 1.56 \sqrt{R t})} \frac{\epsilon}{\alpha} - \frac{i}{\phi} \frac{12 K_{3w} Q R}{L t^2} \frac{\epsilon}{\alpha}$$

$$= - \frac{i}{\phi} \frac{5718}{4 * 0.3125 * (25.0000 + 1.56 * \sqrt{47.8438 * 0.3125})} \frac{\epsilon}{\alpha} - \frac{i}{\phi} \frac{12 * 0.02740 * 5718 * 47.8438}{363.0000 * 0.3125^2} \frac{\epsilon}{\alpha}$$

$$\quad \quad \quad = -2685 \text{ PSI}$$

PLATINUM ENERGY SERVICES ULC

Job No: 30137 & 30138

Vessel Number:01

Date Printed: 2/12/2016

Ring Compression in the Shell Over the Saddle

$$t_e = t + t_{wp} = 0.3125 + 0.3750$$

$$= 0.6875 \text{ in.}$$

$$S_5 = \frac{K_5 Q}{t_e (b + 1.56 \sqrt{R t})} = \frac{0.76027 * 5718}{0.6875 * (0.5000 + 1.56 * \sqrt{47.8438 * 0.3125})}$$

$$= 968 \text{ PSI}$$

Maximum Splitting Force

$$F_s = K_8 Q_s = 0.20352 * 5718$$

$$= 1164 \text{ lb.}$$

Vessel Stress Ratio Calculations

Any ratio greater than 1 represents an overstressed condition

$$R_{1t} = \frac{S_1 + S_p}{S_{\text{Shell}} E} = \frac{133 + 0}{20000 * 1.00}$$

$$= 0.0067$$

$$R_{1C} = \frac{-S_1}{-\text{Min}(S_{\text{Shell}}, B_{\text{Shell}})} = \frac{-133}{-\text{Min}(20000, 10942)}$$

$$= 0.0122$$

$$R_{1t}' = \frac{S_1' + S_p}{S_{\text{Shell}} E} = \frac{66 + 0}{20000 * 1.00}$$

$$= 0.0033$$

$$R_{1C}' = \frac{-S_1'}{-\text{Min}(S_{\text{Shell}}, B_{\text{Shell}})} = \frac{-66}{-\text{Min}(20000, 10942)}$$

$$= 0.0060$$

$$R_2 = \frac{S_2}{0.8 S_{\text{Shell}}} = \frac{154}{0.8 * 20000}$$

$$= 0.0096$$

$$R_{2W} = \frac{S_{2W}}{0.8 S_{\text{Shell}}} = \frac{289}{0.8 * 20000}$$

$$= 0.0181$$

$$R_3 = \frac{S_3}{-(1.25 S_{\text{Shell}})} = \frac{-1330}{-(1.25 * 20000)}$$

$$= 0.0532$$

$$R_{3W} = \frac{S_{3W}}{-(1.25 S_{\text{Shell}})} = \frac{-2685}{-(1.25 * 20000)}$$

$$= 0.1074$$

$$R_5 = \frac{S_5}{0.5 Y_{\text{Shell}}} = \frac{968}{0.5 * 33050}$$

$$= 0.0586$$

PLATINUM ENERGY SERVICES ULC

Job No: 30137 & 30138

Vessel Number:01

Date Printed: 2/12/2016

Empty Unpressurized Condition - Sustained Loads

Saddle Support Loads

$$Q_L = \frac{F_L h}{L - 2A} = \frac{0 * 61.0000}{363.0000 - 2 * 36.0000} = 0 \text{ lb.}$$

$$Q_T = \frac{1.5 F_T h}{d} = \frac{1.5 * 0 * 61.0000}{83.7880} = 0 \text{ lb.}$$

$$Q_W = \frac{W}{2} = \frac{13790}{2} = 6895 \text{ lb.}$$

$$Q_N = Q_W = 6895 = 6895 \text{ lb.}$$

Saddle Load for Vessel Stress Analysis

$$Q = Q_N = 6895 = 6895 \text{ lb.}$$

Saddle Load for Support Stress Analysis

$$Q_S = Q_N = 6895 = 6895 \text{ lb.}$$

Zick Calculations

Longitudinal Stress Due to Internal Pressure

$$S_p = \quad \quad \quad = 0 \text{ PSI}$$

Longitudinal Compressive Stress Due to External Pressure

$$S_{pe} = \quad \quad \quad = 0 \text{ PSI}$$

Longitudinal Bending Stress in the Shell at the Midpoint

$$Z_1 = m R^2 t = 3.1416 * 47.8438^2 * 0.3125 \quad \quad \quad = 2247 \text{ in.}^3$$

$$S_1 = \frac{K_1 Q L}{4 Z_1} = \frac{0.57596 * 6895 * 363.0000}{4 * 2247} \quad \quad \quad = 160 \text{ PSI}$$

Longitudinal Bending Stress in the Shell in the Plane of the Saddle

$$S_1' = \frac{K_1' Q L}{4 Z_1} = \frac{0.28585 * 6895 * 363.0000}{4 * 2247} \quad \quad \quad = 80 \text{ PSI}$$

Saddle Plane Tangential Shear Stress

$$t_e = t + t_{wp} = 0.3125 + 0.3750 \quad \quad \quad = 0.6875 \text{ in.}$$

$$S_2 = \frac{i}{\phi} \frac{K_2 Q}{R t_e} \frac{\epsilon}{\alpha} \frac{i}{\phi} \frac{L - 2 A}{L + \frac{4}{3} H} \frac{\epsilon}{\alpha} = \frac{i}{\phi} \frac{1.17074 * 6895}{47.8438 * 0.6875} \frac{\epsilon}{\alpha} \frac{i}{\phi} \frac{363.0000 - 2 * 36.0000}{363.0000 + \frac{4}{3} * 16.2564} \frac{\epsilon}{\alpha}$$

$$\quad \quad \quad = 186 \text{ PSI}$$

$$S_{2w} = \frac{i}{\phi} \frac{K_{2w} Q}{R t} \frac{\epsilon}{\alpha} \frac{i}{\phi} \frac{L - 2 A}{L + \frac{4}{3} H} \frac{\epsilon}{\alpha} = \frac{i}{\phi} \frac{0.99845 * 6895}{47.8438 * 0.3125} \frac{\epsilon}{\alpha} \frac{i}{\phi} \frac{363.0000 - 2 * 36.0000}{363.0000 + \frac{4}{3} * 16.2564} \frac{\epsilon}{\alpha}$$

$$\quad \quad \quad = 348 \text{ PSI}$$

Circumferential Stress at the Horn of the Saddle

$$t_e^2 = t^2 + t_{wp}^2 = 0.3125^2 + 0.3750^2 \quad \quad \quad = 0.2383 \text{ sq. in.}$$

$$S_3 = - \frac{i}{\phi} \frac{Q}{4 t_e (b + 1.56 \sqrt{R t})} \frac{\epsilon}{\alpha} - \frac{i}{\phi} \frac{12 K_3 Q R}{L t_e^2} \frac{\epsilon}{\alpha}$$

$$= - \frac{i}{\phi} \frac{6895}{4 * 0.6875 * (24.0000 + 1.56 * \sqrt{47.8438 * 0.3125})} \frac{\epsilon}{\alpha} - \frac{i}{\phi} \frac{12 * 0.03322 * 6895 * 47.8438}{363.0000 * 0.2383} \frac{\epsilon}{\alpha}$$

$$\quad \quad \quad = -1604 \text{ PSI}$$

Circumferential Stress at End of the Wear Plate

$$S_{3w} = - \frac{i}{\phi} \frac{Q}{4 t (b_w + 1.56 \sqrt{R t})} \frac{\epsilon}{\alpha} - \frac{i}{\phi} \frac{12 K_{3w} Q R}{L t^2} \frac{\epsilon}{\alpha}$$

$$= - \frac{i}{\phi} \frac{6895}{4 * 0.3125 * (25.0000 + 1.56 * \sqrt{47.8438 * 0.3125})} \frac{\epsilon}{\alpha} - \frac{i}{\phi} \frac{12 * 0.02740 * 6895 * 47.8438}{363.0000 * 0.3125^2} \frac{\epsilon}{\alpha}$$

$$\quad \quad \quad = -3237 \text{ PSI}$$

PLATINUM ENERGY SERVICES ULC

Job No: 30137 & 30138

Vessel Number:01

Date Printed: 2/12/2016

Ring Compression in the Shell Over the Saddle

$$t_e = t + t_{wp} = 0.3125 + 0.3750 \quad = \mathbf{0.6875 \text{ in.}}$$

$$S_5 = \frac{K_5 Q}{t_e (b + 1.56 \sqrt{R t})} = \frac{0.76027 * 6895}{0.6875 * (0.5000 + 1.56 * \sqrt{47.8438 * 0.3125})} \quad = \mathbf{1167 \text{ PSI}}$$

Maximum Splitting Force

$$F_s = K_8 Q_s = 0.20352 * 6895 \quad = \mathbf{1403 \text{ lb.}}$$

Vessel Stress Ratio Calculations

Any ratio greater than 1 represents an overstressed condition

$$R_{1t} = \frac{S_1 + S_p}{S_{\text{Shell}} E} = \frac{160 + 0}{20000 * 1.00} \quad = \mathbf{0.0080}$$

$$R_{1C} = \frac{-S_1}{-\text{Min}(S_{\text{Shell}}, B_{\text{Shell}})} = \frac{-160}{-\text{Min}(20000, 10942)} \quad = \mathbf{0.0146}$$

$$R_{1t}' = \frac{S_1' + S_p}{S_{\text{Shell}} E} = \frac{80 + 0}{20000 * 1.00} \quad = \mathbf{0.0040}$$

$$R_{1C}' = \frac{-S_1'}{-\text{Min}(S_{\text{Shell}}, B_{\text{Shell}})} = \frac{-80}{-\text{Min}(20000, 10942)} \quad = \mathbf{0.0073}$$

$$R_2 = \frac{S_2}{0.8 S_{\text{Shell}}} = \frac{186}{0.8 * 20000} \quad = \mathbf{0.0116}$$

$$R_{2W} = \frac{S_{2W}}{0.8 S_{\text{Shell}}} = \frac{348}{0.8 * 20000} \quad = \mathbf{0.0218}$$

$$R_3 = \frac{S_3}{-(1.25 S_{\text{Shell}})} = \frac{-1604}{-(1.25 * 20000)} \quad = \mathbf{0.0642}$$

$$R_{3W} = \frac{S_{3W}}{-(1.25 S_{\text{Shell}})} = \frac{-3237}{-(1.25 * 20000)} \quad = \mathbf{0.1295}$$

$$R_5 = \frac{S_5}{0.5 Y_{\text{Shell}}} = \frac{1167}{0.5 * 33050} \quad = \mathbf{0.0706}$$

PLATINUM ENERGY SERVICES ULC

Job No: 30137 & 30138

Vessel Number:01

Date Printed: 2/12/2016

Test Condition

Saddle Support Loads

$$Q_L = \frac{F_L h}{L - 2A} = \frac{0 * 61.0000}{363.0000 - 2 * 36.0000} = 0 \text{ lb.}$$

$$Q_T = \frac{1.5 F_T h}{d} = \frac{1.5 * 0 * 61.0000}{83.7880} = 0 \text{ lb.}$$

$$Q_W = \frac{W}{2} = \frac{112716}{2} = 56358 \text{ lb.}$$

$$Q_N = Q_W = 56358 = 56358 \text{ lb.}$$

Saddle Load for Vessel Stress Analysis

$$Q = Q_N = 56358 = 56358 \text{ lb.}$$

Saddle Load for Support Stress Analysis

$$Q_S = Q_N = 56358 = 56358 \text{ lb.}$$

Zick Calculations

Longitudinal Stress Due to Internal Pressure

$$S_p = \frac{P R}{2 t} = \frac{75.00 * 47.8125}{2 * 0.3750} = 4781 \text{ PSI}$$

Longitudinal Compressive Stress Due to External Pressure

$$S_{pe} = 0 \text{ PSI}$$

Longitudinal Bending Stress in the Shell at the Midpoint

$$Z_1 = m R^2 t = 3.1416 * 47.8125^2 * 0.3750 = 2693 \text{ in.}^3$$

$$S_1 = \frac{K_1 Q L}{4 Z_1} = \frac{0.57592 * 56358 * 363.0000}{4 * 2693} = 1094 \text{ PSI}$$

Longitudinal Bending Stress in the Shell in the Plane of the Saddle

$$S_1' = \frac{K_1' Q L}{4 Z_1} = \frac{0.28625 * 56358 * 363.0000}{4 * 2693} = 544 \text{ PSI}$$

Saddle Plane Tangential Shear Stress

$$t_e = t + t_{wp} = 0.3750 + 0.3750 = 0.7500 \text{ in.}$$

$$S_2 = \frac{i}{\phi} \frac{K_2 Q}{R t_e} \frac{\epsilon}{\alpha} \frac{i}{\phi} \frac{L - 2 A}{L + \frac{4}{3} H} \frac{\epsilon}{\alpha} = \frac{i}{\phi} \frac{1.17074 * 56358}{47.8125 * 0.7500} \frac{\epsilon}{\alpha} \frac{i}{\phi} \frac{363.0000 - 2 * 36.0000}{363.0000 + \frac{4}{3} * 16.2564} \frac{\epsilon}{\alpha} = 1392 \text{ PSI}$$

$$S_{2w} = \frac{i}{\phi} \frac{K_{2w} Q}{R t} \frac{\epsilon}{\alpha} \frac{i}{\phi} \frac{L - 2 A}{L + \frac{4}{3} H} \frac{\epsilon}{\alpha} = \frac{i}{\phi} \frac{0.99845 * 56358}{47.8125 * 0.3750} \frac{\epsilon}{\alpha} \frac{i}{\phi} \frac{363.0000 - 2 * 36.0000}{363.0000 + \frac{4}{3} * 16.2564} \frac{\epsilon}{\alpha} = 2374 \text{ PSI}$$

Circumferential Stress at the Horn of the Saddle

$$t_e^2 = t^2 + t_{wp}^2 = 0.3750^2 + 0.3750^2 = 0.2813 \text{ sq. in.}$$

$$S_3 = - \frac{i}{\phi} \frac{Q}{4 t_e (b + 1.56 \sqrt{R t})} \frac{\epsilon}{\alpha} - \frac{i}{\phi} \frac{12 K_3 Q R}{L t_e^2} \frac{\epsilon}{\alpha} = - \frac{i}{\phi} \frac{56358}{4 * 0.7500 * (24.0000 + 1.56 * \sqrt{47.8125 * 0.3750})} \frac{\epsilon}{\alpha} - \frac{i}{\phi} \frac{12 * 0.03326 * 56358 * 47.8125}{363.0000 * 0.2813} \frac{\epsilon}{\alpha} = -11148 \text{ PSI}$$

Circumferential Stress at End of the Wear Plate

$$S_{3w} = - \frac{i}{\phi} \frac{Q}{4 t (b_w + 1.56 \sqrt{R t})} \frac{\epsilon}{\alpha} - \frac{i}{\phi} \frac{12 K_{3w} Q R}{L t^2} \frac{\epsilon}{\alpha} = - \frac{i}{\phi} \frac{56358}{4 * 0.3750 * (25.0000 + 1.56 * \sqrt{47.8125 * 0.3750})} \frac{\epsilon}{\alpha} - \frac{i}{\phi} \frac{12 * 0.02743 * 56358 * 47.8125}{363.0000 * 0.3750^2} \frac{\epsilon}{\alpha} = -18564 \text{ PSI}$$

PLATINUM ENERGY SERVICES ULC

Job No: 30137 & 30138

Vessel Number:01

Date Printed: 2/12/2016

Ring Compression in the Shell Over the Saddle

$$t_e = t + t_{wp} = 0.3750 + 0.3750 \quad = \mathbf{0.7500 \text{ in.}}$$

$$S_5 = \frac{K_5 Q}{t_e (b + 1.56 \sqrt{R t})} = \frac{0.76027 * 56358}{0.7500 * (0.5000 + 1.56 * \sqrt{47.8125 * 0.3750})} \quad = \mathbf{8040 \text{ PSI}}$$

Maximum Splitting Force

$$F_s = K_8 Q_s = 0.20352 * 56358 \quad = \mathbf{11470 \text{ lb.}}$$

Vessel Stress Ratio Calculations

Any ratio greater than 1 represents an overstressed condition

$$R_{1t} = \frac{S_1 + S_p}{S_{\text{Shell}} E} = \frac{1094 + 4781}{20000 * 1.00} \quad = \mathbf{0.2938}$$

$$R_{1C} = \frac{-S_1}{-\text{Min}(S_{\text{Shell}}, B_{\text{Shell}})} = \frac{-1094}{-\text{Min}(20000, 10942)} \quad = \mathbf{0.1000}$$

$$R_{1t'} = \frac{S_1' + S_p}{S_{\text{Shell}} E} = \frac{544 + 4781}{20000 * 1.00} \quad = \mathbf{0.2663}$$

$$R_{1C'} = \frac{-S_1'}{-\text{Min}(S_{\text{Shell}}, B_{\text{Shell}})} = \frac{-544}{-\text{Min}(20000, 10942)} \quad = \mathbf{0.0497}$$

$$R_2 = \frac{S_2}{0.8 S_{\text{Shell}}} = \frac{1392}{0.8 * 20000} \quad = \mathbf{0.0870}$$

$$R_{2W} = \frac{S_{2W}}{0.8 S_{\text{Shell}}} = \frac{2374}{0.8 * 20000} \quad = \mathbf{0.1484}$$

$$R_3 = \frac{S_3}{-(1.25 S_{\text{Shell}})} = \frac{-11148}{-(1.25 * 20000)} \quad = \mathbf{0.4459}$$

$$R_{3W} = \frac{S_{3W}}{-(1.25 S_{\text{Shell}})} = \frac{-18564}{-(1.25 * 20000)} \quad = \mathbf{0.7426}$$

$$R_5 = \frac{S_5}{0.5 Y_{\text{Shell}}} = \frac{8040}{0.5 * 33050} \quad = \mathbf{0.4865}$$

PLATINUM ENERGY SERVICES ULC

Job No: 30137 & 30138

Vessel Number:01

Date Printed: 2/12/2016

MDMT Report by Components

Design MDMT is -20 °F

Component	Material	Curve	Pressure	MDMT
8'-0" OD x 30'-0" LONG SHELL	SA-516 Gr. 70	D	75.00 PSI	-55 °F
3" 150# RFWN (N6B)	SA-106 Gr. B	B	75.00 PSI	-155 °F
1" 150# RFSO (N8)	SA-106 Gr. B	B	75.00 PSI	-155 °F
3" 150# RFWN (N6C)	SA-106 Gr. B	B	75.00 PSI	-155 °F
1" 150# RFSO (N9)	SA-106 Gr. B	B	75.00 PSI	-155 °F
4" 150# RFSO (N7C)	SA-106 Gr. B	B	75.00 PSI	-155 °F
3" 150# RFSO (N17)	SA-106 Gr. B	B	75.00 PSI	-155 °F
3" 150# RFSO (N18)	SA-106 Gr. B	B	75.00 PSI	-155 °F
3" 150# RFWN (N4)	SA-106 Gr. B	B	75.00 PSI	-155 °F
4" 150# RFSO (N7B)	SA-106 Gr. B	B	75.00 PSI	-155 °F
3" 150# RFSO (N16)	SA-106 Gr. B	B	75.00 PSI	-155 °F
4" 150# RFSO (N1)	SA-106 Gr. B	B	75.00 PSI	-155 °F
2" 6000# CPLG (C1)	SA-105	B	75.00 PSI	-155 °F
3" 150# RFWN (N6A)	SA-106 Gr. B	B	75.00 PSI	-155 °F
4" 150# RFSO (N7A)	SA-106 Gr. B	B	75.00 PSI	-155 °F
18" 150# RFSO (M2)	SA-106 Gr. B	B	75.00 PSI	-155 °F
1" 150# RFSO (N13)	SA-106 Gr. B	B	75.00 PSI	-155 °F
3" 150# RFWN (N6D)	SA-106 Gr. B	B	75.00 PSI	-155 °F
96" OD FLANGED & DISHED HEAD C/W 1.5"	SA-516 Gr. 70	D	75.00 PSI	-55 °F
1" 150# RFSO (N11A)	SA-106 Gr. B	B	75.00 PSI	-155 °F
1" 150# RFSO (N15C)	SA-106 Gr. B	B	75.00 PSI	-155 °F
3" 150# RFSO (N19)	SA-106 Gr. B	B	75.00 PSI	-155 °F
1" 150# RFSO (N11D)	SA-106 Gr. B	B	75.00 PSI	-155 °F
2" 150# RFSO (N10A)	SA-106 Gr. B	B	75.00 PSI	-155 °F
3" 150# RFSO (N3)	SA-106 Gr. B	B	75.00 PSI	-155 °F
1" 150# RFSO (N15A)	SA-106 Gr. B	B	75.00 PSI	-155 °F
1" 150# RFSO (N11B)	SA-106 Gr. B	B	75.00 PSI	-155 °F
8" 150# RFSO (N5)	SA-106 Gr. B	B	75.00 PSI	-153 °F
1" 150# RFSO (N15B)	SA-106 Gr. B	B	75.00 PSI	-155 °F
18" 150# RFSO (M1)	SA-106 Gr. B	B	75.00 PSI	-153 °F
1" 150# RFSO (N14)	SA-106 Gr. B	B	75.00 PSI	-155 °F
1" 150# RFSO (N15E)	SA-106 Gr. B	B	75.00 PSI	-155 °F
1" 150# RFSO (N11C)	SA-106 Gr. B	B	75.00 PSI	-155 °F
1" 150# RFSO (N15D)	SA-106 Gr. B	B	75.00 PSI	-155 °F
1" 150# RFSO (N12)	SA-106 Gr. B	B	75.00 PSI	-155 °F
3" 150# RFSO (N2)	SA-106 Gr. B	B	75.00 PSI	-155 °F
8'-0" OD FLANGED & DISHED HEAD C/W 1.5"	SA-516 Gr. 70	D	75.00 PSI	-55 °F
2" 150# RFSO (N10B)	SA-106 Gr. B	B	75.00 PSI	-155 °F

Component with highest MDMT: 8'-0" OD x 30'-0" LONG SHELL.

Computed MDMT = -55 °F

The required design MDMT of -20 °F has been met or exceeded for the calculated MDMT values.

ASME Flanges Are Not Included in MDMT Calculations.

PLATINUM ENERGY SERVICES ULC
TWO (2) 8'-0" OD x 30'-0" LONG TREATERS

Job No: 30137 & 30138

Vessel Number:01

Date Printed: 2/12/2016

MAWP Report by Components

Component	Design Pressure	Static Head	Vessel MAWP New & Cold UG-98(a)	Component MAWP Hot & Corroded UG-98(b)	Vessel MAWP Hot & Corroded UG-98(a)
8'-0" OD x 30'-0" LONG SHELL	75.00 PSI	3.50 PSI	100.57 PSI	83.73 PSI	80.23 PSI
4" 150# RFSO (N1)	75.00 PSI	3.50 PSI	127.02 PSI	98.67 PSI	95.17 PSI
ASME Flange Class: 150 Gr:1.1	75.00 PSI	3.50 PSI	281.50 PSI	215.00 PSI	211.50 PSI
3" 150# RFWN (N4)	75.00 PSI	3.50 PSI	153.26 PSI	130.56 PSI	127.06 PSI
3" 150# RFWN (N6A)	75.00 PSI	3.50 PSI	153.26 PSI	130.56 PSI	127.06 PSI
3" 150# RFWN (N6B)	75.00 PSI	3.50 PSI	153.26 PSI	130.56 PSI	127.06 PSI
3" 150# RFWN (N6C)	75.00 PSI	3.50 PSI	153.26 PSI	130.56 PSI	127.06 PSI
3" 150# RFWN (N6D)	75.00 PSI	3.50 PSI	153.26 PSI	130.56 PSI	127.06 PSI
4" 150# RFSO (N7A)	75.00 PSI	3.50 PSI	119.99 PSI	94.15 PSI	90.65 PSI
4" 150# RFSO (N7B)	75.00 PSI	3.50 PSI	119.99 PSI	94.15 PSI	90.65 PSI
4" 150# RFSO (N7C)	75.00 PSI	3.50 PSI	119.99 PSI	94.15 PSI	90.65 PSI
1" 150# RFSO (N8)	75.00 PSI	3.50 PSI	153.26 PSI	130.56 PSI	127.06 PSI
1" 150# RFSO (N9)	75.00 PSI	3.50 PSI	153.26 PSI	130.56 PSI	127.06 PSI
1" 150# RFSO (N13)	75.00 PSI	3.50 PSI	153.26 PSI	130.56 PSI	127.06 PSI
3" 150# RFSO (N16)	75.00 PSI	3.50 PSI	153.26 PSI	130.56 PSI	127.06 PSI
3" 150# RFSO (N17)	75.00 PSI	3.50 PSI	153.26 PSI	130.56 PSI	127.06 PSI
3" 150# RFSO (N18)	75.00 PSI	3.50 PSI	153.26 PSI	130.56 PSI	127.06 PSI
18" 150# RFSO (M2)	75.00 PSI	3.50 PSI	100.57 PSI	83.73 PSI	80.23 PSI
ASME Flange Class: 150 Gr:1.1	75.00 PSI	3.50 PSI	281.50 PSI	215.00 PSI	211.50 PSI
ASME Flange Class: 150 Gr:1.1	75.00 PSI	3.50 PSI	281.50 PSI	215.00 PSI	211.50 PSI
2" 6000# CPLG (C1)	75.00 PSI	3.50 PSI	153.26 PSI	130.56 PSI	127.06 PSI
96" OD FLANGED & DISHED HEAD C/W 1.5" SF (RIGHT	75.00 PSI		85.18 PSI	88.93 PSI	85.43 PSI
3" 150# RFSO (N2)	75.00 PSI	3.50 PSI	117.68 PSI	98.92 PSI	95.42 PSI
3" 150# RFSO (N3)	75.00 PSI	3.50 PSI	120.53 PSI	100.80 PSI	97.30 PSI
8" 150# RFSO (N5)	75.00 PSI	3.50 PSI	113.46 PSI	98.00 PSI	94.50 PSI
2" 150# RFSO (N10A)	75.00 PSI	3.50 PSI	179.47 PSI	156.76 PSI	153.26 PSI
1" 150# RFSO (N11A)	75.00 PSI	3.50 PSI	179.47 PSI	156.76 PSI	153.26 PSI
1" 150# RFSO (N11B)	75.00 PSI	3.50 PSI	179.47 PSI	156.76 PSI	153.26 PSI
1" 150# RFSO (N11C)	75.00 PSI	3.50 PSI	179.47 PSI	156.76 PSI	153.26 PSI
1" 150# RFSO (N11D)	75.00 PSI	3.50 PSI	100.01 PSI	88.94 PSI	85.44 PSI
1" 150# RFSO (N12)	75.00 PSI	3.50 PSI	100.01 PSI	88.94 PSI	85.44 PSI
1" 150# RFSO (N14)	75.00 PSI	3.50 PSI	100.01 PSI	88.94 PSI	85.44 PSI
1" 150# RFSO (N15A)	75.00 PSI	3.50 PSI	179.47 PSI	156.76 PSI	153.26 PSI
1" 150# RFSO (N15B)	75.00 PSI	3.50 PSI	100.01 PSI	88.94 PSI	85.44 PSI
1" 150# RFSO (N15C)	75.00 PSI	3.50 PSI	100.01 PSI	88.94 PSI	85.44 PSI
1" 150# RFSO (N15D)	75.00 PSI	3.50 PSI	100.01 PSI	88.94 PSI	85.44 PSI
1" 150# RFSO (N15E)	75.00 PSI	3.50 PSI	100.01 PSI	88.94 PSI	85.44 PSI
3" 150# RFSO (N19)	75.00 PSI	3.50 PSI	85.18 PSI	88.94 PSI	85.44 PSI
18" 150# RFSO (M1)	75.00 PSI	3.50 PSI	105.34 PSI	91.14 PSI	87.64 PSI
ASME Flange Class: 150 Gr:1.1	75.00 PSI	3.50 PSI	281.50 PSI	215.00 PSI	211.50 PSI
ASME Flange Class: 150 Gr:1.1	75.00 PSI	3.50 PSI	281.50 PSI	215.00 PSI	211.50 PSI
8'-0" OD FLANGED & DISHED HEAD C/W 1.5" SF (LEFT	75.00 PSI		114.88 PSI	88.95 PSI	85.45 PSI
2" 150# RFSO (N10B)	75.00 PSI	3.50 PSI	114.89 PSI	88.95 PSI	85.45 PSI

NC = Not Calculated Inc = Incomplete

PLATINUM ENERGY SERVICES ULC
TWO (2) 8'-0" OD x 30'-0" LONG TREATERS

Job No: 30137 & 30138

Vessel Number:01

Date Printed: 2/12/2016

<u>Component</u>	<u>Design Pressure</u>	<u>Static Head</u>	<u>Vessel MAWP New & Cold UG-98(a)</u>	<u>Component MAWP Hot & Corroded UG-98(b)</u>	<u>Vessel MAWP Hot & Corroded UG-98(a)</u>
------------------	------------------------	--------------------	--	---	--

PLATINUM ENERGY SERVICES ULC
TWO (2) 8'-0" OD x 30'-0" LONG TREATERS

Job No: 30137 & 30138

Vessel Number:01

Date Printed: 2/12/2016

Summary

Component with the lowest vessel MAWP(New & Cold) :**96" OD FLANGED & DISHED HEAD C/W 1.5" SF (RIGHT SIDE)**
The lowest vessel MAWP(New & Cold) : **85.18 PSI**

Component with the lowest vessel MAWP(Hot & Corroded) :**8'-0" OD x 30'-0" LONG SHELL**
The lowest vessel MAWP(Hot & Corroded) : **80.23 PSI**

Pressures are exclusive of any external loads.

Flange pressures listed here do not consider external loadings

PLATINUM ENERGY SERVICES ULC

Job No: 30137 & 30138

Vessel Number:01

Date Printed: 2/12/2016

Summary Information

	<u>Dry Weight</u>	<u>Flooded Weight</u>
Shell	11355.68 lb.	104136.38 lb.
Head	2317.26 lb.	8577.41 lb.
Nozzle	317.88 lb.	317.88 lb.
ASME Flange	748.00 lb.	748.00 lb.
Totals	14738.83 lb.	113779.67 lb.
	<u>Volume</u>	
Shell	11106.06 Gal.	
Head	750.62 Gal.	
Nozzle	28.10 Gal.	
Totals	11884.78 Gal.	
	<u>Area</u>	
Shell	753.98 Sq. Ft.	
Head	122.61 Sq. Ft.	
Nozzle	29.56 Sq. Ft.	
Totals	906.15 Sq. Ft.	

PLATINUM ENERGY SERVICES ULC

Job No: 30137 & 30138

Vessel Number: 01

Date Printed: 2/12/2016

Hydrostatic Test Information Par. UG-99(b)
Gauge at Top

Component	Const.	x	STest	/	SDesign	x	Pressure	=	Component Hydro Test Pressure
1" 150# RFSO (N11A)	1.3	x	17100	/	17100	x	75.00	=	97.50
1" 150# RFSO (N11B)	1.3	x	17100	/	17100	x	75.00	=	97.50
1" 150# RFSO (N11C)	1.3	x	17100	/	17100	x	75.00	=	97.50
1" 150# RFSO (N11D)	1.3	x	17100	/	17100	x	75.00	=	97.50
1" 150# RFSO (N12)	1.3	x	17100	/	17100	x	75.00	=	97.50
1" 150# RFSO (N13)	1.3	x	17100	/	17100	x	75.00	=	97.50
1" 150# RFSO (N14)	1.3	x	17100	/	17100	x	75.00	=	97.50
1" 150# RFSO (N15A)	1.3	x	17100	/	17100	x	75.00	=	97.50
1" 150# RFSO (N15B)	1.3	x	17100	/	17100	x	75.00	=	97.50
1" 150# RFSO (N15C)	1.3	x	17100	/	17100	x	75.00	=	97.50
1" 150# RFSO (N15D)	1.3	x	17100	/	17100	x	75.00	=	97.50
1" 150# RFSO (N15E)	1.3	x	17100	/	17100	x	75.00	=	97.50
1" 150# RFSO (N8)	1.3	x	17100	/	17100	x	75.00	=	97.50
1" 150# RFSO (N9)	1.3	x	17100	/	17100	x	75.00	=	97.50
18" 150# RFSO (M1)	1.3	x	17100	/	17100	x	75.00	=	97.50
18" 150# RFSO (M2)	1.3	x	17100	/	17100	x	75.00	=	97.50
2" 150# RFSO (N10A)	1.3	x	17100	/	17100	x	75.00	=	97.50
2" 150# RFSO (N10B)	1.3	x	17100	/	17100	x	75.00	=	97.50
2" 6000# CPLG (C1)	1.3	x	20000	/	20000	x	75.00	=	97.50
3" 150# RFSO (N16)	1.3	x	17100	/	17100	x	75.00	=	97.50
3" 150# RFSO (N17)	1.3	x	17100	/	17100	x	75.00	=	97.50
3" 150# RFSO (N18)	1.3	x	17100	/	17100	x	75.00	=	97.50
3" 150# RFSO (N19)	1.3	x	17100	/	17100	x	75.00	=	97.50
3" 150# RFSO (N2)	1.3	x	17100	/	17100	x	75.00	=	97.50
3" 150# RFSO (N3)	1.3	x	17100	/	17100	x	75.00	=	97.50
3" 150# RFWN (N4)	1.3	x	17100	/	17100	x	75.00	=	97.50
3" 150# RFWN (N6A)	1.3	x	17100	/	17100	x	75.00	=	97.50
3" 150# RFWN (N6B)	1.3	x	17100	/	17100	x	75.00	=	97.50
3" 150# RFWN (N6C)	1.3	x	17100	/	17100	x	75.00	=	97.50
3" 150# RFWN (N6D)	1.3	x	17100	/	17100	x	75.00	=	97.50
4" 150# RFSO (N1)	1.3	x	17100	/	17100	x	75.00	=	97.50
4" 150# RFSO (N7A)	1.3	x	17100	/	17100	x	75.00	=	97.50
4" 150# RFSO (N7B)	1.3	x	17100	/	17100	x	75.00	=	97.50
4" 150# RFSO (N7C)	1.3	x	17100	/	17100	x	75.00	=	97.50
8" 150# RFSO (N5)	1.3	x	17100	/	17100	x	75.00	=	97.50
8'-0" OD FLANGED & DIS	1.3	x	20000	/	20000	x	75.00	=	97.50
8'-0" OD x 30'-0" LONG	1.3	x	20000	/	20000	x	75.00	=	97.50
96" OD FLANGED & DISHE	1.3	x	20000	/	20000	x	75.00	=	97.50

Calculated Test Pressure: 97.50 PSI

Special Notes:

This calculation assumes one chamber.

This calculation is limited by the lowest component pressure per chamber.