



TIE-IN SCHEDULE			
MARK	SIZE / RATING	ELEVATION	DESCRIPTION
TP-A	4" 600# RF	75 13/16" [1926]	GAS INLET
TP-B	4" 600# RF	10" [254]	GAS OUTLET
TP-C	2" NPT	104 3/16" [2646]	PSV OUT
TP-D	1" NPT	4 3/4" [121]	LIQUID OUT
TP-E	1" NPT	30" [762]	SWEET FUEL GAS INLET
TP-F	1" NPT	104 3/16" [2646]	SCRUBBER PSV OUT
TP-G	1" NPT	110" [2794]	INSTRUMENT VENT HEADER
TP-H	2" NPT	50 3/16" [1275]	SURGE TANK FILL
TP-I	2" NPT	86 1/4" [2190]	REBOILER FILL

NOTE: ALL ELEVATION DIMENSIONS FROM TOP OF CHECKER PLATE.

7636  
[25'-0 5/8"]  
OVERALL DIMENSION  
PLAN VIEW

- NOTES:
- SEE DWG GA-01 FOR NOTES.
  - OVERALL DIMENSIONS: 25'-1" L x 11'-4" W x 33'-4" H
  - SHIPPING DIMENSIONS: 22'-7" L x 11'-4" W x 12'-6" H
  - SHIPPING WEIGHT: 27,500 lbs (12,474 kg)

REFERENCE DRAWINGS	REV	DESCRIPTION	BY	DATE	CHK'D	APP'D
GA-06		GENERAL ARRANGEMENT - NW ISOMETRIC VIEW				
GA-05		GENERAL ARRANGEMENT - VIEW 'C-C' & D-D'				
GA-04		GENERAL ARRANGEMENT - VIEW 'B-B'				
GA-03		GENERAL ARRANGEMENT - VIEW 'A-A'				
GA-01		GENERAL ARRANGEMENT - SW ISOMETRIC VIEW				
SKD-01	0	STRUCTURAL STEEL	CL	17-08-24	BX	DG
PID-01	A	PIPING & INSTRUMENTATION DIAGRAM	CL	15-10-20	BX	DG

ENGINEER'S STAMP		DRAWN BY CL 15-10-20		CLIENT STOCK	
		CHK'D BY BX 15-10-20			
		APP'D BY DG 15-10-20			
		CAD REF 30086-GA-02.DWG		SCALE AS SHOWN	
				TITLE 24" OD X 28'-0" 1440 PSI AB SOUR DEHY. PACKAGE GENERAL ARRANGEMENT - PLAN VIEW	
		JOB NO. 30086		DRAWING NO. 30086-GA-02	
				REV 0	

The information contained in this drawing is the confidential property of Platinum Energy Services ULC. No part thereof shall be reproduced or communicated to a third party without written authorization from Platinum Energy Services ULC.